

# CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Amy Lou Barker  New Installation  Septic Tank  
Property Location: SR# 471  Repairs  Nitrification Line  
Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_  
TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Contractor: Mike Ray Registration # \_\_\_\_\_  
Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 50+ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 24-30 in.  
French Drain: \_\_\_\_\_ Linear feet

PERMIT NO. 10834

Date: 1-22-94

Inspected by: Thomas J. Boyle R.S.

Environmental Health Specialist

