

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Kenneth H. Suggs New Installation Septic Tank
Property Location: Lot # 11 Oriahills Creek Repairs Nitrification Line
SR 1120

Number of Bedrooms Proposed: 3 Lot Size: .43 acre

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 100' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-22 in.

French Drain required: _____ Linear feet


This permit is subject to revocation if site plans or intended use change.

Date: 9-20-91

Signed: Hal Owen

Environmental Health Specialist

VOID AFTER 5 YEARS



Oriahills Court