


CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Kenneth Suggs New Installation Septic Tank
 Property Location: SR# 1120 Repairs Nitrification Line
 Subdivision Overhills Crk Lot # 11
 Contractor: Precision Plumbing Registration # 17
 Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: _____ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of 4 exact length below width of _____ depth of _____
 Drainage Field ditches _____ of each ditch _____ ft. ditches 3 ft. ditches 18-22 in.
 French Drain: _____ Linear feet

PERMIT NO. 7809 Date: 10-25-93
 Inspected by: Thomas J. Boyce
 Environmental Health Specialist



* Lower line added
 Due to upper lines
 being too close to
 property line