

HTE# _____

Harnett County Department of Public Health Improvement Permit

25131

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Jesus L NINO PROPERTY LOCATION: Hwy 401N
 NEW REPAIR EXPANSION SUBDIVISION: Foxchase S/D LOT # 16
 Type of Structure: EX M/H Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 25% REDUCTION
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: 30 DAYS
 Permit conditions: CONTRACTOR TO MEET ON SITE PRIOR TO INSTALL - (SOIL SCREEN TEST MUST DETERMINE PROPER DETCH DEPTH) Five years No expiration

Authorized State Agent: James L. Manning Date: 3-18-09 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Jesus L NINO PROPERTY LOCATION: Hwy 401N
 Facility Type: EX M/H New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** _____ (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable)

25% REDUCTION System (Repair)
Installation Requirements/Conditions
 Septic Tank Size EXISTING gallons
 Pump Tank Size _____ gallons
 Number of trenches 3
 Exact length of each trench 100 feet
 Trenches shall be installed on contour at a
 Maximum Trench Depth of: 12" IN NATURAL SOIL
 (Trench bottoms shall be level to +1-1/4" in all directions)
 Trench Spacing: 9 Feet on Center
 Soil Cover: 6 inches
 (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM
 Aggregate Depth: 6 inches below pipe
2 inches above pipe
12 inches total
 Conditions: CONTRACTOR TO MEET ON SITE PRIOR TO INSTALL. (SOIL SCREEN TEST (OT) MUST DETERMINE PROPER DETCH DEPTH.)

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James L. Manning Date: 3-18-09
 Construction Authorization Expiration Date: 04-18-09

HTE# _____

Permit # 25131

Harnett County Department of Public Health Site Sketch

ISSUED TO: JESUS L NINO PROPERTY LOCATOR: Hwy 401N
SUBDIVISION FOXCHASE 5D LOT # 16

Authorized State Agent: James E. Matthews Date: 3-18-09

* Contractor to meet on site prior to install.

