

# OPERATIONS PERMIT

Name: (owner) Patricia Davis  New Installation  Septic Tank  
 Property Location: SR# 2026  Repairs  Nitrification Line  
 Subdivision Roger Elliott Est Lot # 8  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Gerald Temple Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:   
 Water Supply:  Well  Public  Community  
 Distance From Well: 50+ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-22 in.  
 French Drain: \_\_\_\_\_ Linear feet

SR 2026 Date: 8-7-97  
 PERMIT NO. 12143 Inspected by: Thomas J. Boyce R.S.  
 Environmental Health Specialist

