

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

OWNER: Willis Harvey APPLICANT: Jim Brown
 ADDRESS: _____ APPLICATION DATE: 7-25-96 DATE EVALUATED: 8-11-96
 PROPOSED FACILITY: DW PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: .64 AC.
 LOCATION OF SITE: Lot 14 River Bluffs PROPERTY RECORDED: _____
 WATER SUPPLY: Private Public Well Spring Other _____
 EVALUATION METHOD: Auger Boring Pit Cut
 TYPE OF WASTEWATER: Sewage Industrial Process Mixed

P R O F I L E #	.1940 LAND- SCAPE POSITION/ SLOPE %	HORI- ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	C 15%	0-22	LStoSL						PS .4
		22-48	C/						
2	L 15%	0-12	LS						PS .5
		12-30	C/						
		30-48	C/ + SCL						
3	L 15%	0-15	LS						PS .5
		15-48	C/						
4		0-12	LS						.6
		12-36	SCL						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM	OTHER FACTORS (.1946): _____
Available Space (.1945)	OK	OK	SITE CLASSIFICATION (.1948): <u>PS</u>
System Type(s)	CONV,	CONVI	EVALUATED BY: <u>JH Eudy</u>
Site LTAR	.5	.4 + .5	OTHER(S) PRESENT: _____

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL 1955 LTAR	LPP 1957 LTAR	MINERALOGY/ CONSISTENCE	STRUCTURE
CC (Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4	NEXP (Non-expansive) SEX ⁷ (Slightly Expansive) EXP (Expansive)	G (Single Grain)
CV (Convex Slope)		LS (Loamy Sand)				M (Massive)
D (Drainage Way)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3		CR (Crumb)
DS (Debris Slump)		L (Loam)				GR (Granular)
FP (Flood Plain)	III	SI (Silt)	0.6 - 0.3	0.3 - 0.15		SBK (Subangular Blocky)
FS (Foot Slope)		SICL (Silty Clay Loam)				ABK (Angular Blocky)
H (Head Slope)		CL (Clay Loam)				PL (Platy)
L (Linear Slope)		SCL (Sandy Clay Loam)				PR (Prismatic)
N (Nose Slope)	IV	SLC (Silt Loam Clay)	0.4 - 0.1	0.2 - 0.05		
R (Ridge)		SC (Sandy Clay)				
S (Shoulder Slope)		SIC (Silty Clay)				
T (Terrace)		Clay O (Organic)				None

MOIST

WET

- | | |
|--------------------------------|-----------------------|
| VFR (Very Friable) | NS (Non-sticky) |
| FR (Friable) | SS (Slightly Sticky) |
| FI (Firm) | S (Sticky) |
| VFI (Very Firm v. Very Sticky) | VS (Very Sticky) |
| EFI (Extremely Firm) | NP (Non-plastic) |
| | SP (Slightly Plastic) |
| | P (Plastic) |
| | VP (Very Plastic) |

NOTES

- HORIZON DEPTH** In inches below natural soil surface
 - DEPTH OF FILL** In inches from land surface
 - RESTRICTIVE HORIZON** Thickness and depth from land surface
 - SAPROLITE** S(suitable) or U(unsuitable)
 - SOIL WETNESS** Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
 - CLASSIFICATION** S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)
- Evaluation of saprolite shall be by pits.
 Long-term Acceptance Rate (LTAR): gal/day/ft²

Show profile locations and other site features (dimensions, reference or benchmark, and North).

