

HTE# _____

Harnett County Department of Public Health 24231

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: RONNIE BETTS PROPERTY LOCATION: SC - BETTS RD + Hwy 42
 SUBDIVISION _____ LOT # _____
 NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: _____
 Type of Structure: Megant Home
 Proposed Wastewater System Type: 25% REDUCTION
 Projected Daily Flow: 600 GPD
 Number of bedrooms: 1 Number of Occupants: 10 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet
 Permit conditions: _____ Permit valid for: 30 DAYS Five years No expiration

Authorized State Agent: James E. Murchison Date: 8-30-07 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: RONNIE BETTS PROPERTY LOCATION: SC + Hwy 42
 SUBDIVISION _____ LOT # _____
 Facility Type: Megant Home New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** _____ (Initial) Wastewater Flow: 600 GPD
 (See note below, if applicable 25% REDUCTION syst (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 150 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 28-18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/- 1/4" in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
 Conditions: _____ 2 inches above pipe
12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: James E. Murchison Date: 8-30-07 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 9-30-07

HTE# _____

Permit # 24231

Harnett County Department of Public Health Site Sketch

ISSUED TO: ROWLER BETHS PROPERTY LOCATOR: SR BETHS RD + Hwy 42
SUBDIVISION _____ LOT # _____

Authorized State Agent: James E. Marshall Date: 8-30-07

