

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Cary Coost / Tom Seest  New Installation  Septic Tank  
 Property Location: SR# 1510  Repairs  Nitrification Line

Subdivision Carolina Est. Lot # 5

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: .466 ac

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50+ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18-24 in.


French Drain Required: \_\_\_\_\_ Linear feet

Date: 11-7-96

**This permit is subject to revocation if site plans or intended use change.**

Signed: Thomas J. Boyer R.S.  
 Environmental Health Specialist

**VOID AFTER 5 YEARS**



Carolina Dr.

Maintain Setbacks  
 Stub plumbing out shallow  
 Set tank shallow  
 Maintain Ditch Depths

HARNETT COUNTY HEALTH DEPARTMENT  
**AUTHORIZATION TO CONSTRUCT**

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 11525. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Cary Const / Tom Secrest

Name: Cary Const / Tom Secrest Telephone # 919-467-2265

Address: 139 E. Chatham St Cary NC

Property Location: SR # 1510 Road Name Matthews Mill Pond

New Installation  Repair  Septic Tank  Nitrification Lines

Subdivision Caroline Est. Lot # 5

Number of Bedrooms Proposed: 3 Lot size: .460ac

Basement  With Plumbing  Without Plumbing

Water Supply: Well  Public  Minimum Well Setback: 50r ft.

Type of System: Conventional  Other

Tank Volume: Septic Tank 1000 gallons Pump Chamber  gallons

**Nitrification Field Specifications**

Number of fields 1 Number of Lines per Field 4 Length of lines 75

Width of ditches 3 ft. Depth of ditches 18-24 inches

French Drain: Linear feet required  Depth of gravel

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Thomas J. Boyce R.S. Date: 11-2-96