

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Ronald Black  New Installation  Septic Tank  
Property Location: SR# 1261  Repairs  Nitrification Line

Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_

Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 2 Lot Size: 27.21 ac

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other Pump to conv lines

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 90 ft. width of ditches 3 ft. depth of \*18\* in.

French Drain required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site plans or intended use change.


Date: 10-31-95

Signed: Thomas J. Boye RS.

Environmental Health Specialist

VOID AFTER 5 YEARS

Maintain Setbacks  
Contractor to contact  
Thomas Boye prior to  
installing



HARNETT COUNTY HEALTH DEPARTMENT

AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 10721. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Ronald Black

Name: Ronald Black Telephone # 687 5092

Address: Rt 3 Box 309B Willington NC 27546

Property Location: SR# 1261 Road Name Newton Rd.

New Installation X Repair Septic Tank X Nitrification Lines X

Subdivision Lot #

Number of Bedrooms Proposed: 2 Lot Size: 27.21a

Basement With Plumbing Without Plumbing

Water Supply: Well Public A

Minimum Well Setback: 100' ft.

Type of System: Conventional X Other X Pump to conv lines

Tank Volume: Septic Tank 1000 gallons, Pump Chamber 1000 gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines Per Field 3 Length of Lines 90

Width of Ditches 3 ft. Depth of ditches 14 inches

French Drain: Linear feet required Depth of gravel

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent of Harnett County Health Department

Name: Thomas J. Boyce R.S. Date: 10-31-95