

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Joe Bowden ☐ New Installation ☒ Septic Tank
Property Location: SR# 1120 ☒ Repairs ☒ Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 existing Lot Size: 3.5 ac

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☒ Well ☐ Public ☐ Community

Distance From Well: 500 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☐ Conventional ☒ Other Polystyrene Aggregate Trench System 1 AWS-95-3A

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface No. of exact length width of depth of
Drainage Field ditches 2 of each ditch 60 ft. ditches 3 ft. ditches 18-30 in.

French Drain Required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 5-17-99

Signed: Thomas G. Bayne R.S.
Environmental Health Specialist



SR 1120

HARNETT COUNTY HEALTH DEPARTMENT
AUTORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 15750. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Joe Bowden

Name: _____ Telephone # 843-5915

Address: 56 Hanna Lane Spring Lake NC

Property Location: SR # 1120 Road Name _____

New Installation _____ Repair x Septic Tank x Nitrification Lines x

Subdivision _____ Lot # _____

Number of Bedrooms Proposed: 3 Lot size: 3.5ac

Basement _____ With Plumbing _____ Without Plumbing _____

Water Supply: Well _____ Public _____ Minimum Well Setback: _____ ft.

Type of System: Conventional _____ Other Polystyrene Aggregate Trench System

Tank Volume: Septic Tank 1000 gallons Pump Chamber _____ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 2 Length of lines 60

Width of ditches 3 ft. Depth of ditches 18-30 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Thomas J. Boyce R.S. Date: 5-19-99