HTE# REPAIR

## Harnett County Department of Public Health

## Improvement Permit

27161

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: NC27 KURTIS BUMMER SUBDIVISION NEW 🗆 REPAIR D EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 550 Proposed Wastewater System Type: 25% REDUCTION SYSTEM Projected Daily Flow: 360 Number of bedrooms: Number of Occupants: Basement Tes Pump Required: ☐Yes X No ☐ May be required based on final location and elevations of facilities Type of Water Supply: 

Community Public Well Distance from well 50 feet Permit valid for: Five years Permit conditions: ☐ No expiration RENS Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: KURTIS BOMMED PROPERTY LOCATION: NC27 SUBDIVISION Facility Type: 550 ☐ Expansion ☐ Repair Basement? 

Yes No Basement Fixtures? 

Yes Type of Wastewater System\*\* (Initial) Wastewater Flow: 360 GPD (See note below, if applicable 

) 25% REDUCTION SYSTEM (Repair) Installation Requirements/Conditions Number of trenches \_\_\_\_1 Septic Tank Size Existing gallons Exact length of each trench 180 Trench Spacing: Pump Tank Size \_\_\_\_ gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18-36 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_ \_\_\_\_\_ inches below pipe Aggregate Depth: \_\_\_\_\_\_ inches above pipe Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the ecovisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Construction Authorization Expiration Date:

HTE#	REPAIR
------	--------

Permit # 27161

## Harnett County Department of Public Health Site Sketch

PROPERTY LOCATON: NC27	
ISSUED TO: KURTIS BOMMER SUBDIVISION	LOT #
Authorized State Agent: Date: 9/21/12	

