

## IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Sherton & Gura Blunt ☒ New Installation ☒ Septic Tank  
Property Location: SR# 2039 ☐ Repairs ☒ Nitrification Line

Subdivision \_\_\_\_\_ Lot # 1C

Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: 1.9 ac

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 501 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface No. of 3 exact length 70 width of depth of  
Drainage Field ditches 4 of each ditch 50 ft. ditches 3 ft. ditches 18 in.

French Drain required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 7-27-95

Signed: Thomas J. Boyd

Environmental Health Specialist

VOID AFTER 5 YEARS

SR 2039

