



5c1105c
 20-48
 0-205c
 15-485c
 0-15-5c
 24 to 11 loop
 430
 30x100'

SITE/SOIL EVALUATION
 FOR
 ON-SITE WASTE WATER

APPLICANT: Alex Dawson PHONE: _____ APPLICATION DATE: 4-2-97
 ADDRESS: _____
 COUNTY: Harnett PROPERTY SIZE: 22.78 PROPOSED FACILITY: SWMH
 LOCATION OF SITE: SR 2035
 WATER SUPPLY: On-Site Wall _____ Community _____ Public Other _____ EVALUATION BY: Auger Boring Pit _____ Cut _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L							
SLOPE (%)	.1940	45%									
HORIZON 1 DEPTH		0-15	0-15	0-20							
Texture Group	.1941(A)(1)	SL	SL	SL							
Consistence	.1941	VFR	VFR	VFR							
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 2 DEPTH		15-48	15-48	20-48							
Texture Group	.1941(A)(1)	F1	F1	F1							
Consistence	.1941	SC	SC	SC							
Structure	.1941(A)(2)	sbk	sbk	sbk							
Mineralogy	.1941(A)(3)										
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942		36"								
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/1956										
CLASSIFICATION	.1948	PS	PS	PS							
LONG TERM ACCEPTANCE RATE	.1955	.4	.4	.4							

AVAILABLE SPACE (1945): _____ SITE LONG TERM ACCEPTANCE RATE: .4
 OTHER FACTORS (1946): _____ SYSTEM TYPE: CONV.
 SITE CLASSIFICATION (1948): PS

EVALUATED BY: JJJ Eudy OTHERS PRESENT: _____

COMMENTS: _____

