

IMPROVEMENT PERMIT

NO 08614

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) John A. Rhew ☒ New Installation ☒ Septic Tank
 Property Location: SR# 1440 ☐ Repairs ☒ Nitrification Line

Subdivision Windsor Neill's Creek Farm Lot # 145

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 1.476 ac

Basement with Plumbing: ☐ Garage: ☒

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface No. of exact length width of depth of
 Drainage Field ditches 2 of each ditch 240 ft. ditches 3 ft. ditches 18 in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 4-25-95
 Signed: Thomas J. Boye Jr. West

Environmental Health Specialist

VOID AFTER 5 YEARS

Contractor to meet on
 site prior to installation
 for layout.
 Run lines on contour

