

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Ruben + Marcia Dickens ☒ New Installation ☒ Septic Tank
Property Location: SR# 421 ☐ Repairs ☒ Nitrification Line

Subdivision _____ Lot # _____

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 2.52 ac

Basement with Plumbing: ☐ Garage: ☒

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 50+ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface No. of exact length width of depth of
Drainage Field ditches 4 of each ditch 100 ft. ditches 3 ft. ditches 18-24 in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 9-6-95

Signed: Thomas J. Boye R.S.

Environmental Health Specialist

VOID AFTER 5 YEARS

421

Maintain Setbacks

