

IMPROVEMENT PERM

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Napoleon Dockery ☒ New Installation ☒ Septic Tank
 Property Location: SR# 1141 ☐ Repairs ☒ Nitrification Line

Subdivision The Word Education Church Lot # 28

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 1.63 ac

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface No. of exact length width of depth of
 Drainage Field ditches 3 of each ditch 80 ft. ditches 3 ft. ditches 18-36 in.

French Drain Required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 12-11-97

Signed: Thomas J. Bayne R.S.
 Environmental Health Specialist



Maintain setbacks

HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 13119. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Napoleon Dickey

Name: Napoleon Dickey Telephone # 893-2057

Address: Rt 2 Box 116 Longleaf Dr. Lillington NC 27546

Property Location: SR # 1141 Road Name Microtower

New Installation ☒ Repair ☐ Septic Tank ☒ Nitrification Lines ☒

Subdivision The Word Education Church Lot # 28

Number of Bedrooms Proposed: 3 Lot size: 1.63ac

Basement ☐ With Plumbing ☐ Without Plumbing ☐

Water Supply: Well ☐ Public ☒ Minimum Well Setback: 50+ ft.

Type of System: Conventional ☒ Other ☐

Tank Volume: Septic Tank 1000 gallons Pump Chamber ☐ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 3 Length of lines 80

Width of ditches 3 ft. Depth of ditches 18-36 inches

French Drain: Linear feet required ☐ Depth of gravel ☐

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Thomas J. Boye R.S. Date: 12-11-97