

## IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) RUFUS Anderson ☒ New Installation ☐ Septic Tank  
Property Location: SR# (1427) 2407 Laurel Brook DR. ☐ Repairs ☐ Nitrification Line  
401 N T/L 1412 T/R 1407 T/R on Laurel Brook lot on Rt.  
Subdivision LAUREL BROOK II Lot # 11  
Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Number of Bedrooms Proposed: 3 Lot Size: 4.45 Acres  
Basement with Plumbing: ☐ Garage: ☐  
Water Supply: ☐ Well ☐ Public ☐ Community  
Distance From Well: N/A ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: N/A gallons  
Subsurface No. of exact length width of depth of  
Drainage Field ditches 3 of each ditch 115 ft. ditches 3 ft. ditches 30 in.  
French Drain required: N/A Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 2/27/94  
Signed: H. B. Phillips

Environmental Health Specialist

VOID AFTER 5 YEARS

