

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROCESSES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L	L	L	L				
SLOPE (%)	.1940	0-5	0-5	0-5	0-5	0-5	0-5				
HORIZON 1 DEPTH		0-10	0-12	0-10	0-12	0-10	0-12				
Texture Group	.1941(A)(1)	SL	SL	SL	SL	SL	SL				
Consistence	.1941	FR	FR	FR	FR	FR	FR				
Structure	.1941(A)(2)	GR	GR	GR	GR	GR	GR				
Mineralogy	.1941(A)(3)	1:1	1:1	1:1	1:1	1:1	1:1				
HORIZON 2 DEPTH		10-18	12-18	10-18	12-18	10-18	12-18				
Texture Group	.1941(A)(1)	SCL	SCL	SCL	SCL	SCL	SCL				
Consistence	.1941	FR	FR	FR	FR	FR	FR				
Structure	.1941(A)(2)	ABK	ABK	ABK	ABK	ABK	ABK				
Mineralogy	.1941(A)(3)	1:1	1:1	1:1	1:1	1:1	1:1				
HORIZON 3 DEPTH		18-36	18-36	18-36	18-36	18-36	18-36				
Texture Group	.1941(A)(1)	SL	SL	SL	SL	SL	SL				
Consistence	.1941	FR	FR	FR	FR	FR	FR				
Structure	.1941(A)(2)	ABK	ABK	ABK	ABK	ABK	ABK				
Mineralogy	.1941(A)(3)	2:1	2:1	2:1	2:1	2:1	2:1				
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942	30	28	32	30	28	32				
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	PS	PS	PS	PS	PS	PS				
LONG TERM											
ACCEPTANCE RATE	.1955	.4	.4	.4	.4	.4	.4				