

SITE/SOIL EVALUATION
FOR
ON-SITE WASTE WATER

3/7/95

APPLICANT: Farrar, James PHONE: _____ APPLICATION DATE: _____
ADDRESS: Darrock, FL
COUNTY: HARNETT PROPERTY SIZE: _____ PROPOSED FACILITY: MH
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well _____ Community _____ Public ☒ Other _____ EVALUATION BY: Auger Boring ☒ Pit _____ Cut _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	LS	LS	LS							
SLOPE (%)	.1940	0-8	0-8	0-8							
HORIZON 1 DEPTH		0-36	0-36	0-30							
Texture Group	.1941(A)(1)	SL	SL	SL							
Consistence	.1941	Fr	Fr	Fr							
Structure	.1941(A)(2)	SG	SG	SG							
Mineralogy	.1941(A)(3)	1:1	1:1	1:1							
HORIZON 2 DEPTH		36-40	36-40	30-40							
Texture Group	.1941(A)(1)	SC	SC	SC							
Consistence	.1941	Fr	Fr	Fr							
Structure	.1941(A)(2)	SAB	SAB	SAB							
Mineralogy	.1941(A)(3)	SExp	SExp	SExp							
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
OIL WETNESS	.1942										
RESTRICTIVE HORIZON	.1944										
APROLITE	.1943/1956										
CLASSIFICATION	.1948	PS	PS	PS							
DNG TERM	.1955	.4	.4	.4							
ACCEPTANCE RATE											

AVAILABLE SPACE (.1945): _____ SITE LONG TERM
OTHER FACTORS (.1946): _____ ACCEPTANCE RATE:
SITE CLASSIFICATION (.1948): _____ SYSTEM TYPE:

EVALUATED BY: James Farrar OTHERS PRESENT: _____

COMMENTS: Mr. Farrar wants to set lines up to 36" deep.
He also wants to set tank approx. 80' from mobile home. I advise him to keep tank next to house to insure solids make it tank. Hill has enough slope to allow solid line to be sloped gently to tank if he digs down deep near MH.

