

HARNETT COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT

No. 5841

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) ① Leon Anderson, Const. ☒ New Installation ☒ Septic Tank  
 Property Location: SR 1415 ☐ Repairs ☒ Nitrification Line  
Lot # 20 Woodland Ridge.

Number of Bedrooms Proposed: 3 Lot Size: 1.409 acre

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: \_\_\_\_\_ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface No. of exact length width of depth of  
 Drainage Field ditches 4 of each ditch 90 ft. ditches 3 ft. ditches 18 in.

French Drain required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 11/08/91  
 Signed: Charles Wood  
 Environmental Health Specialist

VOID AFTER 5 YEARS



→ Woodland Dr. to SR 1415 →