

# HARNETT COUNTY HEALTH DEPARTMENT

## IMPROVEMENT PERMIT

No

5764

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Wilmington Free Will Baptist Church ☒ New Installation ☒ Septic Tank  
Property Location: SR 1705 across from Ondaessa ☐ Repairs ☒ Nitrification Line

Number of Bedrooms Proposed: 250 persons Lot Size: 1.83 acres

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: N/A ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other \_\_\_\_\_

Size of tank: Septic Tank: 1500 gallons Pump Tank: N/A gallons

Subsurface 1 No. of exact length width of depth of  
inage Field 4 of each ditch 80 ft. ditches 3 ft. ditches 20 in.

French Drain required: N/A Linear feet

This permit is subject to revocation if site plans or intended use change.


Date: 13 May 92

Signed: 7/2/92 RS

Environmental Health Specialist

VOID AFTER 5 YEARS

② Baptistry - Install D-box w/2 lines 50ft long at a depth of 20 inches 3ft wide



← Drive SR 1705