

HTE# _____

Harnett County Department of Public Health

Improvement Permit

26083

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Joe + Lula K RoysterPROPERTY LOCATION: SR 1532 OAK GROVE CH RDNEW ☐ REPAIR ☒ EXPANSION ☐

SUBDIVISION _____

LOT # B

Site Improvements required prior to Construction Authorization Issuance: _____

Type of Structure: EX DWMMProposed Wastewater System Type: GRAVEL OR 25% RED-Projected Daily Flow: 480 GPDNumber of bedrooms: 4 Number of Occupants: 8 maxBasement ☐ Yes ☒ NoPump Required: ☐ Yes ☐ No ☒ May be required based on final location and elevations of facilitiesType of Water Supply: ☐ Community ☒ Public ☒ Well Distance from well 36-40 feet

Permit valid for:

☒ Five years☐ No expirationPermit conditions: Contractor to meet on site prior to install.OWNER IS ALLOWED TO TRY TO RECONNECT BACK TO EXISTING LINES AFTER CLOGGED MAIN AND NEW FILTER AND RISER REQUIRED.Authorized State Agent: James E. MarkhamDate: 10-12-10

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Joe + Lula K RoysterPROPERTY LOCATION: SR 1532 OAK GROVE CH RD

SUBDIVISION _____

LOT # BFacility Type: EX DWMM☐ New☐ Expansion☒ RepairBasement? ☐ Yes ☒ No Basement Fixtures? ☐ Yes ☒ No

Type of Wastewater System**

(See note below, if applicable ☐)(Initial) Wastewater Flow: 480 GPD

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size _____ gallons

Number of trenches 4Exact length of each trench 70 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 26" inches(Trench bottoms shall be level to $\pm 1/4"$

in all directions)

Trench Spacing: 9 Feet on CenterSoil Cover: 6 inches

(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 6 inches below pipe2 inches above pipe12 inches total

Conditions: Contractor to meet on site prior to install. OWNER IS ALLOWED TO TRY TO RECONNECT TO EXISTING LINES AFTER CLOGGED MAIN NEW FILTER AND RISER REQUIRED.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. MarkhamDate: 10-12-10Construction Authorization Expiration Date: 10-12-15

HTE# _____

Permit # 26083

Harnett County Department of Public Health Site Sketch

ISSUED TO: JOE + LULA K ROYSTON PROPERTY LOCATION: SL-1532 OAK GROVE CH RD
SUBDIVISION _____ LOT # 13

Authorized State Agent: JAMES C. MARTIN FOR HRS Date: 10-12-10

- * Contractor to meet on site prior to install.
- * Several options for repair on Septic System.
START WITH GAS TEST and gradually go to more
extensive.
- * EXISTING TANK WITH ^{NEW} RISER AND NEW Filter
may try to RECONNECT TO EXISTING DRAIN LINES.
THIS IS OPTION #1.
- * NEW TANK WITH DRAIN LINES IS OPTION #2. AS PERMIT.
- * Well Abandonment
* Well MUST BE filled for any other work besides working
ON EXISTING SYSTEM.

