

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Michael W. Frye ☒ New Installation ☒ Septic Tank
 Property Location: SR# 1100 Line Rd ☐ Repairs ☒ Nitrification Line

Subdivision _____ Lot # 8

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 28.2 AC

Basement with Plumbing: ☐ Garage: ☒

Water Supply: ☒ Well ☐ Public ☐ Community

Distance From Well: 100' ft.
50 min

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 24" in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.


Date: 4.3.96

Signed: J. W. ARS

Environmental Health Specialist

VOID AFTER 5 YEARS

SR 1100
Line Rd



STUD out Plumbing shall be 24" dia. Depth Place Bach 30' above system To divert surface water maintain all pipes and set Bach 55' 100' from the well.

HARNETT COUNTY HEALTH DEPARTMENT

AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 10253. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Michael W. Frye

Name: SAME Telephone # 245-4720

Address: Rt. 4 Box 268-B Cameron NC 28320

Property Location: SR# 1100 Road Name Candy Line Rd

New Installation ☒ Repair ☐ Septic Tank ☒ Nitrification Lines ☒

Subdivision N/A Lot # 8

Number of Bedrooms Proposed: 3 Lot Size: 28.2 ac

Basement ☐ With Plumbing ☐ Without Plumbing ☐

Water Supply: Well ☒ Public ☐

Minimum Well Setback: 100' ft.

Type of System: Conventional ☒ Other ☐

Tank Volume: Septic Tank 1000 gallons, Pump Chamber ☐ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines Per Field 3 Length of Lines 80

Width of Ditches 3 ft. Depth of ditches 24 inches

French Drain: Linear feet required ☐ Depth of gravel ☐

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent of Harnett County Health Department

Name: Joe L. R. Date: 4-3-94