

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) William & Robin Rider ☒ New Installation ☒ Septic Tank
 Property Location: SR# 1238 ☐ Repairs ☒ Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 17.8 ac

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 50+ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface No. of exact length width of depth of
 Drainage Field ditches 4 of each ditch 85 ft. ditches 3 ft. ditches 18-22 in.

French Drain Required: _____ Linear feet

Date: 10-31-97

This permit is subject to revocation if site plans or intended use change.

Signed: Thomas J. Boyer R.S.
 Environmental Health Specialist



Maintain Setbacks
 Install on contour

HARNETT COUNTY HEALTH DEPARTMENT
AUTORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 12953. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent William & Robin Kinton

Name: William & Robin Kinton Telephone # 814-2681

Address: P.O. Box 1718 Lillington NC 27546

Property Location: SR # 1238 Road Name Spring Hill Ch. Rd

New Installation X Repair Septic Tank X Nitrification Lines X

Subdivision Lot #

Number of Bedrooms Proposed: 3 Lot size: 17.8ac

Basement With Plumbing Without Plumbing

Water Supply: Well Public X Minimum Well Setback: 50 ft.

Type of System: Conventional X Other

Tank Volume: Septic Tank 1000 gallons Pump Chamber gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 4 Length of lines 85

Width of ditches 3 ft. Depth of ditches 18-22 inches

French Drain: Linear feet required Depth of gravel

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Thomas J. Boyce R.S. Date: 10-31-97