

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Lambert Home Inc.☒ New Installation ☒ Septic TankProperty Location: SR# 1427 Baptist Grove Road☐ Repairs ☒ Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: OFFICE Lot Size: 2.434Basement with Plumbing: ☐ Garage: ☐Water Supply: ☐ Well ☒ Public ☐ CommunityDistance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other _____Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallonsSubsurface No. of 2 exact length 60 width of _____ depth of _____
Drainage Field ditches 1 of each ditch 125 ft. ditches 3 ft. ditches 18-20 in.

French Drain Required: _____ Linear feet

Date: 2-20-97


* This permit is subject to revocation if site plans or intended use change.

Signed: James C. Mantel

Environmental Health Specialist

* Maintain all setbacks

VOID AFTER 5 YEARS



SR 1427

H NETT COUNTY HEALTH DEP. MENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 11721. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Lambert Homes

Name: Lambert Homes Telephone # 552-9810

Address: RT 2 Box 732 C Fuquay Varina N.C. 27526

Property Location: SR # 1427 Road Name Baptist Grove

New Installation ☐ Repair ☒ Septic Tank ☐ Nitrification Lines ☒

Subdivision Lot #

Number of Bedrooms Proposed: 2 Lot size: 2.343

Basement ☐ With Plumbing ☐ Without Plumbing ☐

Water Supply: Well ☒ Public ☐ Minimum Well Setback: 50 ft.

Type of System: Conventional ☒ Other ☐

Tank Volume: Septic Tank 1000 gallons Pump Chamber gallons

Nitrification Field Specifications

Number of fields 2 Number of Lines per Field 1^{or 2} Length of lines 125'-0" 2-63

Width of ditches 3 ft. Depth of ditches 18-20 inches

French Drain: Linear feet required Depth of gravel

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: James E. Markham Date: 2-20-97