

IMPROVEMENT PERMIT

Be It ordained by the Harnett County Board of Health as follows:
 Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Charles E. LYNN ☐ New Installation ☒ Septic Tank
 Property Location: off SR 1105 ☐ Repairs ☒ Nitrification Line

Number of Bedrooms Proposed: 2 ☐ Dish Washer ☐ Garbage Disposal
 Lot Size: 14.31 acres Water Supply: ☒ Well ☐ City ☐ Community
 Distance From Well? ☒

Above information certified by: 100' and 50' min.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Kind of Material for Tank: ☒ Concrete ☐ Other _____

Size of Tank: Capacity 1000 Gallons
 Subsurface No. of Ditches 2 Exact Length 70 Width of 3 Depth of 24 Inches
 Drainage Field Ditches of each Ditch Ft. Ditches Ft. Ditches Inches


Any Change in the layout of this system without prior approval of the issuing authority will result in this permit being void.

Date: 05/03/91

Signed: John H. Byrd R.S.
 (SANITARIAN)

After 3 Years

This permit is subject to revocation if site plans or intended use change.



- 50' min from oil wells

- Keeping level on contour or use steps as needed.