

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Nicholas Skatell ☐ New Installation ☐ Septic Tank
Property Location: SR# 1775 ☐ Repairs ☐ Nitrification Line

Subdivision _____ Lot # _____

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 4 Lot Size: 3.3 acre

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☐ Public ☐ Community

Distance From Well: 50+ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: ☒ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface No. of exact length width of depth of
Drainage Field ditches 5 of each ditch 100 ft. ditches 3 ft. ditches 18-20 in.

French Drain required: - Linear feet


This permit is subject to revocation if site plans or intended use change.

Date: 11-22-54

Signed: James E. Marshall

Environmental Health Specialist

VOID AFTER 5 YEARS



* Contractor
to Meet
Local Health
Department
on site prior
TO INSTALLATION
(853-7547)