



Alternative Power Sales and Rental  
 512 OLD APEX ROAD  
 CARY, NC 27511  
 (919) 467-8001  
 www.alternativepower.com

### Sizing Report

Rated Nominal Voltage 240  
 Generator Fuel Choice Propane  
 Sizing Method (NEC 220) Part IV  
 (Part III required for selected circuit implementation, Both valid for whole house)

General Lighting & Receptacles		Load (kW)
Square Footage Being Covered (ft^2)	2026	6.078
Small Appliance Circuits (20 amps)		
Kitchen Circuits	2	3
Laundry Circuits	1	1.5

Fixed-In-Place Appliances & Motors	Managed Loads	Estimated (kW)	Nameplate (amps)	240 V	Load (kW)
Dryer		5.5		X	5.5
Microwave		1.3			1.3
Range - Oven w/ Top		8.5		X	8.5
Water Heater		5.0		X	5.0
Dishwasher		1.5			1.5
Freezer		0.8			0.8
Refrigerator		0.8			0.8

Air Conditioning & Cooling	Managed Loads	Estimated (kW)	Nameplate (amps)	240 V	Load (kW)

Heating & Heat Pumps	Managed Loads	Estimated (kW)	Nameplate (amps)	240 V	Load (kW)
Heat Pump (3 Ton)	X	3.0		X	0.0
Heat Pump Electric Element	X	5.0		X	0.0

Transient Requirement	Estimated (LRA)	Actual (LRA)	Utilized (LRA)
Largest Motor's Starting Amps (LRA)	86	83	83

	Load (kW)	NEC Required
Summary NEC Load		
General Lighting & Receptacles	10.6	
Fixed-in-Place Appliances & Motors	23.4	
Sum of all General Loads	33.9	19.6
Cooling	0	0
Heating (w/demand factors)	0	0
Larger of Heating & Cooling	0	0
Sizing based on requirements of NEC Article 220, Part IV		19.6
Elevation		0 ft
Minimum size generator for motor starting requirements		11
BTU load required		324000

20 kW Generac Model Generator Recommended