

### MODULE TYPE, DIMENSIONS & WEIGHT

NUMBER OF MODULES = 16 MODULES MODULE TYPE = SILFAB SOLAR SILFAB SLA 300W MONO MODULES MODULE WEIGHT = 41.89 LBS / 19 KG.

MODULE DIMENSIONS = 64.96"x 38.98" = 17.58 SF

(E) BACK OF RESIDENCE

	ROOF DESCRIPTION				
F	ROOF TYPE			COMPOSITE SHINGLE	
F	ROOF LAYER			1 LAYERS	
	ROOF	OF ROOF AZIMUTH RAFTER SIZE		RAFTER SPACING	
	#1	45°	164°	2X6	16"

ARRAY AREA & ROOF AREA CALC'S				
ROOF	# OF MODULES	ARRAY AREA (Sq. Ft.)	ROOF AREA (Sq. Ft.)	ROOF AREA COVERED BY ARRAY (%)
#1	16	281.28	936.48	30

**REVISIONS** DESCRIPTION DATE

SOLAR & ROOFING SOLAR & ROOFING DWER HOME SOLAR, LLC POWER YOUR FUTURE" 919 N. MAIN ST. MODRESVILLE, NC 28115

Signature with Seal

DATE:03/31/2019

2508 SHERIFF JOHNSON RD., LILLINGTON, NC 27546

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

DESIGNED BY

PHS


SHEET NAME **ROOF PLAN & MODULES** 

SHEET SIZE

**ANSI B** 11" X 17"

SHEET NUMBER

PV-2



**LEGEND** 

- JUNCTION BOX

- INVERTER INV

- INTEGRATED DC DISCONNECT

- SOLAR LOAD CENTER

- PRODUCTION METER

- MAIN SERVICE PANEL

- COMBINER BOX

- RAFTERS

- CONDUIT

- ROOF ATTACHMENT

- VENT, ATTIC FAN (ROOF OBSTRUCTION)

SILFAB SOLAR SILFAB SLA 300W MONO **MODULES** 

.96 94

**ROOF PLAN & MODULES** 

SCALE: 3/32" = 1'-0"

PV-2

,38.98"

PM MSP

DC

SLD







REVISIONS DESCRIPTION DATE

Signature with Seal

DATE:03/31/2019

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

2508 SHERIFF JOHNSON RD., LILLINGTON, NC 27546

DESIGNED BY

PHS


SHEET NAME **STRING LAYOUT** 

SHEET SIZE

ANSI B 11" X 17"


SHEET NUMBER PV-2A

(E) BACK OF RESIDENCE




(E) FRONT OF RESIDENCE

BILL OF MATERIALS		
EQUIPMENT	QTY	DESCRIPTION
SOLAR PV MODULE	16	SILFAB SOLAR SILFAB SLA 300W MONO MODULES
OPTIMIZER	16	SOLAREDGE POWER OPTIMIZER P320
INVERTER	01	SOLAREDGE SE5000H-US INVERTER
AC DISCONNECT	1	30A FUSED, (2) 30A FUSES, 240V, NEMA 3R, UL LISTED
SOLAR DECK	1	SOLAR DECKS
RAILS	12	IRONRIDGE XR10 RAIL 168" (14 FEET) BLACK
BONDED SPLICE	6	SPLICE KIT
MODULE CLAMPS	38	UNIVERSAL MODULE CLAMPS
GROUNDING LUG	3	IRONRIDGE GROUNDING LUG
END CLAMPS	12	END CLAMPS / STOPPER SLEEVE
ATTACHMENT	34	SRH LOW PROFILE QUICKBOLT
SQUARE-BOLT	34	SQUARE-BOLT BONDING ATTACHMENT HARDWARE



ATTACHMENT DETAIL

SCALE: 1" = 1'-0"



POWERHOME
SOLAR & ROOFING
POWER HOME SOLAR, LLC
"POWER YOUR FUTURE"
919 N. MAIN ST.
MOORESVILLE, NC 28115

REVISIONS				
DATE	REV			

Signature with Seal

DATE:03/31/2019

2508 SHERIFF JOHNSON RD., LILLINGTON, NC 27546

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

DESIGNED BY

PHS

SHEET NAME
ATTACHMENT
DETAIL


SHEET SIZE

ANSI B 11" X 17"

SHEET NUMBER

PV-3

ATTACHMENT DETAIL (enlarged view)



(3)

SCALE: NTS

PV-4

#6AWG -

THWN-2

PVC, LFNC OR LFMC

3/4"

SOLAR & ROOFING
SOLAR & ROOFING
POWER HOME SOLAR, LLC
"POWER YOUR FUTURE"
919 N. MAIN ST.
MOORESVILLE, NC 28115
Phone: 704-800-6591 (OFFICE) C 28115 (OFFICE) ome.com

**REVISIONS** DESCRIPTION DATE

Signature with Seal

DATE:03/31/2019

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

2508 SHERIFF JOHNSON RD., LILLINGTON, NC 27546

**DESIGNED BY** 

PHS

SHEET NAME **ELECTRICAL LINE** 

> DIAGRAM SHEET SIZE

ANSI B 11" X 17"

SHEET NUMBER

SOLAR MODULE SPECIFICATIONS		
MANUFACTURER / MODEL #	SILFAB SOLAR SILFAB SLA 300W MONO	
VMP	32.8V	
IMP	9.16A	
VOC	39.85V	
ISC	9.71A	
TEMP. COEFF. VOC	-0.300%/°C	
MODULE DIMENSION	64.96"L x 38.98"W x 1.50"D (In Inch)	

INVERTER #1 SPECIFICATIONS		
MANUFACTURER / MODEL #	SOLAREDGE SE5000H-US	
NOMINAL AC POWER	5.0 KW	
NOMINAL OUTPUT VOLTAGE	240 VAC	
NOMINAL OUTPUT CURRENT	21A	

ſ	POWER OPTIMIZER (OPTIMIZER P320-2NM4ARS)		
Ī	MAXIMUM INPUT POWER	320W	
	MINIMUM INPUT VOLTAGE	8 VDC	
	MAXIMUM INPUT VOLTAGE	48VDC	
	MAXIMUM MODULE ISC	11 ADC	
	MAXIMUM OUTPUT CURRENT	15 ADC	

PERCENT OF VALUES	NUMBER OF CURRENT CARRYING CONDUCTORS IN EMT
.80	4-6
.70	7-9
.50	10-20

AMBIENT TEMPERATURE SPECS		
RECORD LOW TEMP	-10°	
AMBIENT TEMP (HIGH TEMP 2%)	36°	
CONDUIT HEIGHT	0.5"	
ROOF TOP TEMP	58°	
CONDUCTOR TEMPERATURE RATE	90°	
MODULE TEMPERATURE COEFFICIENT OF Voc	-0.29%/°K	

## DC CONDUCTOR AMPACITY CALCULATIONS: ARRAY TO JUNCTION BOX:

EXPECTED WIRE TEMP (In Celsius)	58 <b>°</b>
TEMP. CORRECTION PER TABLE (310.16)	0.71
NO. OF CURRENT CARRYING CONDUCTORS	2
CONDUIT FILL CORRECTION PER NEC 310.15(B)(3)(a)	1.0
CIRCUIT CONDUCTOR SIZE	10 AWG
CIRCUIT CONDUCTOR AMPACITY	40A

REQUIRED CIRCUIT CONDUCTOR AMPACITY PER NEC 690.8(A&B)	18.75A
1.25 X Isc	10.75A
DERATED AMPACITY OF CIRCUIT CONDUCTOR PER NEC TABLE 310.16	
CONDUIT FILL CORRECTION PER NEC 310.15(B)(3)(a) X CIRCUIT CONDUCTOR AMPACITY	40A
Result should be greater than (18.75A) otherwise less the entry for circuit conductor size	

## DC CONDUCTOR AMPACITY CALCULATIONS: FROM JUNCTION BOX TO INVERTER:

AMBIENT TEMPERATURE ADJUSTMENT FOR EXPOSED CONDUIT PER NEC 310.15(B)(2)(c)	+22*
EXPECTED WIRE TEMP (In Celsius)	36°+22° = 58°
TEMP. CORRECTION PER TABLE (310.16)	0.71
NO. OF CURRENT CARRYING CONDUCTORS	2
CONDUIT FILL CORRECTION PER NEC 310.15(B)(2)(a)	1.0
CIRCUIT CONDUCTOR SIZE	10AWG
CIRCUIT CONDUCTOR AMPACITY	40A

REQUIRED CIRCUIT CONDUCTOR AMPACITY PER NEC 690.8(A&B)	18.75A
1.25 X Isc	16.75A
DERATED AMPACITY OF CIRCUIT CONDUCTOR PER NEC TABLE 310.16	
CONDUIT FILL CORRECTION PER NEC 310.15(B)(2)(a) X CIRCUIT CONDUCTOR AMPACITY	40A
Result should be greater than (18.75A) otherwise less the entry for circuit cond	uctor size

### **ELECTRICAL NOTES**

- 1.) ALL EQUIPMENT TO BE LISTED BY UL OR OTHER NRTL, AND LABELED FOR ITS APPLICATION.
- 2.) ALL CONDUCTORS SHALL BE COPPER, RATED FOR 600 V AND 90 DEGREE C WET ENVIRONMENT.
- 3.) WIRING, CONDUIT, AND RACEWAYS MOUNTED ON ROOFTOPS SHALL BE ROUTED DIRECTLY TO, AND LOCATED AS CLOSE AS POSSIBLE TO THE NEAREST RIDGE, HIP, OR VALLEY.

and ampacity

- 4.) WORKING CLEARANCES AROUND ALL NEW AND EXISTING ELECTRICAL EQUIPMENT SHALL COMPLY WITH NEC 110.26.
- 5.) DRAWINGS INDICATE THE GENERAL ARRANGEMENT OF SYSTEMS. CONTRACTOR SHALL FURNISH ALL NECESSARY OUTLETS, SUPPORTS, FITTINGS AND ACESSORIES TO FULFILL APPLICABLE CODES AND STANDARDS.
- 6.) WHERE SIZES OF JUNCTION BOXES, RACEWAYS, AND CONDUITS ARE NOT SPECIFIED, THE CONTRACTOR SHALL SIZE THEM ACCORDINGLY.
- 7.) ALL WIRE TERMINATIONS SHALL BE APPROPRIATELY LABELED AND READILY VISIBLE.
- 8.) MODULE GROUNDING CLIPS TO BE INSTALLED BETWEEN MODULE FRAME AND MODULE SUPPORT RAIL, PER THE GROUNDING CLIP MANUFACTURER'S INSTRUCTION.
- 9.) MODULE SUPPORT RAIL TO BE BONDED TO CONTINUOUS COPPER G.E.C. VIA WEEB LUG OR ILSCO GBL-4DBT LAY-IN LUG.
- 10.) THE POLARITY OF THE GROUNDED CONDUCTORS IS NEGATIVE

## AC CONDUCTOR AMPACITY CALCULATIONS:

and ampacity

No. OF INVERTER	1
EXPECTED WIRE TEMP (In Celsius)	36°
TEMP. CORRECTION PER TABLE (310.16)	0.91
NO. OF CURRENT CARRYING CONDUCTORS	3
CONDUIT FILL CORRECTION PER NEC 310.15(B)(2)(a)	1
CIRCUIT CONDUCTOR SIZE	6 AWG
CIRCUIT CONDUCTOR AMPACITY	75A

REQUIRED CIRCUIT CONDUCTOR AMPACITY PER NEC 690.8(B)	26 25A
1.25 X MAX INVERTER OUTPUT CURRENT	20.23A
DERATED AMPACITY OF CIRCUIT CONDUCTOR PER NEC TABLE 310.16	
TEMP. CORRECTION PER TABLE (310.16) X CONDUIT FILL CORRECTION PER NEC 310.15(B)(2)(a) X CIRCUIT CONDUCTOR AMPACITY	68.25A

Result should be greater than (26.25A) otherwise less the entry for circuit conductor size

DESCRIPTION DATE REV

Signature with Seal

DATE:03/31/2019

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

2508 SHERIFF JOHNSON RD., LILLINGTON, NC 27546

DESIGNED BY

PHS

SHEET NAME
WIRING
CALCULATIONS


SHEET SIZE

ANSI B 11" X 17"

SHEET NUMBER

	1-10	11-20	21-30	31-40	41-50	51-60	61-70	1
1								S
2								
3								-
4								-
5								
6								
7								-
8								-
9								-
10								
		I	I	I	ı	I	I	J

### SOLAREDGE OPTIMIZER CHART





REVISIONS					
DESCRIPTION	DATE	REV			

Signature with Seal

DATE:03/31/2019

2508 SHERIFF JOHNSON RD., LILLINGTON, NC 27546

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

DESIGNED BY

PHS

SHEET NAME
SOLAREDGE
OPTIMIZER CHART

SHEET SIZE

ANSI B 11" X 17"

SHEET NUMBER



## SLA-M Monocrystalline













## 300 Wp 60 Cell

Monocrystalline **PV Module** 



#### 100% MAXIMUM POWER DENSITY

Silfab's SLA-M 300 ultra-high-efficiency modules are optimized for both Residential and Commercial projects where maximum power density is preferred.

### 100% NORTH AMERICAN **QUALITY MATTERS**

Silfab's fully-automated manufacturing facility ensures precision engineering is applied at every stage. Superior reliability and performance combine to produce one of the highest quality modules with the lowest defect rate in the industry.

### **NORTH AMERICAN CUSTOMIZED SERVICE**

Silfab's 100% North American based team leverages just-in-time manufacturing to deliver unparalleled service, on-time delivery and flexible project solutions.



### **ENSURES MAXIMUM EFFICIENCY**

60 of the highest efficiency, premium quality monocrystalline cells result in a maximum power rating of 300Wp.

### **##** ADVANCED PERFORMANCE WARRANTY

30-year linear power performance guarantee

#### **ENHANCED PRODUCT WARRANTY**

25-year product workmanship warranty\*

### **BUILT BY INDUSTRY EXPERTS**

With over 35 years of industry experience, Silfab's technical team are pioneers in PV technology and are dedicated to an innovative approach that provides superior manufacturing processes including: infra-red cell sorting, glass washing, automated soldering and meticulous cell alignment.

### **## POSITIVE TOLERANCE**

(-0/+5W) All positive module sorting ensures maximum performance

### **EXAMPLE 1** LOWEST DEFECT RATE\*

Total automation ensures strict quality control during each step of the process at our certified ISO manufacturing facility. \*82.56 ppm as per December 2017

### **III** LIGHT AND DURABLE

Over-engineered to weather low load bearing structures up to 5400 Pa. Light-weight frame exclusively designed with wide-ranging racking compatibility and durability.

#### **PID RESISTANT**

Proven in accordance to IEC 62804-1

**## AVAILABLE IN** All Black

Electrical Specifications		SILFAD SLA IV	ionocrystainine
Test Conditions		STC	NOCT
Module Power (Pmax)	Wp	300	227
Maximum power voltage (Vpmax)	V	32.8	29.5
Maximum power current (Ipmax)	Α	9.16	7.69
Open circuit voltage (Voc)	V	39.85	36.9
Short circuit current (Isc)	A	9.71	7.96
Module efficiency	%	18.4	17.3
Maximum system voltage (VDC)	V	10	000
Series fuse rating	A		20
Power Tolerance	Wp	-0	/+5

Sun simulator calibration reference modules from Fraunhofer Institute. Electrical characteristics may vary by ±5% and power by -0/+5

Temperature Ratings		SILFAB SLA Monocrystalline	
Temperature Coefficient Isc	%/K	0.03	
Temperature Coefficient Voc	%/K	-0.30	
Temperature Coefficient Pmax	%/K	-0.38	
NOCT (± 2°C)	°C	45	
Operating temperature	°C	-40/+85	

Operating temperature		-40/+85			
Mechanical Properties and Components		SILFAB SLA Monocrystalline			
Module weight (± 1 kg)	kg	19			
Dimensions (H x L x D; ± 1mm)	mm	1650 x 990 x 38			
Maximum surface load (wind/snow)*	N/m²	5400			
Hail impact resistance		ø 25 mm at 83 km/h			
Cells		60 - Si monocrystalline - 4 or 5 busbar - 156.75 x 156.75 mm			
Glass		3.2 mm high transmittance, tempered, antireflective coating			
Backsheet		Multilayer polyester-based			
rame		Anodized Al			
Bypass diodes		3 diodes-45V/12A, IP67/IP68			
Cables and connectors (See installation manua	1)	1200 mm ø 5.7 mm (4 mm2), MC4 compatible			
Warranties		SILFAB SLA Monocrystalline			
Module product workmanship warranty		25 years*			
Linear power performance guarantee		30 years			
Certifications		SILFAB SLA Monocrystalline			
Product		ULC ORD C1703, UL 1703, IEC 61215, IEC 61730, IEC 61701, CEC liste IEC 62716 Ammonia Corrosion, IEC 61701:2011 Salt Mist Corrosion			



Factory

Warning: Read the installation and User Manual before handling, installing and operating modules.

Third-party generated pan files from Fraunhofer-Institute for Solar Energy Systems ISE are available for download at: www.silfab.ca/downloads


Modules Per Pallet: 26 Pallets Per Truck: 36 **III** Modules Per Truck: 936



Silfab Solar Inc. 240 Courtneypark Drive East Mississauga, ON L5T 2S5 Tel +1 905-255-2501 • Fax +1 905-696-0267 Tel +1 360-647-9531 info@silfab.ca • www.silfab.ca

800 Cornwall Ave Bellingham, WA 98226

Silfab Solar Inc.



UL Fire Rating: Type 2 (Type 1 on request)

ISO9001:2015

SOLAR & ROOFING WER HOME SOLAR, LLC POWER YOUR FUTURE"

•					
REVISIONS					
DESCRIPTION	DATE	REV			

Signature with Seal

DATE:03/31/2019

RD.,

2508 SHERIFF JOHNSON | LILLINGTON, NC 27546

PROJECT NAME & ADDRESS

RUIZ JANETTE RUIZ RESIDENCE

DESIGNED BY

PHS

SHEET NAME **EQUIPMENT SPECIFICATION** 

> SHEET SIZE **ANSI B**

11" X 17" SHEET NUMBER

## solaredge

### **Single Phase Inverter**

with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US



### Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Record-breaking efficiency
- Fixed voltage inverter for longer strings
- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12
- UL1741 SA certified, for CPUC Rule 21 grid compliance
- High reliability without any electrolytic capacitors
- Built-in module-level monitoring
- Outdoor and indoor installation
- Optional: Revenue grade data, ANSI C12.20 Class 0.5 (0.5% accuracy)



S

Ш

www.solaredge.us



## Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US

	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
OUTPUT		2000 0 2401		5000 0 3401				1
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400	VA
Max. AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400	VA
AC Output Voltage MinNomMax. (183 - 208 - 229)	-	1	*	1	8	-	-	Vac
AC Output Voltage MinNomMax.	J	1	1	J	1	1	1	Vac
(211 - 240 - 264) AC Frequency (Nominal)	***********			59.3 - 60 - 60.5	l 	1	l	Hz
Maximum Continuous Output Current 208V	-	16	-	24	-	-	-	А
Maximum Continuous Output Current	12.5	16	21	25	32	42	47.5	Α
@240V GFDI Threshold		l		1	I	L	l	Α
Utility Monitoring, Islanding Protection, Country Configurable Thresholds			*************	Yes	**************	**************	***************	
INPUT								
Maximum DC Power @240V Maximum DC Power @208V	4650	5900 5100	7750	9300 7750	11800	15500	17650	W
Transformer-less, Ungrounded Maximum Input Voltage	.,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			Yes 480		1	1	Vdc
Nominal DC Input Voltage Maximum Input Current 208V			80	13.5		400		Vdc
Maximum Input Current @240V	8.5	9 10.5	13.5	16.5	20	27	30.5	Adc
Max. Input Short Circuit Current				45	***************			Adc
Reverse-Polarity Protection Ground-Fault Isolation Detection	*********			Yes	********	********	***********	
Maximum Inverter Efficiency CEC Weighted Efficiency	600 <b>kg</b> Sensitivity 99 99.2 99						% %	
Nighttime Power Consumption	<2.5						W	
ADDITIONAL FEATURES								
Supported Communication Interfaces Revenue Grade Data, ANSI C12.20 Rapid Shutdown - NEC 2014 and 2017		R	S485, Ethernet,	ZigBee (optional Optional <sup>(2)</sup>	), Cellular (optic	onal) 	*************	
690.12		Δ.	utomatic Rapid	Shutdown upon	AC Grid Disconi	nect		
STANDARD COMPLIANCE								
Safety Grid Connection Standards Emissions		UL1741, UL174	IEEE1!	CSA C22.2, Cana 547, Rule 21, Rul FCC Part 15 Class	e 14 (HI)	ding to T.I.L. M-0	7	
INSTALLATION SPECIFICATIONS	ļ.			rcc Part 15 Class	5 D			
AC Output Conduit Size / AWG Range		3/4"	minimum / 14-6	AWG		3/4" minimu	m /14-4 AWG	Ī
DC Input Conduit Size / # of Strings / AWG Range	************	3/4" minim	um / 1-2 strings	/ 14-6 AWG	**************		n / 1-3 strings / AWG	
Dimensions with Safety Switch (HxWxD)		17.7 x 14	1.6 x 6.8 / 450 x	370 x 174			AWG 7.3 / 540 x 370	in / mm
Weight with Safety Switch Noise	22	/ 10	25.1/11.4	26.2 /	11.9	38.8 <50		lb / kg dBA
Cooling	************		Convection		**************	Natural convection	on	
Operating Temperature Range Protection Rating			-13 to +140 / -2	25 to +60 <sup>(3)</sup> (-40°F (Inverter with Sa	/-40°C option		**************	*F/.°C

RoHS

© SolarEdge Technologies, Inc. All rights reserved. SOLAREDGE, the SolarEdge logo, OPTIMIZED BY SOLAREDGE re trademarks or registered trademarks of SolarEdge Technologies, Inc. All other trademarks mentioned herein e trademarks of their respective owners. Date: 07/2018/V01/ENG IAM. Subject to change without notice.



_						
REVISIONS						
DESCRIPTION	DATE	REV				

Signature with Seal

DATE:03/31/2019

RD.,

2508 SHERIFF JOHNSON | LILLINGTON, NC 27546

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

DESIGNED BY

PHS

SHEET NAME **EQUIPMENT SPECIFICATION** 

SHEET SIZE


**ANSIB** 11" X 17"

SHEET NUMBER



### **Power Optimizer**

P320 / P370 / P400 / P405 / P505



### PV power optimization at the module-level

- Specifically designed to work with SolarEdge inverters
- Up to 25% more energy
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch losses, from manufacturing tolerance to partial shading
- Flexible system design for maximum space utilization
- Fast installation with a single bolt
- Next generation maintenance with module-level monitoring
- Compliant with arc fault protection and rapid shutdown NEC requirements (when installed as part of the SolarEdge system)
- Module-level voltage shutdown for installer and firefighter safety

solaredge

### **Power Optimizer**

P320 / P370 / P400 / P405 / P505

OPTIMIZER MODEL (typical module compatibility)	P320 (for high-power 60-cell modules)	P370 (for higher-power 60 and 72-cell modules)	P400 (for 72 & 96-cell modules)	P405 (for thin film modules)	P505 (for higher current modules)				
NPUT	**								
Rated Input DC Power <sup>(1)</sup>	320	370	400	405	505	W			
Absolute Maximum Input Voltage (Voc at lowest temperature)	48	60	80	125	83	Vdc			
MPPT Operating Range	8 - 48	8 - 60	8 - 80	12.5 - 105	12.5 - 83	Vdc			
Maximum Short Circuit Current (Isc)		1	10	).1	14	Adc			
Maximum DC Input Current	13	.75	12	.63	17.5	Adc			
Maximum Efficiency		****************	99.5		1	%			
Weighted Efficiency		99	3.8		98.6	%			
Overvoltage Category						********			
OUTPUT DURING OPERATION (POWER	R OPTIMIZER CONNE	CTED TO OPERATIN	G SOLAREDGE INVE	RTER)		I.			
Maximum Output Current		01112 10 0121111111	15			Adc			
Maximum Output Voltage	****************	60 85							
OUTPUT DURING STANDBY (POWER O	PTIMIZER DISCONN		EDGE INVERTER OR			Vdc			
Safety Output Voltage per Power Optimizer	THILLER DISCONI	ECTED TROM SOLA	1 ± 0.1	JOEANE DOE HIVE	TER OTT	Vdc			
STANDARD COMPLIANCE									
EMC		ECC Part 15 C	lass B. IEC61000-6-2.	IFC61000-6-3		-			
Safety		IEC62109-1 (class II safety), UL1741							
RoHS	Yes								
INSTALLATION SPECIFICATIONS			ies						
Maximum Allowed System Voltage	T		1000			Vdc			
Compatible inverters		All SolarEdge Single Phase and Three Phase inverters							
terretterretterretterretterretterretterretterret		128 x 152 x 36 / 128 x 152 x 50 / 128 x 152 x 59 /							
Dimensions (W x L x H)	128 × 152 × 28	/5 x 5.97 x 1.1	5 x 5.97 x 1.42	5 x 5.97 x 1.96	5 x 5.97 x 2.32	mm / in			
Weight (including cables)	630	/ 1.4	750 / 1.7	845 / 1.9	1064 / 2.3	gr / lb			
		******************	MC4 <sup>(2)</sup>						
nput Connector	Double Insulated; MC4								
Output Wire Type / Connector	0.95 / 3.0	[	*** *** * * * * * * * * * * * * * * * *	/ 3.9		m / ft			
nput Connector Output Wire Type / Connector Output Wire Length Operating Temperature Range	0.95 / 3.0		1.2,		****************	m / ft "C / "F			
Output Wire Type / Connector	0.95 / 3.0		*** *** * * * * * * * * * * * * * * * *						

<sup>(1)</sup> Rated STC power of the module. Module of up to +5% power tolerance allowed.

<sup>(2)</sup> For other connector types please contact SolarEdge

PV SYSTEM DESIGN US A SOLAREDGE INVERTE	5000000	SINGLE PHASE HD-WAVE	SINGLE PHASE	THREE PHASE 208V	THREE PHASE 480V	
Minimum String Length	P320, P370, P400	8		10	18	
(Power Optimizers)	P405 / P505	6		8	14	
Maximum String Length (Power Optimizers)		25		25	50(5)	
Maximum Power per Str	ng	5700 (6000 with SE7600-US - SE11400- US)	5250	6000	12750	W
Parallel Strings of Differe or Orientations	nt Lengths			Yes		***********

<sup>(3)</sup> For detailed string sizing information refer to: http://www.solaredge.com/sites/default/files/string\_sizing\_na.pdf.
(4) It is not allowed to mix P405/P505 with P320/P370/P400/P600/P700/P800 in one string.
(5) A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement



© SolarEdge Technologies, Inc. All rights reserved. SOLAREDGE, the SolarEdge logo, OPTIMIZED BY SOLAREDGE are trademarks or registered trademarks of SolarEdge Technologies, Inc. All other trademarks mentioned herein are trademarks of their respective owners. Date: 07/2018/V01/ENG NAM. Subject to change without notice.

SOLAR & ROOFING
OWER HOME SOLAR, LLC
"POWER YOUR FUTURE"
919 N. MAIN ST.
"TSVILLE, NC 28115

REVISIONS				
DATE	REV			

Signature with Seal

DATE:03/31/2019

2508 SHERIFF JOHNSON RD., LILLINGTON, NC 27546

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

DESIGNED BY

PHS

**EQUIPMENT SPECIFICATION** 

SHEET SIZE

**ANSIB** 11" X 17"

SHEET NUMBER

PV-9

www.solaredge.us




### **XR** Rail Family

### Solar Is Not Always Sunny

Over their lifetime, solar panels experience countless extreme weather events. Not just the worst storms in years, but the worst storms in 40 years. High winds capable of ripping panels from a roof, and snowfalls weighing enough to buckle a panel frame.

XR Rails are the structural backbone preventing these results. They resist uplift, protect against buckling and safely and efficiently transfer loads into the building structure. Their superior spanning capability requires fewer roof attachments, reducing the number of roof penetrations and the amount of installation time.



### Force-Stabilizing Curve

Sloped roofs generate both vertical and lateral forces on mounting rails which can cause them to bend and twist. The curved shape of XR Rails is specially designed to increase strength in both directions while resisting the twisting. This unique feature ensures greater security during extreme weather and a longer system lifetime.

### Compatible with Flat & Pitched Roofs



XR Rails are compatible with FlashFoot and other pitched roof attachments.



IronRidge offers a range of tilt leg options for flat roof mounting applications.

### **Corrosion-Resistant Materials**

All XR Rails are made of marine-grade aluminum alloy, then protected with an anodized finish. Anodizing prevents surface and structural corrosion, while also providing a more attractive appearance.



### **XR Rail Family**

The XR Rail Family offers the strength of a curved rail in three targeted sizes. Each size supports specific design loads, while minimizing material costs. Depending on your location, there is an XR Rail to match.



#### XR10

XR10 is a sleek, low-profile mounting rail, designed for regions with light or no snow. It achieves 6 foot spans, while remaining light and economical.

- · 6' spanning capability
- Moderate load capability
- · Clear anodized finish
- · Internal splices available



#### XR100

XR100 is the ultimate residential mounting rail. It supports a range of wind and snow conditions, while also maximizing spans up to 8 feet.

- · 8' spanning capability
- · Heavy load capability
- Clear & black anodized finishInternal splices available



#### XR1000

XR1000 is a heavyweight among solar mounting rails. It's built to handle extreme climates and spans 12 feet or more for commercial applications.

- 12' spanning capability
- Extreme load capability
- Clear anodized finish
- · Internal splices available

### **Rail Selection**

The following table was prepared in compliance with applicable engineering codes and standards. Values are based on the following criteria: ASCE 7-10, Roof Zone 1, Exposure B, Roof Slope of 7 to 27 degrees and Mean Building Height of 30 ft. Visit IronRidge.com for detailed span tables and certifications.

Load		Rail Span					
Snow (PSF)	Wind (MPH)	4*	5' 4"	6'	8'	10'	12'
	100						
None	120						
None	140	XR10		XR100		XR1000	
	160						
	100						
10-20	120						
10-20	140						
	160						
30	100						
30	160						
40	100						
40	160						
50-70	160						
80-90	160						

SOLAR & ROOFING
SOLAR & ROOFING
SOLAR & ROOFING
POWER HOME SOLAR, LLC
"POWER YOUR FUTURE"
919 N. MAIN ST.
MOORESVILLE, NC 28115
Phone: 704-800-6591 (OFFICE)
Email: info@powerhome.com
Web: www.powerhome.com

REVISIONS				
DESCRIPTION	DATE	REV		

Signature with Seal

DATE:03/31/2019

PROJECT NAME & ADDRESS

JANETTE RUIZ
RESIDENCE
2508 SHERIFF JOHNSON RD.,
LILLINGTON, NC 27546

DESIGNED BY

PHS

SHEET NAME
EQUIPMENT
SPECIFICATION

SHEET SIZE

ANSI B 11" X 17"

SHEET NUMBER

PV-10

© 2014 IronRidge, Inc. All rights reserved. Visit www.ironridge.com or call 1-800-227-9523 for more information. Version 1.1




### **UFO Family of Components**

### **Simplified Grounding for Every Application**

The UFO family of components eliminates the need for separate grounding hardware by bonding solar modules directly to IronRidge XR Rails. All system types that feature the UFO family-Flush Mount, Tilt Mount and Ground Mount-are fully listed to the UL 2703 standard.

UFO hardware forms secure electrical bonds with both the module and the rail, resulting in many parallel grounding paths throughout the system. This leads to safer and more reliable installations.




### **Bonded Splice** Each Bonded Splice uses self-drilling screws to form a secure connection. No bonding strap needed.



### **Bonded Attachments**

The bonding bolt attaches and bonds the L-foot to the rail. It is installed with the same socket as the rest of the

### System Diagram



Approved Enphase microinverters can provide equipment grounding of IronRidge systems, eliminating the need for grounding lugs and field installed equipment ground conductors (EGC). A minimum of two microinverters mounted to the same rail and connected to the same Engage cable is required. Refer to installation manuals for additional details.

### **UL Certification**

The IronRidge Flush Mount, Tilt Mount, and Ground Mount Systems have been listed to UL 2703 by Intertek Group plc.

UL 2703 is the standard for evaluating solar mounting systems. It ensures these devices will maintain strong electrical and mechanical connections over an extended period of time in extreme outdoor environments.

Go to IronRidge.com/UFO

Feature	Flush Mount	Tilt Mount	Ground Mount	
XR Rails	•	· ·		
UFO/Stopper	-	~	~	
Bonded Splice	•	~	N/A	
Grounding Lugs	1 per Row	1 per Row	1 per Array	
Microinverters & Power Optimizers	Darfon - M	0-72, M250-60, M IIG240, MIG300, C P320, P400, P405		
Fire Rating	Class A	Class A	N/A	
Modules	Tested or Evaluated with over 400 Framed Modules Refer to installation manuals for a detailed list.			

REVISIONS				
DESCRIPTION	DATE	REV		

Signature with Seal

DATE:03/31/2019

RD.,

2508 SHERIFF JOHNSON | LILLINGTON, NC 27546

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

DESIGNED BY

PHS SHEET NAME

**EQUIPMENT SPECIFICATION** 

SHEET SIZE

**ANSIB** 11" X 17"

SHEET NUMBER

## Low Profile QuickBOLT™ (



Part#	Box Quantity	Size	
Ì	10 Washers;	5/16" x 3";	
17667	10 Bolts;	5/16" x 5.25";	
17007	10 Offset L-Feet;	NA;	
	10 Serrated Hex Flange Nuts	5/16"	




5830 Las Positas Road, Livermore, California 94551 | 3948 Airway Drive, Rock Hill, South Carolina 29732 Phone: (844)-671-6045 | Fax: (800)-689-7975 | www.solarroofhook.com SolarRoofHook is a division of Quickscrews International Corp.









# LOW PROFILE QUICKBOLT TO INSTALLATION INSTRUCTIONS











### **RECOMMENDED MATERIALS**

- Rafterlocater
- Chalk or crayon
- + 3/16" Drill Bit
- Roofing Manufacturer's approved sealant

### **INSTALLATION INSTRUCTIONS**

- 1. Locate and mark the rafters.
- 2. Predrill the hole with the 3/16" Drill Bit.
- 3. Fill the predrilled hole with sealant.

  \*We also recommend creating a circle of sealant on the back of the
- 4. Place the EPDM Washer & drive the Bolt until the Washer compresses to the roof.
- 5. Place the L-Foot & Nut.
- 6. Tighten the Nut until the L-Foot is secure.

### WHERE IS MY FLASHING?

The Stainless Steel backed EPDM Washer is fully Code-Complaint and does not require additional Sheet Metal Flashing. The collar on the QuickBOLT™ compresses the washer down onto the roof, forming a 100% leak-proof seal.



INSTALLATION VIDEOS, SPEC SHEETS, & TEST RESULTS AVAILABLE ON WWW.SOLARROOFHOOK.COM

POWERHOME SOLAR & ROOFING POWER HOME SOLAR, LLC "POWER YOUR FUTURE"

REVISIONS				
DESCRIPTION DATE RE				

Signature with Seal

DATE:03/31/2019

RD.,

2508 SHERIFF JOHNSON | LILLINGTON, NC 27546

PROJECT NAME & ADDRESS

JANETTE RUIZ RESIDENCE

DESIGNED BY

PHS

SHEET NAME
EQUIPMENT
SPECIFICATION

SHEET SIZE

ANSI B 11" X 17"

SHEET NUMBER