

Attachment 2



**South River Electric
Membership Corporation**

A Touchstone Energy® Cooperative 

Renewable Generator Interconnection Request Up to 50 kw (Application Form)

Service Provider: _____ South River Electric Membership Corporation _____

Service Provider Contact Person: Catherine O'Dell _____

Telephone Number: 910-230-2982 _____

Fax Number: 910-230-2995 _____

E-Mail Address: codell@sremc.com _____

Address: P.O.Box 931, Dunn, NC 28335 (17494 NC Hwy 421 South) _____

An interconnection request is considered complete when it provides all applicable and correct information required below. Documentation of site control must be submitted with the interconnection request.

Interconnection Customer Information:

Legal name of the interconnection customer (Or, if an individual, individual's name)

Company: _____

Contact Person: Harold Brunson _____

Mailing Address: 582 McNeil Hobbs Rd _____

City: Bunnlevel State: NC Zip: 28323 _____

Facility Location (If different from above): Same as above _____

Telephone Number: 910-890-6749 Cellular Number: _____

Fax Number: _____ E-Mail Address: louisebrunson@yahoo.com _____

Alternative Contact Information (If different from the interconnection customer)

Contact Name: _____

Title: _____

Attachment 2

Address: _____

Telephone Number: _____ Cellular Number: _____

Fax Number: _____ E-Mail Address: solar@powerhome.com

Application is for: New renewable generating facility
 Capacity addition to existing renewable generator facility

If capacity addition to existing facility, please describe: _____

Will the renewable generating facility be used for any of the following?

Net metering? **Yes** No
To supply power to the interconnection customer? **Yes** No
To supply power to others? Yes **No** (**excess to SREMC**)

Requested point of interconnection: 10/18/19 South River EMC meter

11/4/18

Interconnection customer's requested in-service date: _____

For installations at locations with existing electric service where the proposed renewable generating facility will interconnect, provide:

South River Electric Membership Corporation 300084000003
(Electric Service Provider) (Existing Account Number(s))

(Please provide contact information for existing owner(s) of each account number. If multiple account numbers, please use space provided on last page of this Interconnection Request)

Eric Kappaz
Contact Name: _____

Interconnection Specialist
Title: _____

919 N. Main St. Mooresville NC, 28115
Address: _____

843-277-6960
Telephone Number: _____ Cellular Number: _____

Fax Number: _____

E-Mail Address: solar@powerhome.com

Attachment 2

Renewable Generating Facility Information:

Location (if different from above): Same as above

Cooperative: South River EMC

Account Number: 300084000003

Inverter Manufacturer: Solar Edge Technologies Model 10000H-US

Is the equipment UL 1741 Listed? Yes No

If Yes, attach manufacturer's cut-sheet/specifications showing UL 1741 listing for model.

Nameplate Rating: 10.0 (kW) _____ (kVA) 240 (AC Volts)

Single Phase Three Phase _____

System Design Capacity: 9.6 (kW) _____ (kVA)

Prime Mover:

Photovoltaic Other
 Reciprocating Engine Fuel Cell Micro Turbine

Energy Source: Solar Wind Hydro Diesel Natural Gas Fuel Oil

Other (describe) _____

Is the equipment identified and listed as "Utility Interactive" when operated in conjunction with a voltage inverter that is UL 1741 Listed? Yes No

Estimated Installation Date: 10/18/19 Estimated In-Service Date: 11/4/19

The 50 kw Inverter Process is available only for inverter-based Generating Facilities no larger than 50 kw that meet the codes, standards, and certification requirements of Attachments 3 and 4 of the North Carolina Interconnection Procedures, or the Cooperative has reviewed the design or tested the proposed Generating Facility and is satisfied that it is safe to operate.

List components of the Generating Facility equipment package that are currently certified:

	Equipment Type	Certifying Entity
1. <u>Silfab</u>	<u>_____</u>	ULC ORD C1703,UL1703, IEC 61215, IEC 61730, IEC 61701,CEC Listed
2. _____	_____	_____
3. _____	_____	_____

Attachment 2

- 4. _____
- 5. _____
- 6. _____

Interconnection Member Signature

I hereby certify that, to the best of my knowledge, the information provided in this Interconnection Request is true. I agree to abide by the Terms and Conditions for Interconnecting a Certified Inverter-Based Generating Facility No Larger than 50 kw and return the Certificate of Completion when the Generating Facility has been installed.

Signed: Harold Brunson

Title: Homeowner Date: 10/4/19

.....
Contingent Approval to Interconnect the Generating Facility (For Cooperative use only)

Interconnection of the Generating Facility is approved contingent upon the Terms and Conditions for Interconnecting a Certified Inverter-Based Generating Facility No Larger than 50 kw and return of the Certificate of Completion.

Cooperative Representative Signature: _____

Title: _____ Date: _____

Interconnection Request ID number: _____

Cooperative waives inspection/witness test? Yes No

DOCKET NO. SP 19393, SUB 0

Filing Fee Tendered \$ 50.00

Report of Proposed Construction (RPC) – Commission Rule R8-65

Pursuant to G.S. 62-110.1(g), any person who seeks to construct an electric generating facility in North Carolina, and is exempt from the requirement to obtain a certificate of public convenience and necessity, is required to file this form and a notice of completion of the construction of the facility. This form may be accompanied by any exhibits or additional responses incorporated by reference thereto and attached to this form. This form must be accompanied by the required filing fee of \$50.00.

This form may be electronically filed. Please see www.ncuc.net for instructions.

If this form is filed by hard copy, the original plus 6 copies must be presented at or transmitted to the office of the Chief Clerk. Regardless of the method of delivery, this form is not deemed filed until it is received by the Chief Clerk, along with the required filing fee.

The mailing address is:

Chief Clerk
 NC Utilities Commission
 4325 Mail Service Center
 Raleigh, NC 27699-4325

Exhibits required by Rule R8-65(g)		Applicant's Response
(1)(i)	Full and correct name of the owner of the facility	Harold Brunson
	Facility name	
	Business address	582 Mcneil Hobbs Rd. Bunnlevel, NC, 28323
	E-mail address	louisebrunson@yahoo.com
	Telephone number	(910) 890-6749
(ii)	The owner is (check one)	<input checked="" type="checkbox"/> Individual <input type="checkbox"/> Partnership <input type="checkbox"/> Corporation
	If a partnership, the name and business address of each general partner	
	If a corporation, the state and date of incorporation	
	If a partnership, the name and address of each general partner (add additional sheets if necessary)	

	Owner's agent for purposes of this report, if applicable:	Eric Kappaz
	Agent's business address	919 N. Main St. Mooresville, NC, 28115
	Agent's e-mail address	solar@powerhome.com
	Agent's telephone number	(843) 277-6960
(iii)	The full and correct name of the site owner and, if the site owner is other than the applicant, the applicant's legal interest in the site	Harold Brunson
(2)(i)	Attach a color map or aerial photo showing the location of the generating facility site in relation to local highways, streets, rivers, streams, and other generally known local landmarks with the proposed location of major equipment indicated on the map or photo, including: the generator, fuel handling equipment, plant distribution system, startup equipment, the site boundary, planned and existing pipelines, planned and existing roads, planned and existing water supplies, and planned and existing electric facilities;. A U.S. Geological Survey map or an aerial photo map prepared via the State's geographic information system (found at www.gis.ncdcr.gov/hpoweb/) is preferred.	
(ii)	E911 street address of the proposed facility	582 Mcneil Hobbs Rd. Bunnlevel, NC, 28323
	County in which the proposed facility will be physically located	Harnett
	GPS coordinates of the approximate center of the proposed facility site to the nearest second or one thousandth of a degree	Lat: 35.351279 Long: -78.837908
(3)(i)	The nature of the facility, including its technology, and the source of its power and fuel(s)	This ROPC is for a 9.6 kw-DC Solar Photovoltaic array, ground-mounted and grid-tied. The source facility power is solar energy
(ii)	A description of the buildings, structures and equipment comprising the generating facility and the manner of its operation	The system will be a ground-mounted solar PV array at the above mentioned address. The system will be grid-tied and does not have a battery back-up.
(iii)	The gross and net projected maximum dependable capacity of the facility in megawatts – Alternating Current	System losses include DC to AC conversion, wiring and other factors. Due to intermittent solar availability, the maximum dependable capacity is 0 megawatts.

	The facility's nameplate capacity in megawatts – Alternating Current	
(iv)	The projected date on which the facility will come on line	11/03/2019
(v)	The applicant's general plan for sale of the electricity to be generated, including the name of utility to which the applicant plans to sell the electricity	The applicant plans on Net Metering under the South River EMC net meter rider. South River EMC will retain any excess Renewable Energy Credit.
(vi)	Any provisions for wheeling of the electricity, if applicable	
(vii)	Arrangements for firm, non-firm, or emergency generation, if applicable	
(viii)	The service life of the project	The projected lifetime of the equipment is 25 years.
(ix)	The projected annual sales in kilowatt-hours	Annual production credit is expected to be 0 KWh/yr.
(x)	Whether the applicant intends to produce renewable energy certificates that are eligible for compliance with the State's renewable energy and energy efficiency portfolio standard <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
(4)	The expected cost of the proposed facility	\$ 49,350.00

Confidentiality

If an applicant considers certain of the required information above to be confidential and entitled to protection from public disclosure, it may designate said information as confidential and file it under seal. Documents marked as confidential will be treated pursuant to applicable Commission rules, procedures, and orders dealing with filings made under seal and with nondisclosure agreements.

All reports shall be signed and verified (notarized) by the applicant or by an individual duly authorized to act on behalf of the applicant for the purpose of the report. A blank verification page is attached below:

VERIFICATION

STATE OF North Carolina COUNTY OF Iredell

Debra Kiser
Signature of Owner's Representative or Agent

Interconnection Coordinator
Title of Representative or Agent

Debra Kiser
Typed or Printed Name of Representative or Agent

The above named person personally appeared before me this day and, being first duly sworn, says that the facts stated in the foregoing report and any exhibits, documents, and statements thereto attached are true as he or she believes.

WITNESS my hand and notarial seal, this 4th day of Oct., 2019.

My Commission Expires: 9/19/22

[Signature]
Signature of Notary Public

LaShawna Williams
Name of Notary Public – Typed or Printed



This original verification must be affixed to the original report, and a copy of this verification must be affixed to each of the copies that are also submitted to the Commission.



HPO Data Layers

Background View



Find an address

Locations found: 1

582 McNeill Hobbs Rd, Bunnlevel, North Carolina, 28323
Score: 98.7

582 McNeill Hobbs Rd, Bunnlevel, North Carolina, 28323
Score: 98.7

[Zoom to](#)

HANETT

Search Results



Latitude: 35.356721 Longitude: -78.817485 Scale 1 : 9,027.9

OFFICIAL COPY
Oct 04 2019



Find an address

Locations found: 1

582 McNeill Hobbs Rd, Bunnlevel, North Carolina, 28323
Score: 98.7

582 McNeill Hobbs Rd, Bunnlevel, North Carolina, 28323
Score: 98.7

Zoom to

HAYLETT

HP 5178743 47 COINSURANCE CONTRACT
 NORTH CAROLINA FARM BUREAU MUTUAL INSURANCE COMPANY PART B DECLARATION PAGE
 P.O. BOX 27427 RALEIGH, NORTH CAROLINA 27611-7427 HOMEOWNERS POLICY

CORRECTED RENEWAL DECLARATION - COVERAGE WILL EXPIRE ON 03/10/19 IF PREMIUM IS NOT PAID.

REASON FOR AMENDMENT SEE DETAILED CHANGES



POLICY NUMBER	POLICY PERIOD 1 FROM TO	MEMBERSHIP NO	AGENT CODE
HP 5178743	03/10/19 03/10/20	0480676	0435555

NAMED INSURED AND ADDRESS
 HAROLD L BRUNSON
 LOUISE F BRUNSON
 582 MCNEILL HOBBS RD
 BUNNLEVEL, NC 28323-8986

AGENT
 JUSTIN RAY
 TELE: (910) 893-8311
 PO BOX 369
 LILLINGTON, NC 27546

TOTAL ANNUAL PREMIUM - - - - - \$1,267

THE PREMISES COVERED BY THIS POLICY IS LOCATED
 582 MCNEILL HOBBS RD BUNNLEVEL NC 28323 HARNETT CNTY.

RATING INFORMATION- AUTOMATIC VALUE-UP AT RENEWAL, FRAME, CONSTRUCTED IN 1935,
 PRIMARY RESIDENCE, FIRE PROTECTION - SUMMERVILLE BUNNLEVEL FD,
 PROTECTION CLASS 5, ANNUAL INCREASE IN SECTION I COVERAGES IS 4.0%,
 TERRITORY 250, HYDRANT WITHIN 1000 FEET,
 \$ 500 SECTION I ALL OTHER PERILS LOSS DEDUCTIBLE,
 \$1000 SECTION I WINDSTORM OR HAIL LOSS DEDUCTIBLE 1 FAMILY.
 LAST REWRITE 03/18.

COVERAGE AT THE ABOVE DESCRIBED LOCATION IS PROVIDED ONLY WHERE A LIMIT OF LIABILITY IS SHOWN OR A PREMIUM IS STATED

SECTION I COVERAGE	LIMIT OF LIABILITY	PREMIUMS
A. DWELLING	\$206,000	\$942
B. OTHER STRUCTURES	\$20,600	
C. PERSONAL PROPERTY	\$144,200	\$62
D. LOSS OF USE	\$41,200	
SECTION II COVERAGE		
E. PERSONAL LIABILITY	\$300,000 EACH OCCURRENCE	
F. MEDICAL PAY. TO OTHERS -	\$1,000 EACH PERSON	\$8
	BASIC PREMIUM - - - - -	\$1,012

ADDITIONAL PREMIUMS

PROJECT DESCRIPTION:

32 x SILFAB SOLAR SILFAB SIL-300 ML 300W MONO MODULES
 GROUND MOUNTED SOLAR PHOTOVOLTAIC MODULES
 SYSTEM SIZE: 9.60 kW DC STC
 ARRAY AREA #1:- 585.60 SQ FT.

EQUIPMENT SUMMARY

32 SILFAB SOLAR SILFAB SIL-300 ML 300W MODULES
 32 SOLAREGE POWER OPTIMIZER P320
 01 SOLAREGE SE10000H-US INVERTER

APPLICABLE CODES & STANDARDS


BUILDING: NCBC 2018
 ELECTRICAL: NEC 2017

DESIGN SPECIFICATION


OCCUPANCY: II
 CONSTRUCTION: SINGLE-FAMILY
 FIRE: RESIDENTIAL
 GROUND SNOW LOAD: 20 PSF
 WIND EXPOSURE: B
 WIND SPEED: 115 MPH

AUTHORITIES HAVING JURISDICTION

BUILDING: HARNETT COUNTY
 ZONING: HARNETT COUNTY
 UTILITY: SOUTH RIVER ELECTRIC CORP




1 PLOT PLAN WITH ROOF PLAN
 PV-1 SCALE: 1"=50'-0"



NOTE: GROUND MOUNT LOCATION TBD ON-SITE



2 HOUSE PHOTO
 PV-1 SCALE: NTS



3 VICINITY MAP
 PV-1 SCALE: NTS

SHEET INDEX

PV-1	PLOT PLAN & VICINITY MAP
PV-2	ROOF PLAN & MODULES
PV-2A	STRING LAYOUT
PV-3	GROUNDING DETAILS
PV-3A	GROUNDING DETAILS
PV-4	ELECTRICAL LINE DIAGRAM
PV-5	WIRING CALCULATIONS
PV-6	SOLAREGE OPTIMIZER CHART
PV-7 to 10	EQUIPMENT SPECIFICATIONS

POWERHOME SOLAR & ROOFING
 POWER HOME SOLAR, LLC
 "POWER YOUR FUTURE"
 919 N. MAIN ST.
 MOORESVILLE, NC 28115
 Phone: 704-800-6591 (OFFICE)
 Email: info@powerhome.com
 Web: www.powerhome.com

REVISIONS

DESCRIPTION	DATE	REV

Signature with Seal

DATE: 10/03/2019


PROJECT NAME & ADDRESS

HAROLD LLOYD BRUNSON RESIDENCE
 582 MCNEIL HOBBS RD.,
 BUNNLEVEL, NC 28323

SHEET NAME	PLOT PLAN & VICINITY MAP
SHEET SIZE	ANSI B 11" X 17"
SHEET NUMBER	PV-1

MODULE TYPE, DIMENSIONS & WEIGHT

NUMBER OF MODULES = 32 MODULES
 MODULE TYPE = SILFAB SOLAR SILFAB SIL-300 ML 300W MONO MODULES
 MODULE WEIGHT = 41.89 LBS / 19 KG.
 MODULE DIMENSIONS = 66.93"x 39.37" = 18.30 SF



POWERHOME SOLAR & ROOFING
 POWER HOME SOLAR, LLC
 "POWER YOUR FUTURE"
 919 N. MAIN ST.
 MOORESVILLE, NC 28115
 Phone: 704-800-6591 (OFFICE)
 Email: info@powerhome.com
 Web: www.powerhome.com

REVISIONS		
DESCRIPTION	DATE	REV


Signature with Seal
 DATE: 10/03/2019

PROJECT NAME & ADDRESS
HAROLD LLOYD BRUNSON RESIDENCE
 582 MCNEIL HOBBS RD.,
 BUNNLEVEL, NC 28323

SHEET NAME
ROOF PLAN & MODULES


SHEET SIZE
**ANSI B
 11" X 17"**

SHEET NUMBER
PV-2



LEGEND	
[JB]	- JUNCTION BOX
[INV]	- INVERTER
[DC]	- INTEGRATED DC DISCONNECT
[SLD]	- SOLAR LOAD CENTER
[PVM]	- PRODUCTION METER
[MSP]	- MAIN SERVICE PANEL
○	- VENT, ATTIC FAN (ROOF OBSTRUCTION)
●	- ROOF ATTACHMENT
---	- RAFTERS
- - -	- CONDUIT
[CB]	- COMBINER BOX

(32) SILFAB SOLAR SILFAB SIL-300 ML
300W MONO MODULES
(2) STRING OF 16 MODULES CONNECTED IN SERIES



SolarEdge Power Optimizer P320 Rated
DC Input Power - 320 watts
Maximum Input Voltage - 48 Vdc
MPPT Range - 8 to 48 Vdc
Maximum Short Circuit Current - 11 Adc
Maximum Output Current - 15 Adc String
Limitations - 8 to 25 Optimizers,
5700 watts STC per string maximum

SOLAREGE SE10000H-US (240V)
OUTPUT: 240 VAC, 42A
99% CEC WEIGHTED EFFICIENCY
NEMA 3R, UL LISTED, INTERNAL GFDI
WITH INTEGRATED DC DISCONNECT

JUNCTION BOX
600 V, NEMA 3
UL LISTED

REF NEC 230.82(6) FOR
SUPPLY SIDE TAP

TO UTILITY GRID
L1
L2
N

BI-DIRECTIONAL
UTILITY METER
1-PHASE, 3-W,
120V/240V

SUPPLY SIDE TAP

(E) MAIN BREAKER TO
HOUSE 240 V, 200A/2P
(BOTTOM FED)

(E) MAIN SERVICE
PANEL, SQUARE D
200A RATED, 240V

LOAD/LINE SIDE
INTERCONNECTION
AT MAIN PANEL
PER ART. 705.12

EXISTING GROUNDING
ELECTRODE SYSTEM
TO EARTH
REF. NEC 250.52,
250.53(A)

AC DISCONNECT:
60A FUSED, (2) 60A FUSES,
240V NEMA 3R, UL LISTED

WARNING:
PHOTOVOLTAIC
POWER SOURCE

LABEL 1
ON ALL CONDUITS SPACED AT MAX 10FT

! CAUTION !
SOLAR ELECTRIC
SYSTEM CONNECTED
AND ENERGIZED

LABEL 2
AT INVERTER

SOLAR PV SYSTEM EQUIPPED
WITH RAPID SHUTDOWN
TURN RAPID SHUTDOWN
SWITCH TO THE
"OFF" POSITION TO
SHUT DOWN PV SYSTEM
AND REDUCE
SHOCK HAZARD
IN THE ARRAY

LABEL 3
AT INVERTER

PHOTOVOLTAIC
DC DISCONNECT

LABEL 4
AT EACH DC DISCONNECT

! WARNING !
ELECTRIC SHOCK HAZARD
DO NOT TOUCH TERMINALS
TERMINALS ON BOTH LINE AND LOAD SIDE
MAY BE ENERGIZED IN THE OPEN POSITION

LABEL 5
AT EACH AC DISCONNECT

PHOTOVOLTAIC
AC
DISCONNECT

LABEL 6
AT EACH AC DISCONNECT

! WARNING !
DUAL POWER SOURCES
SECOND SOURCE IS PV SYSTEM

LABEL 8
AT MEP

! WARNING !
SOLAR SYSTEM
CONNECTED
AND ENERGIZED

LABEL 9
AT MEP

! CAUTION !
SOLAR POINT OF
INTERCONNECTION

LABEL 10
AT UTILITY METER

! WARNING !
THE SERVICE METER IS ALSO SERVED
BY A PHOTOVOLTAIC SYSTEM

LABEL 11
AT UTILITY METER

QTY	CONDUCTOR INFORMATION	CONDUIT TYPE	CONDUIT SIZE
(4)	#10AWG - PV WIRE/USE-2	N/A	N/A
(1)	#6AWG - BARE COPPER IN FREE AIR		
(4)	#10AWG - THWN-2	IMC OR PVC IN TRENCH / LFNC	3/4"
(1)	#6AWG - THWN-2 GND		
(3)	#6AWG - THWN-2	PVC, LFNC OR LFMC	3/4"
(1)	#6AWG - THWN-2 GND		
(3)	#6AWG - THWN-2	PVC, LFNC OR LFMC	3/4"
(1)	#6AWG - THWN-2 GND		

SERVICE INFO	
UTILITY PROVIDER:	SOUTH RIVER ELECTRIC CORP
MAIN SERVICE VOLTAGE:	240V
MAIN PANEL BRAND:	
MAIN SERVICE PANEL:	200A
MAIN CIRCUIT BREAKER RATING:	200A
MAIN SERVICE LOCATION:	SOUTHEAST
SERVICE FEED SOURCE:	UNDERGROUND

REVISIONS		
DESCRIPTION	DATE	REV

Signature with Seal
DATE: 10/03/2019

PROJECT NAME & ADDRESS

**HAROLD LLOYD BRUNSON
RESIDENCE**
582 MCNEIL HOBBS RD.,
BUNNLEVEL, NC 28323

SHEET NAME
**ELECTRICAL LINE
DIAGRAM**

SHEET SIZE
**ANSI B
11" X 17"**

SHEET NUMBER
PV-4



SLA-M Monocrystalline



300 Wp 60 Cell Monocrystalline PV Module

100% MAXIMUM POWER DENSITY


Silfab's SLA-M 300 ultra-high-efficiency modules are optimized for both Residential and Commercial projects where maximum power density is preferred.

100% NORTH AMERICAN QUALITY MATTERS

Silfab's fully-automated manufacturing facility ensures precision engineering is applied at every stage. Superior reliability and performance combine to produce one of the highest quality modules with the lowest defect rate in the industry.

NORTH AMERICAN CUSTOMIZED SERVICE

Silfab's 100% North American based team leverages just-in-time manufacturing to deliver unparalleled service, on-time delivery and flexible project solutions.



ENSURES MAXIMUM EFFICIENCY

60 of the highest efficiency, premium quality monocrystalline cells result in a maximum power rating of 300Wp.

ADVANCED PERFORMANCE WARRANTY

30-year linear power performance guarantee

ENHANCED PRODUCT WARRANTY

25-year product workmanship warranty*

BUILT BY INDUSTRY EXPERTS

With over 35 years of industry experience, Silfab's technical team are pioneers in PV technology and are dedicated to an innovative approach that provides superior manufacturing processes including: infra-red cell sorting, glass washing, automated soldering and meticulous cell alignment.

POSITIVE TOLERANCE

(-0/+5W) All positive module sorting ensures maximum performance

LOWEST DEFECT RATE*

Total automation ensures strict quality control during each step of the process at our certified ISO manufacturing facility. *82.56 ppm as per December 2017

LIGHT AND DURABLE

Over-engineered to weather low load bearing structures up to 5400 Pa. Light-weight frame exclusively designed with wide-ranging racking compatibility and durability.

PID RESISTANT

Proven in accordance to IEC 62804-1

AVAILABLE WITH

Black Frame and Backsheet

*12 year, extendable based on registration at www.silfabsolar.com

Electrical Specifications		SILFAB SLA Monocrystalline	
Test Conditions		STC	NOCT
Module Power (Pmax)	Wp	300	227
Maximum power voltage (Vpmax)	V	32.8	29.5
Maximum power current (Ipmax)	A	9.16	7.69
Open circuit voltage (Voc)	V	39.85	36.9
Short circuit current (Isc)	A	9.71	7.96
Module efficiency	%	18.4	17.3
Maximum system voltage (VDC)	V		1000
Series fuse rating	A		20
Power Tolerance	Wp		-0/+5


Measurement conditions: STC 1000 W/m² • AM 1.5 • Temperature 25 °C • NOCT 800 W/m² • AM 1.5 • Measurement uncertainty ≤ 3%
 • Sun simulator calibration reference modules from Fraunhofer Institute. Electrical characteristics may vary by ±5% and power by -0/+5.

Temperature Ratings		SILFAB SLA Monocrystalline	
Temperature Coefficient Isc	%/K		0.03
Temperature Coefficient Voc	%/K		-0.30
Temperature Coefficient Pmax	%/K		-0.38
NOCT (± 2°C)	°C		45
Operating temperature	°C		-40/+85

Mechanical Properties and Components		SILFAB SLA Monocrystalline	
Module weight (± 1 kg)	kg		19
Dimensions (H x L x D; ± 1mm)	mm		1650 x 990 x 38
Maximum surface load (wind/snow)*	N/m ²		5400
Hail impact resistance			Ø 25 mm at 83 km/h
Cells			60 - Si monocrystalline - 4 or 5 busbar - 156.75 x 156.75 mm
Glass			3.2 mm high transmittance, tempered, antireflective coating
Backsheet			Multilayer polyester-based
Frame			Anodized Al
Bypass diodes			3 diodes-45V/12A, IP67/IP68
Cables and connectors (See installation manual)			1200 mm Ø 5.7 mm (4 mm ²), MC4 compatible

Warranties		SILFAB SLA Monocrystalline	
Module product workmanship warranty			25 years*
Linear power performance guarantee			30 years

Certifications		SILFAB SLA Monocrystalline	
Product		ULC ORD C1703, UL 1703, IEC 61215, IEC 61730-1 and IEC 61730-2 Certified. FSEC and CEC listed. IEC 62716 Ammonia Corrosion, IEC 61701:2011 Salt Mist Corrosion Certified	
Factory		UL Fire Rating: Type 2 (Type 1 on request) ISO9001:2015	

 Warning: Read the installation and User Manual before handling, installing and operating modules.

Third-party generated pan files from Fraunhofer-Institute for Solar Energy Systems ISE are available for download at:
www.silfabsolar.com/downloads




- Modules Per Pallet: 26
- Pallets Per Truck: 36
- Modules Per Truck: 936



Silfab Solar Inc.
 240 Courtneypark Drive East
 Mississauga ON L5T 2Y3 Canada
 Tel +1 905-255-2501 | Fax +1 905-696-0267
 info@silfabsolar.com | www.silfabsolar.com



Silfab Solar Inc.
 800 Cornwall Ave
 Bellingham WA 98225 USA
 Tel +1 360-569-4733



solar**edge**

Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US /
SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US



INVERTERS

Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Record-breaking efficiency
- Fixed voltage inverter for longer strings
- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12
- UL1741 SA certified, for CPUC Rule 21 grid compliance
- Extremely small
- High reliability without any electrolytic capacitors
- Built-in module-level monitoring
- Outdoor and indoor installation
- Optional: Revenue grade data, ANSI C12.20 Class 0.5 (0.5% accuracy)





Single Phase Inverter

with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US /
SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US

	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
OUTPUT								
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400	VA
Max. AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400	VA
AC Output Voltage Min.-Nom.-Max. (183 - 208 - 229)	-	✓	-	✓	-	-	-	Vac
AC Output Voltage Min.-Nom.-Max. (211 - 240 - 264)	✓	✓	✓	✓	✓	✓	✓	Vac
AC Frequency (Nominal)					59.3 - 60 - 60.5 ⁽¹⁾			Hz
Maximum Continuous Output Current 208V	-	16	-	24	-	-	-	A
Maximum Continuous Output Current @240V	12.5	16	21	25	32	42	47.5	A
GFDI Threshold					1			A
Utility Monitoring, Islanding Protection, Country Configurable Thresholds					Yes			
INPUT								
Maximum DC Power @240V	4650	5900	7750	9300	11800	15500	17650	W
Maximum DC Power @208V Transformer-less, Ungrounded	-	5100	-	7750 Yes	-	-	-	
Maximum Input Voltage					480			Vdc
Nominal DC Input Voltage					380		400	Vdc
Maximum Input Current 208V	-	9	-	13.5	-	-	-	
Maximum Input Current @240V	8.5	10.5	13.5	16.5	20	27	30.5	Adc
Max. Input Short Circuit Current					45			Adc
Reverse-Polarity Protection					Yes			
Ground-Fault Isolation Detection					600ka Sensitivity			
Maximum Inverter Efficiency	99			99.2				%
CEC Weighted Efficiency					99			%
Nighttime Power Consumption					< 2.5			W
ADDITIONAL FEATURES								
Supported Communication Interfaces Revenue Grade Data, ANSI C12.20 Rapid Shutdown - NEC 2014 and 2017 690.12					RS485, Ethernet, ZigBee (optional), Cellular (optional) Optional ⁽²⁾			
					Automatic Rapid Shutdown upon AC Grid Disconnect			
STANDARD COMPLIANCE								
Safety					UL1741, UL1741 SA, UL1699B, CSA C22.2, Canadian AFCL according to T.I.L. M-07			
Grid Connection Standards					IEEE1547, Rule 21, Rule 14 (H)			
Emissions					FCC Part 15 Class B			
INSTALLATION SPECIFICATIONS								
AC Output Conduit Size / AWG Range					3/4" minimum / 14-6 AWG		3/4" minimum / 14-4 AWG	
DC Input Conduit Size / # of Strings / AWG Range					3/4" minimum / 1-2 strings / 14-6 AWG		3/4" minimum / 1-3 strings / 14-6 AWG	
Dimensions with Safety Switch (HxWxD)					17.7 x 14.6 x 6.8 / 450 x 370 x 174		21.3 x 14.6 x 7.3 / 540 x 370 x 185	in / mm
Weight with Safety Switch	22 / 10	25.1 / 11.4	26.2 / 11.9			38.8 / 17.6		lb / kg
Noise					< 25		< 50	dBA
Cooling					Natural Convection		Natural convection	
Operating Temperature Range					-13 to +140 / -25 to +60 ⁽³⁾ (-40° F / -40° C option) ⁽⁴⁾			°F / °C
Protection Rating					NEMA 3R (Inverter with Safety Switch)			

⁽¹⁾ For other regional settings please contact SolarEdge support

⁽²⁾ Revenue grade inverter P/N: SExxxH-US000N2

⁽³⁾ For power de-rating information refer to: <https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf>

⁽⁴⁾ -40 version P/N: SExxxH-US000N4

