Briggs and Stratton Power Profile



Tell us about your home

Tony Womack 6249 Cool Springs Rd Broadway NC 27505

What Size is your Electrical Service?

200 Amp

What is the square footage of your home?

1500

What fuel type will you run your generator on?
What size is the propane tank?
Number of Small Appliance Circuits (Min 2)
Additional 120V Branch Circuits (Min 1)

Propane	
	300
	4
	6

Major electrical appliances in your home

Are you willing to manage this appliance?



No	
Yes	Outside
Yes	Beside a/h
Yes	beside wh
No	
Max Output (w)	
	Yes Yes Yes No



- 19.2 Minimum load requirment based on National Electrical Code Part III
- 19.2 Minimum load with capacitive load
- 37.9 Maximum load requirment based on National Electrical Code Part III*
- 37.9 Maximum load with capacitive load
- 20 kW Recommended Size Generator for your Home
 - 3 Module(s) for power management