



# Permit Inspections Harnett County

**Permit Number: ERES1911-0036**

Description: **Redo electrical / replace tub**

Applied: **11/22/2019**

Approved: **11/22/2019**

Site Address: **100 PINECREST ST B**

Issued: **11/22/2019**

Finalized: **4/1/2020**

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **FINALED**

Applicant: **NORTHPOINT LAKE CHARLES LLC**

Parent Permit:

Owner: **NORTHPOINT LAKE CHARLES LLC**

Parent Project:

Contractor: **Anderson's Electrical**

Details:

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	11/25/2019	11/25/2019	ROUGH IN	Steven Gazlay	DISAPPROVED	
Notes: Inspector SBL changed the inspection assignment from SBL to SPG Need permits for all trades and firewalls. Mechanical, building, insulation, electrical and plumbing. Need licensed contractors listed on permits.						
	12/5/2019	12/5/2019	ROUGH IN	Steven Gazlay	CANCELLED	
Notes: Inspector SBL changed the inspection assignment from SBL to SPG						
	12/9/2019	12/9/2019	ROUGH IN	Slade Burton Lawson III	APPROVED	
Notes:						
	3/24/2020	3/24/2020	FINAL**	Slade Burton Lawson III	DISAPPROVED	
Notes: Disconnect for dishwasher not in per code. See 422 of 2017 NEC						
	3/27/2020	3/27/2020	FINAL**	Slade Burton Lawson III	FAIL W/ PENALTY	
Notes: Flex cord in same bay as d/w no disconnect provided in line of sight						
	4/1/2020	4/1/2020	FINAL**	Slade Burton Lawson III	APPROVED	
Notes:						

