



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

2/20/2020

SUBJECT: ERES2001-0055
ELECTRICAL RESIDENTIAL

To: ALL SEASONS AC & HEATING INC

Here are the results of all Inspections located at **421 BROWN RD:**

Inspection Type: RE-CONNECT
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: RE-CONNECT
Scheduled Date/Time: 2/3/2020
Completed Date/Time: 2/3/2020
Inspector: Scott Guy
Result: DISAPPROVED
Remarks:

Notes: Load calculation sheet required. Locations of load share modules If used. work done in meter base, meter has been set and sealed.





Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: GAS PIPING
Scheduled Date/Time: 2/3/2020
Completed Date/Time: 2/3/2020
Inspector: Scott Guy
Result: DISAPPROVED
Remarks:
Notes: No installed

Inspection Type: FINAL**
Scheduled Date/Time: 2/3/2020
Completed Date/Time: 2/3/2020
Inspector: Scott Guy
Result: DISAPPROVED
Remarks:
Notes: Job not ready