

Date: 6/3/2020

Project Name: Mark Champion

Address: 11454 Highway 210 North

Angier , North Carolina 27501

Please update the tie-in method with the dropdown "Supply-side tap - CO Springs". Make sure the wire tags are also updated to reflect a #8 or larger neutral, and no ground in between the MSP and disconnect.

Please reach out to the team directly if you have any questions.

BRS Design

[design@blueravensolar.com](mailto:design@blueravensolar.com)

(385) 498 – 4020



The Future of Energy. Today.