



Scott E. Wyssling, PE, PP, CME

Wyssling Consulting
76 North Meadowbrook Drive
Alpine, UT 84004
office (201) 874-3483
swyssling@wysslingconsulting.com

August 5, 2020
Revised on September 1, 2020

Jon Kirchner, VP of Technology
Sigora Solar
1222 Harris Street
Charlottesville, VA 22903

Re: Engineering Services
Bradley Residence
308 West E Street, Erwin NC
4.875 kW System Size

Dear Mr. Kirchner:

Pursuant to your request, we have reviewed the following information regarding solar panel installation on the roof of the above referenced home:

1. Site Visit/Verification Form prepared by a Sigora Solar representative identifying specific site information including size and spacing of rafters for the existing roof structure.
2. Design drawings of the proposed system including a site plan, roof plan and connection details for the solar panels. This information was prepared by Sigora Solar and will be utilized for approval and construction of the proposed system.
3. Photographs of the interior and exterior of the roof system identifying existing structural members and their conditions.

Based on the above information we have evaluated the structural capacity of the existing roof system to support the additional loads imposed by the solar panels and have the following comments related to our review and evaluation:

Description of Residence:

The existing residence is typical wood framing construction with the roof system consisting of truss system with all chords constructed of 2 x 4 dimensional lumber at 24" on center. The attic space is unfinished and photos indicate that there was free access to visually inspect the size and condition of the roof rafters. All wood material utilized for the roof system is assumed to be Doug-Fir #2 or better with standard construction components. The existing roofing material consists of composite asphalt shingles. Photos of the dwelling also indicate that there is a permanent foundation.

A. Loading Criteria Used

- 115 MPH wind loading based on ASCE 7-10 Exposure Category "C" at a slope of 21 degrees
- 7 PSF = Dead Load roofing/framing Live Load = 20 PSF Snow Load = 15 PSF
- 3 PSF = Dead Load solar panels/mounting hardware

Total Dead Load = 10 PSF

The above values are within acceptable limits of recognized industry standards for similar structures in accordance with the North Carolina Residential Code (2018). Analysis performed of the existing roof structure utilizing the above loading criteria indicates that the existing rafters will support the additional panel loading without damage, if installed correctly.

B. Solar Panel Anchorage

1. The solar panels shall be mounted in accordance with the most recent “*Everest Installation Manual*”, which can be found on the Everest website (<https://everest-solarsystems.com/>). If during solar panel installation, the roof framing members appear unstable or deflect non-uniformly, our office should be notified before proceeding with the installation.
2. Maximum allowable pullout per lag screw is 235 lbs/inch of penetration as identified in the National Design Standards (NDS) of timber construction specifications for Doug-Fir #2 *assumed*. Based on our evaluation, the pullout value, utilizing a penetration depth of 2 ½”, is less than what is allowable per connection and therefore is adequate. Based on the variable factors for the existing roof framing and installation tolerances, using a thread depth of 2 ½” with a minimum size of 5/16” lag screw per attachment point for panel anchor mounts should be adequate with a sufficient factor of safety.
3. Considering the roof slopes, the size, spacing, condition of roof, the panel supports shall be placed no greater than 48” o/c.
4. Panel supports connections shall be staggered to distribute load to adjacent Trusses.


C. Solar Panel Layout



Based on the above evaluation, it is the opinion of this office that with appropriate panel anchors being utilized the roof system will adequately support the additional loading imposed by the solar panels. This evaluation is in conformance with the North Carolina Residential Code (2018), current industry and standards, and based on information supplied to us at the time of this report.

Should you have any questions regarding the above or if you require further information do not hesitate to contact me.

Very truly yours,


Scott E. Wyssling, PE
North Carolina License No. 46546



PROJECT DESCRIPTION:

15 x TRINA: TSM-325-DD06M.05(II) 325W MONO MODULES
 ROOF MOUNTED SOLAR PHOTOVOLTAIC MODULES


DC SYSTEM SIZE: 4.875kW DC
 AC SYSTEM SIZE: 3.600kW AC

EQUIPMENT SUMMARY

15 TRINA: TSM-325-DD06M.05(II) 325W MONO MODULES
 15 ENPHASE IQ7-60-2-US MICRO INVERTERS

ROOF ARRAY AREA #1:- 274.50 SQ FT.

AUTHORITIES HAVING JURISDICTION
 BUILDING: HARNETT, COUNTY OF (NC)
 ZONING: HARNETT, COUNTY OF (NC)



APPLICABLE CODES & STANDARDS

NCBC 2018
 NEC 2017


DESIGN SPECIFICATION

OCCUPANCY: II
 CONSTRUCTION: SINGLE-FAMILY
 ZONING: RESIDENTIAL
 GROUND SNOW LOAD: REFER STRUCTURAL LETTER
 WIND EXPOSURE: REFER STRUCTURAL LETTER
 WIND SPEED: REFER STRUCTURAL LETTER

1 | PLOT PLAN WITH ROOF PLAN

PV-1


SCALE: 1/16" = 1'-0"



2 | HOUSE PHOTO

PV-1

SCALE: NTS



3 | VICINITY MAP

PV-1

SCALE: NTS

SHEET INDEX

- PV-1 PLOT PLAN WITH ROOF PLAN
- PV-2 ROOF PLAN & MODULES
- PV-2A CIRCUIT LAYOUT
- PV-3 ATTACHMENT DETAIL
- PV-4 ELECTRICAL LINE DIAGRAM
- PV-5 PLACARD
- PV-6 MICRO INVERTER CHART
- PV-7+ EQUIPMENT SPECIFICATIONS

SIGORA SOLAR LLC
 490 WESTFIELD RD STE A
 CHARLOTTEVILLE, VA 22901

| REVISIONS | | |
|-------------|------------|-----|
| DESCRIPTION | DATE | REV |
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

**JEAN BRADLEY
 RESIDENCE**

308 WEST E ST,
 ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME

**PLOT PLAN WITH
 ROOF PLAN**

SHEET SIZE



**ANSI B
 11" X 17"**

SHEET NUMBER

PV-1

MODULE TYPE, DIMENSIONS & WEIGHT

NUMBER OF MODULES = 15 MODULES
 MODULE TYPE = TRINA: TSM-325-DD06M.05(II) 325W MONO MODULES
 MODULE WEIGHT = 40.10 LBS / 18.2KG.
 MODULE DIMENSIONS = 66.9"x 39.4" = 18.30 SF



| ROOF DESCRIPTION | | | | |
|------------------|------------|-------------------|------------|---------------|
| ROOF TYPE | | COMPOSITE SHINGLE | | |
| ROOF LAYER | | 1 LAYER | | |
| ROOF | ROOF PITCH | AZIMUTH | TRUSS SIZE | TRUSS SPACING |
| #1 | 21° | 178° | 2X4 | 24" |

| ARRAY AREA & ROOF AREA CALC'S | | | | |
|-------------------------------|--------------|----------------------|---------------------|--------------------------------|
| ROOF | # OF MODULES | ARRAY AREA (Sq. Ft.) | ROOF AREA (Sq. Ft.) | ROOF AREA COVERED BY ARRAY (%) |
| #1 | 15 | 274.50 | 384.00 | 71 |


SIGORA SOLAR LLC
 490 WESTFIELD RD STE A
 CHARLOTTEVILLE, VA 22901

| REVISIONS | | |
|-------------|------------|-----|
| DESCRIPTION | DATE | REV |
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

JEAN BRADLEY RESIDENCE
 308 WEST E ST,
 ERWIN, NC 28339



LEGEND

- SD - SOLADECK
- INV - INVERTER
- CB - COMBINER BOX
- ACD - AC DISCONNECT
- LC - LOAD CENTER
- UM - UTILITY METER
- MSP - MAIN SERVICE PANEL
- VENT, ATTIC FAN (ROOF OBSTRUCTION)
- - ROOF ATTACHMENT
- - TRUSS
- - CONDUIT

1 ROOF PLAN & MODULES



PV-2 SCALE: 1/16" = 1'-0"

DRAWN BY
ESR

SHEET NAME
ROOF PLAN & MODULES

SHEET SIZE
**ANSI B
 11" X 17"**

SHEET NUMBER
PV-2

| CIRCUIT LEGENDS | |
|---|------------|
|  | CIRCUIT #1 |
|  | CIRCUIT #2 |

| BILL OF MATERIALS | | |
|-------------------|-----|-------------------------------------|
| EQUIPMENT | QTY | DESCRIPTION |
| SOLAR PV MODULES | 15 | TRINA: TSM-325-DD06M.05(II) 325W |
| MICRO INVERTERS | 15 | ENPHASE IQ7-60-2-US MICRO INVERTERS |
| SOLADECK | 1 | SOLADECK |
| MODULE CLAMPS | 24 | MID MODULE CLAMPS |
| END CLAMPS | 12 | END CLAMPS / STOPPER SLEEVE |
| ATTACHMENT | 48 | EVERFLASH XP COMP |
| BOLT | 48 | LAG BOLT |



SIGORA SOLAR LLC
490 WESTFIELD RD STE A
CHARLOTTEVILLE, VA 22901

| REVISIONS | | |
|-------------|------------|-----|
| DESCRIPTION | DATE | REV |
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

**JEAN BRADLEY
RESIDENCE**

308 WEST E ST,
ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME



CIRCUIT LAYOUT

SHEET SIZE

**ANSI B
11" X 17"**

SHEET NUMBER

PV-2A



| REVISIONS | | |
|-------------|------------|-----|
| DESCRIPTION | DATE | REV |
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

**JEAN BRADLEY
RESIDENCE**

308 WEST E ST,
ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME


**ATTACHMENT
DETAIL**

SHEET SIZE


**ANSI B
11" X 17"**

SHEET NUMBER


PV-3




1 END CLAMP DETAILS




2 MID CLAMP DETAILS



FRONT VIEW



3 DETAIL, MOUNTING AND FLASHING



SIDE VIEW

DC SYSTEM SIZE: 4.875 kW DC
AC SYSTEM SIZE: 3.600 kW AC

(15) TRINA: TSM-325-DD06M.05(II) 325W MONO MODULES WITH (15) ENPHASE IQ7-60-2-US MICRO INVERTERS (1) BRANCH CIRCUIT OF 8 MODULE AND (1) BRANCH CIRCUIT OF 7 MODULES CONNECTED IN PARALLEL

INTERCONNECTION NOTES:


1. INTERCONNECTION SIZING, LIMITATIONS AND COMPLIANCE DETERMINED IN ACCORDANCE WITH [NEC 705.12], AND [NEC 690.64].
3. GROUND FAULT PROTECTION IN ACCORDANCE WITH [NEC 215.9], [NEC 230.95] AND [NEC 690.5]
4. ALL EQUIPMENT TO BE RATED FOR BACKFEEDING.
5. PV BREAKER TO BE POSITIONED AT THE OPPOSITE END OF THE BUSBAR RELATIVE TO THE MAIN BREAKER.

DISCONNECT NOTES:

1. DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHEN THE SWITCH IS OPENED THE CONDUCTORS REMAINING LIVE ARE CONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS)
2. AC DISCONNECT MUST BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH

GROUNDING & GENERAL NOTES:

1. A SECOND FACILITY GROUNDING ELECTRODE IS NOT REQUIRED PER [NEC 690.47(C)(3)]
2. PV INVERTER IS UNGROUNDED, TRANSFORMER-LESS TYPE.
3. DC GEC AND AC EGC TO REMAIN UNSPLICED, OR SPLICED TO EXISTING ELECTRODE
4. ANY EXISTING WIRING INVOLVED WITH PV SYSTEM CONNECTION THAT IS FOUND TO BE INADEQUATE PER CODE SHALL BE CORRECTED PRIOR TO FINAL INSPECTION.
5. SOLADECK QUANTITIES, AND PLACEMENT SUBJECT TO CHANGE IN THE FIELD - SOLADECKES DEPICTED ON ELECTRICAL DIAGRAM REPRESENT WIRE TYPE TRANSITIONS.
6. AC DISCONNECT NOTED IN EQUIPMENT SCHEDULE OPTIONAL IF OTHER AC DISCONNECTING MEANS IS LOCATED WITHIN 10' OF SERVICE DISCONNECT
7. RACEWAYS AND CABLES EXPOSED TO SUNLIGHT ON ROOFTOPS SHOULD BE INSTALLED MORE THAN 7/8" ABOVE THE ROOF USING CONDUIT SUPPORTS.



| QTY | CONDUCTOR INFORMATION | | CONDUIT TYPE | CONDUIT SIZE |
|-----|-----------------------|--|--------------------------------|--------------|
| 1 | (4) | #12AWG - ENPHASE ENGAGE CABLE (L1 & L2 NO NUETRAL) | N/A | N/A |
| | (1) | #6AWG - BARE COPPER IN FREE AIR | | |
| 2 | (4) | #10AWG - CU, THWN-2 (L1, L2) | EMT OR LFMC IN ATTIC | 3/4" |
| | (1) | #10AWG - CU, THWN-2 GND | | |
| 3A | (2) | #2AWG - AL USE-2 (L1, L2) | DIRECT BURIAL (24" DEPTH MIN.) | N/A |
| | (1) | #4AWG - AL USE-2 N | | |
| 3 | (1) | #6AWG - AL USE-2 GND | EMT, LFMC OR PVC | 3/4" |
| | (2) | #10AWG - CU, THWN-2 (L1, L2) | | |
| 4 | (1) | #10AWG - CU, THWN-2 N | EMT, LFMC OR PVC | 3/4" |
| | (1) | #10AWG - CU, THWN-2 GND | | |
| 4 | (1) | #10AWG - CU, THWN-2 N | EMT, LFMC OR PVC | 3/4" |
| | (1) | #10AWG - CU, THWN-2 GND | | |

SIGORA SOLAR
SIGORA SOLAR LLC
490 WESTFIELD RD STE A
CHARLOTTEVILLE, VA 22901

REVISIONS

| DESCRIPTION | DATE | REV |
|-------------|------------|-----|
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |


DATE: 08/06/2020

PROJECT NAME & ADDRESS
JEAN BRADLEY RESIDENCE
308 WEST E ST,
ERWIN, NC 28339

DRAWN BY
ESR
SHEET NAME
ELECTRICAL LINE DIAGRAM
SHEET SIZE
ANSI B 11" X 17"
SHEET NUMBER
PV-4



SIGORA SOLAR LLC
490 WESTFIELD RD STE A
CHARLOTTEVILLE, VA 22901




DIRECTORY
PERMANENT PLAQUE OR DIRECTORY PROVIDING THE LOCATION OF THE SERVICE DISCONNECTING MEANS AND THE PHOTOVOLTAIC SYSTEM.

(ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS OUTLINED WITHIN:
NEC 690.56(B)&(C), [NEC 705.10])

LABELING NOTES:

1. LABELS CALLED OUT ACCORDING TO ALL COMMON CONFIGURATIONS. ELECTRICIAN TO DETERMINE EXACT REQUIREMENTS IN THE FIELD PER CURRENT NEC AND LOCAL CODES AND MAKE APPROPRIATE ADJUSTMENTS.
2. LABELING REQUIREMENTS BASED ON THE 2017 NATIONAL ELECTRIC CODE, OSHA STANDARD 19010.145, ANSI Z535.
3. MATERIAL BASED ON THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.
4. LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED [NEC 110.21]
5. LABELS TO BE A MINIMUM LETTER HEIGHT OF 3/8", WHITE ON RED BACKGROUND; REFLECTIVE, AND PERMANENTLY AFFIXED [IFC 605.11.1.1]

LABELING DIAGRAM:



** ELECTRICAL DIAGRAM SHOWN ABOVE IS FOR LABELING PURPOSES ONLY. NOT AN ACTUAL REPRESENTATION OF EQUIPMENT AND CONNECTIONS TO BE INSTALLED. LABEL LOCATIONS PRESENTED MAY VARY DEPENDING ON TYPE OF INTERCONNECTION METHOD AND LOCATION PRESENTED ELECTRICAL DIAGRAM PAGE. **

| REVISIONS | | |
|-------------|------------|-----|
| DESCRIPTION | DATE | REV |
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

**JEAN BRADLEY
RESIDENCE**

308 WEST E ST,
ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME

PLACARD

SHEET SIZE

**ANSI B
11" X 17"**


SHEET NUMBER

PV-5

1-10 11-20 21-30 31-40 41-50 51-60 61-70 71-80 81-90 91-100 101-110 111-120 121-130

| | | | | | | | | | | | | | |
|---|--|--|--|--|--|--|--|--|--|--|--|--|--|
| 1 | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | |

MICRO INVERTER CHART



SIGORA SOLAR LLC
490 WESTFIELD RD STE A
CHARLOTTEVILLE, VA 22901

REVISIONS

| DESCRIPTION | DATE | REV |
|-------------|------------|-----|
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

JEAN BRADLEY
RESIDENCE
308 WEST E ST,
ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME

MICRO INVERTER
CHART

SHEET SIZE

ANSI B
11" X 17"

SHEET NUMBER

PV-6

THE

Residential Module

MULTI-BUSBAR120 HALF-CELL BOB MODULE



120-Cell
MONOCRYSTALLINE MODULE

310-335W
POWER OUTPUT RANGE

19.7%
MAXIMUM EFFICIENCY

0~+5W
POSITIVE POWER TOLERANCE

| PRODUCTS | BACKSHEET COLOR | POWER RANGE |
|------------------|-----------------|-------------|
| TSM-DD06M.05(II) | Black | 310-335W |

FRAME COLOR: Black



High power output

- Reduce BOS cost with high power bin and module efficiency
- New cell string layout and split J-box location reduces the energy loss caused by inter-row shading
- Lower resistance of half-cut cells and increased MBB (Multi Busbar) reflectance ensure higher power



High energy generation, low LCOE

- Excellent 3rd party validated IAM and low light performance with cell process and module material optimization
- Low Pmax temp coefficient (-0.36%) increases energy production
- Better anti-shading performance and lower operating temperature



Outstanding visual appearance, easy to install

- Designed for superior rooftop aesthetics
- Thinner wires give a eye catching all black look
- Safe and easy to transport, handle, and install



Certified to perform in highly challenging environments

- High PID resistance through cell process and module material control
- Resistant to salt, acid, sand, and ammonia
- Over 30 in-house tests (UV, TC, HF etc)
- Certified to 5400 Pa positive load and 2400 Pa negative load

Founded in 1997, Trina Solar is the world's leading total solution provider for solar energy. With local presence around the globe, Trina Solar is able to provide exceptional service to each customer in each market and deliver our innovative, reliable products with the backing of Trina as a strong, bankable brand. Trina Solar now distributes its PV products to over 100 countries all over the world. We are committed to building strategic, mutually beneficial collaborations with installers, developers, distributors and other partners in driving smart energy together.


Comprehensive Products and System Certificates

IEC61215/IEC61730/IEC61701/IEC62716
 ISO 9001: Quality Management System
 ISO 14001: Environmental Management System
 ISO14064: Greenhouse Gases Emissions Veriycation
 OHSAS 18001: Occupation Health and Safety Management System






PERFORMANCE WARRANTY

10 Year Product Warranty · 25 Year Power Warranty




From the 2nd year to the 25th year, the average annual power decline will be no more than 0.6%.


DIMENSIONS OF PV MODULE(mm)



I-V CURVES OF PV MODULE (335W)



P-V CURVES OF PV MODULE (335W)



ELECTRICAL DATA (STC)

| Peak Power Watts- P_{MAX} (Wp)* | 310 | 315 | 320 | 325 | 330 | 335 |
|---------------------------------------|--------|-------|-------|-------|-------|-------|
| Power Output Tolerance- P_{MAX} (W) | 0 ~ +5 | | | | | |
| Maximum Power Voltage- V_{MPP} (V) | 33.0 | 33.2 | 33.4 | 33.6 | 33.8 | 34.0 |
| Maximum Power Current- I_{MPP} (A) | 9.40 | 9.49 | 9.58 | 9.67 | 9.76 | 9.85 |
| Open Circuit Voltage- V_{OC} (V) | 39.9 | 40.1 | 40.3 | 40.4 | 40.6 | 40.7 |
| Short Circuit Current- I_{SC} (A) | 10.03 | 10.12 | 10.20 | 10.30 | 10.40 | 10.50 |
| Module Efficiency η m(%) | 18.2 | 18.5 | 18.8 | 19.1 | 19.4 | 19.7 |

STC: Irradiance 1000W/m², Cell Temperature 25°C, Air Mass AM1.5.
*Measuring tolerance: $\pm 3\%$.

ELECTRICAL DATA (NMOT)

| Maximum Power- P_{MAX} (Wp) | 235 | 238 | 242 | 246 | 250 | 254 |
|--------------------------------------|------|------|------|------|------|------|
| Maximum Power Voltage- V_{MPP} (V) | 31.0 | 31.2 | 31.4 | 31.6 | 31.7 | 31.9 |
| Maximum Power Current- I_{MPP} (A) | 7.57 | 7.64 | 7.71 | 7.79 | 7.86 | 7.94 |
| Open Circuit Voltage- V_{OC} (V) | 37.6 | 37.8 | 38.0 | 38.1 | 38.3 | 38.4 |
| Short Circuit Current- I_{SC} (A) | 8.08 | 8.15 | 8.22 | 8.30 | 8.38 | 8.46 |

NMOT: Irradiance at 800W/m², Ambient Temperature 20°C, Wind Speed 1m/s.

MECHANICAL DATA

| | |
|----------------------|--|
| Solar Cells | Monocrystalline |
| Cell Orientation | 120 cells (6 × 20) |
| Module Dimensions | 1698 × 1004 × 35 mm (66.85 × 39.53 × 1.38 inches) |
| Weight | 18.7kg (41.2lb) |
| Glass | 3.2mm (0.13 inches), High Transmission, AR Coated Tempered Glass |
| Encapsulant Material | EVA |
| Backsheet | Black |
| Frame | 35 mm (1.38 inches) Anodized Aluminium Alloy |
| J-Box | IP 68 rated |
| Cables | Photovoltaic Technology Cable 4.0mm ² (0.006 inches ²) Portrait: N 140mm/P 285mm (5.51/11.22 inches) Landscape: N 1200 mm /P 1200 mm (47.24/47.24 inches) |
| Connector | MC4 |

TEMPERATURE RATINGS

| | |
|--|--------------------------------|
| NMOT(Nominal Module Operating Temperature) | 41°C ($\pm 3^\circ\text{C}$) |
| Temperature Coefficient of P_{MAX} | -0.36%/°C |
| Temperature Coefficient of V_{OC} | -0.26%/°C |
| Temperature Coefficient of I_{SC} | 0.04%/°C |

(Do not connect Fuse in Combiner Box with two or more strings in parallel connection)

MAXIMUM RATINGS

| | |
|-------------------------|---------------------------------|
| Operational Temperature | -40~+85°C |
| Maximum System Voltage | 1000V DC (IEC) 1000V DC (UL) |
| Max Series Fuse Rating | 20A |

WARRANTY

- 10 year Product Workmanship Warranty
- 25 year Power Warranty

(Please refer to product warranty for details)

PACKAGING CONFIGURATION

- Modules per box: 30 pieces
- Modules per 40' container: 780 pieces

Enphase IQ 7 and IQ 7+ Microinverters

The high-powered smart grid-ready **Enphase IQ 7 Micro™** and **Enphase IQ 7+ Micro™** dramatically simplify the installation process while achieving the highest system efficiency.

Part of the Enphase IQ System, the IQ 7 and IQ 7+ Microinverters integrate with the Enphase IQ Envoy™, Enphase IQ Battery™, and the Enphase Enlighten™ monitoring and analysis software.

IQ Series Microinverters extend the reliability standards set forth by previous generations and undergo over a million hours of power-on testing, enabling Enphase to provide an industry-leading warranty of up to 25 years.

Easy to Install

- Lightweight and simple
- Faster installation with improved, lighter two-wire cabling
- Built-in rapid shutdown compliant (NEC 2014 & 2017)

Productive and Reliable

- Optimized for high powered 60-cell and 72-cell* modules
- More than a million hours of testing
- Class II double-insulated enclosure
- UL listed

Smart Grid Ready

- Complies with advanced grid support, voltage and frequency ride-through requirements
- Remotely updates to respond to changing grid requirements
- Configurable for varying grid profiles
- Meets CA Rule 21 (UL 1741-SA)

*The IQ 7+ Micro is required to support 72-cell modules.



To learn more about Enphase offerings, visit enphase.com



Enphase IQ 7 and IQ 7+ Microinverters

| INPUT DATA (DC) | IQ7-60-2-US | | IQ7PLUS-72-2-US | |
|--|--|----------------------|--------------------------------|----------------------|
| Commonly used module pairings ¹ | 235 W - 350 W + | | 235 W - 440 W + | |
| Module compatibility | 60-cell PV modules only | | 60-cell and 72-cell PV modules | |
| Maximum input DC voltage | 48 V | | 60 V | |
| Peak power tracking voltage | 27 V - 37 V | | 27 V - 45 V | |
| Operating range | 16 V - 48 V | | 16 V - 60 V | |
| Min/Max start voltage | 22 V / 48 V | | 22 V / 60 V | |
| Max DC short circuit current (module Isc) | 15 A | | 15 A | |
| Overvoltage class DC port | II | | II | |
| DC port backfeed current | 0 A | | 0 A | |
| PV array configuration | 1 x 1 ungrounded array; No additional DC side protection required; AC side protection requires max 20A per branch circuit | | | |
| OUTPUT DATA (AC) | IQ 7 Microinverter | | IQ 7+ Microinverter | |
| Peak output power | 250 VA | | 295 VA | |
| Maximum continuous output power | 240 VA | | 290 VA | |
| Nominal (L-L) voltage/range ² | 240 V / 211-264 V | 208 V / 183-229 V | 240 V / 211-264 V | 208 V / 183-229 V |
| Maximum continuous output current | 1.0 A (240 V) | 1.15 A (208 V) | 1.21 A (240 V) | 1.39 A (208 V) |
| Nominal frequency | 60 Hz | | 60 Hz | |
| Extended frequency range | 47 - 68 Hz | | 47 - 68 Hz | |
| AC short circuit fault current over 3 cycles | 5.8 Arms | | 5.8 Arms | |
| Maximum units per 20 A (L-L) branch circuit ³ | 16 (240 VAC) | 13 (208 VAC) | 13 (240 VAC) | 11 (208 VAC) |
| Overvoltage class AC port | III | | III | |
| AC port backfeed current | 0 A | | 0 A | |
| Power factor setting | 1.0 | | 1.0 | |
| Power factor (adjustable) | 0.85 leading ... 0.85 lagging | | 0.85 leading ... 0.85 lagging | |
| EFFICIENCY | @240 V | @208 V | @240 V | @208 V |
| Peak efficiency | 97.6 % | 97.6 % | 97.5 % | 97.3 % |
| CEC weighted efficiency | 97.0 % | 97.0 % | 97.0 % | 97.0 % |
| MECHANICAL DATA | | | | |
| Ambient temperature range | -40°C to +65°C | | | |
| Relative humidity range | 4% to 100% (condensing) | | | |
| Connector type (IQ7-60-2-US & IQ7PLUS-72-2-US) | MC4 (or Amphenol H4 UTX with additional Q-DCC-5 adapter) | | | |
| Dimensions (WxHxD) | 212 mm x 175 mm x 30.2 mm (without bracket) | | | |
| Weight | 1.08 kg (2.38 lbs) | | | |
| Cooling | Natural convection - No fans | | | |
| Approved for wet locations | Yes | | | |
| Pollution degree | PD3 | | | |
| Enclosure | Class II double-insulated, corrosion resistant polymeric enclosure | | | |
| Environmental category / UV exposure rating | NEMA Type 6 / outdoor | | | |
| FEATURES | | | | |
| Communication | Power Line Communication (PLC) | | | |
| Monitoring | Enlighten Manager and MyEnlighten monitoring options. Both options require installation of an Enphase IQ Envoy. | | | |
| Disconnecting means | The AC and DC connectors have been evaluated and approved by UL for use as the load-break disconnect required by NEC 690. | | | |
| Compliance | CA Rule 21 (UL 1741-SA) UL 62109-1, UL1741/IEEE1547, FCC Part 15 Class B, ICES-0003 Class B, CAN/CSA-C22.2 NO. 107.1-01 This product is UL Listed as PV Rapid Shut Down Equipment and conforms with NEC-2014 and NEC-2017 section 690.12 and C22.1-2015 Rule 64-218 Rapid Shutdown of PV Systems, for AC and DC conductors, when installed according manufacturer's instructions. | | | |

1. No enforced DC/AC ratio. See the compatibility calculator at <https://enphase.com/en-us/support/module-compatibility>
 2. Nominal voltage range can be extended beyond nominal if required by the utility.
 3. Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.

To learn more about Enphase offerings, visit enphase.com

© 2019 Enphase Energy. All rights reserved. All trademarks or brands used are the property of Enphase Energy, Inc.
 2019-3-26



SIGORA SOLAR LLC
 490 WESTFIELD RD STE A
 CHARLOTTEVILLE, VA 22901

REVISIONS

| DESCRIPTION | DATE | REV |
|-------------|------------|-----|
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

JEAN BRADLEY
 RESIDENCE
 308 WEST E ST,
 ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME
**EQUIPMENT
 SPECIFICATION**

SHEET SIZE

ANSI B
 11" X 17"

SHEET NUMBER

PV-8

Enphase IQ Combiner 3 (X-IQ-AM1-240-3)

The **Enphase IQ Combiner 3™** with Enphase IQ Envoy™ consolidates interconnection equipment into a single enclosure and streamlines PV and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.



Smart

- Includes IQ Envoy for communication and control
- Flexible networking supports Wi-Fi, Ethernet, or cellular
- Optional AC receptacle available for PLC bridge
- Provides production metering and optional consumption monitoring

Simple

- Reduced size from previous combiner
- Centered mounting brackets support single stud mounting
- Supports back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- 80 A total PV or storage branch circuits

Reliable

- Durable NRTL-certified NEMA type 3R enclosure
- Five-year warranty
- UL listed



To learn more about Enphase offerings, visit enphase.com



Enphase IQ Combiner 3

MODEL NUMBER

| | |
|------------------------------|--|
| IQ Combiner 3 X-IQ-AM1-240-3 | IQ Combiner 3 with Enphase IQ Envoy™ printed circuit board for integrated revenue grade PV production metering (ANSI C12.20 +/- 0.5%) and optional* consumption monitoring (+/- 2.5%). |
|------------------------------|--|

ACCESSORIES and REPLACEMENT PARTS (not included, order separately)

| | |
|--|---|
| Enphase Mobile Connect™ CELLMODEM-03 (4G / 12-year data plan) CELLMODEM-01 (3G / 5-year data plan) CELLMODEM-M1 (4G based LTE-M / 5-year data plan) | Plug and play industrial grade cellular modem with data plan for systems up to 60 microinverters. (Available in the US, Canada, Mexico, Puerto Rico, and the US Virgin Islands, where there is adequate cellular service in the installation area.) |
| Consumption Monitoring* CT CT-200-SPLIT | Split core current transformers enable whole home consumption metering (+/- 2.5%). |
| Circuit Breakers BRK-10A-2-240 BRK-15A-2-240 BRK-20A-2P-240 | Supports Eaton BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers. Circuit breaker, 2 pole, 10A, Eaton BR210 Circuit breaker, 2 pole, 15A, Eaton BR215 Circuit breaker, 2 pole, 20A, Eaton BR220 |
| EPLC-01 | Power line carrier (communication bridge pair), quantity 2 |
| XA-PLUG-120-3 | Accessory receptacle for Power Line Carrier in IQ Combiner 3 (required for EPLC-01) |
| XA-ENV-PCBA-3 | Replacement IQ Envoy printed circuit board (PCB) for Combiner 3 |

ELECTRICAL SPECIFICATIONS

| | |
|--|--|
| Rating | Continuous duty |
| System voltage | 120/240 VAC, 60 Hz |
| Eaton BR series busbar rating | 125 A |
| Max. continuous current rating (output to grid) | 65 A |
| Max. fuse/circuit rating (output) | 90 A |
| Branch circuits (solar and/or storage) | Up to four 2-pole Eaton BR series Distributed Generation (DG) breakers only (not included) |
| Max. continuous current rating (input from PV) | 64 A |
| Max. total branch circuit breaker rating (input) | 80A of distributed generation / 90A with IQ Envoy breaker included |
| Production Metering CT | 200 A solid core pre-installed and wired to IQ Envoy |

MECHANICAL DATA

| | |
|--------------------------------|---|
| Dimensions (WxHxD) | 49.5 x 37.5 x 16.8 cm (19.5" x 14.75" x 6.63"). Height is 21.06" (53.5 cm with mounting brackets). |
| Weight | 7.5 kg (16.5 lbs) |
| Ambient temperature range | -40° C to +46° C (-40° to 115° F) |
| Cooling | Natural convection, plus heat shield |
| Enclosure environmental rating | Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction |
| Wire sizes | <ul style="list-style-type: none"> • 20 A to 50 A breaker inputs: 14 to 4 AWG copper conductors • 60 A breaker branch input: 4 to 1/0 AWG copper conductors • Main lug combined output: 10 to 2/0 AWG copper conductors • Neutral and ground: 14 to 1/0 copper conductors Always follow local code requirements for conductor sizing. |
| Altitude | To 2000 meters (6,560 feet) |

INTERNET CONNECTION OPTIONS

| | |
|------------------|--|
| Integrated Wi-Fi | 802.11b/g/n |
| Ethernet | Optional, 802.3, Cat5E (or Cat 6) UTP Ethernet cable (not included) |
| Cellular | Optional, CELLMODEM-01 (3G) or CELLMODEM-03 (4G) or CELLMODEM-M1 (4G based LTE-M) (not included) |

COMPLIANCE

| | |
|----------------------|---|
| Compliance, Combiner | UL 1741 CAN/CSA C22.2 No. 107.1 47 CFR, Part 15, Class B, ICES 003 Production metering: ANSI C12.20 accuracy class 0.5 (PV production) |
| Compliance, IQ Envoy | UL 60601-1/CANCSA 22.2 No. 61010-1 |

* Consumption monitoring is required for Enphase Storage Systems.

To learn more about Enphase offerings, visit enphase.com

© 2018 Enphase Energy. All rights reserved. All trademarks or brands in this document are registered by their respective owner.
2018-09-13



SIGORA SOLAR LLC
490 WESTFIELD RD STE A
CHARLOTTEVILLE, VA 22901

REVISIONS

| DESCRIPTION | DATE | REV |
|-------------|------------|-----|
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

JEAN BRADLEY
RESIDENCE
308 WEST E ST,
ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME

EQUIPMENT
SPECIFICATION

SHEET SIZE


ANSI B
11" X 17"

SHEET NUMBER

PV-9



CrossRail System



| Item No. | Description | Part No. |
|----------|--|---------------------------|
| 1 | EverFlash XP Comp Kit, Mill or Dark | 4000060, 4000061, 4000057 |
| 2 | Lag Bolt D145/16 x 4" SS | 4000359 |
| 3 | L-Foot XP Set, Mill or Dark | 4000036, 4000038 |
| 4 | CrossRail 80 168" Rail, Mill | 4000508 |
| 5 | CrossRail 80 End Cap, Black | 4001221 |
| 6 | CrossRail 48-XL 166", Mill or Dark | 4000695, 4000705 |
| 7 | CrossRail 48-X/48-XL End Cap or Flat End Cap | 4000433, 4000431 |
| 8 | CrossRail 48-X 166" or 180", Mill or Dark | 4000662, 4000675, 4000663 |
| 9 | CrossRail 48-X/48-XL 3" Sleeve | 4000583 |
| 10 | CrossRail 44-X 166", Mill or Dark | 4000019, 4000020 |
| 11 | CrossRail 44-X End Cap | 4000067 |
| 12 | CR Mid Clamp Silver or Dark | 4000601-H, 4000602-H |
| 13 | CR End Clamp Silver or Dark | 4000429, 4000430 |
| 14 | Yeti Clamp (Hidden End Clamp) | 40000050-H |

www.everest-solarsystems.com

CrossRail 44-X




Mechanical Properties

| | CrossRail 44-X |
|---------------------------|--------------------------|
| Material | 6000 Series Aluminum |
| Ultimate Tensile Strength | 37.7 ksi (260 MPa) |
| Yield Strength | 34.8 ksi (240 MPa) |
| Weight | 0.47 lbs/ft (0.699 kg/m) |
| Finish | Mill or Dark Anodized |

Section Properties

| | CrossRail 44-X |
|---------------|--|
| Sx | 0.1490 in ³ (0.3785 cm ³) |
| Sy | 0.1450 in ³ (0.3683 cm ³) |
| A (X-Section) | 0.4050 in ² (1.0287 cm ²) |



Dimensions in [mm] Inches

Notes:

- Structural values and span charts determined in accordance with Aluminum Design Manual and ASCE 7-16
- UL2703 Listed System for Fire and Bonding

www.everest-solarsystems.com



SIGORA SOLAR LLC
490 WESTFIELD RD STE A
CHARLOTTEVILLE, VA 22901

REVISIONS

| DESCRIPTION | DATE | REV |
|-------------|------------|-----|
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

JEAN BRADLEY
RESIDENCE
308 WEST E ST,
ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME

EQUIPMENT
SPECIFICATION

SHEET SIZE

ANSI B
11" X 17"

SHEET NUMBER

PV-10




EverFlash XP Comp



| Part Number | Description |
|-------------|---------------------------------------|
| 4000057 | EverFlash XP Kit, Mill LF, Dark Flash |
| 4000060 | EverFlash XP Comp Kit, Dark |
| 4000061 | EverFlash XP Comp Kit, Mill |

- ▶ Everest's very own comp shingle flashing and mount!
- ▶ Best in class - 3 stages of waterproofing
- ▶ All CrossRail hardware included and preassembled
- ▶ UL 441 Section 27 Rain test
- ▶ TAS 100-95 Wind driven rain test



SIGORA SOLAR LLC
490 WESTFIELD RD STE A
CHARLOTTEVILLE, VA 22901

REVISIONS

| DESCRIPTION | DATE | REV |
|-------------|------------|-----|
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

**JEAN BRADLEY
RESIDENCE**

308 WEST E ST,
ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME

**EQUIPMENT
SPECIFICATION**

SHEET SIZE

**ANSI B
11" X 17"**

SHEET NUMBER

PV-11

www.everest-solarsystems.com

EverFlash XP Comp Product Sheet US02 | 1019 · Subject to change · Product illustrations are exemplary and may differ from the original.

SolaDeck

FLASHED PV ROOF-MOUNT COMBINER/ENCLOSURE



SolaDeck Model SD 0783

Basic Features

- Stamped Seamless Construction
- 18 Gauge Galvanized Steel
- Powder Coated Surfaces
- Flashes into the roof deck
- 3 Roof deck knockouts .5", .75", 1"
- 5 Centering dimples for entry/exit fittings or conduit
- 2 Position Ground lug installed
- Mounting Hardware Included



SolaDeck UL50 Type 3R Enclosures

- Available Models:
- Model SD 0783 - (3" fixed Din Rail)
 - Model SD 0786 - (6" slotted Din Rail)



SolaDeck UL 1741 Combiner/Enclosures

Models SD 0783-41 and SD 0786-41 are labeled and ETL listed UL STD 1741 according to the UL STD 1741 for photovoltaic combiner enclosures.
Max Rated - 600VDC, 120AMPS

Model SD 0783-41 3" Fixed Din Rail fastened using Norlock System

- **Typical System Configuration**
- 4- Din Rail Mounted Fuse Holders 600VDC 30 AMP
 - 1- Power Distribution Block 600VDC 175AMP
 - 1- Bus Bar with UL lug

Model SD 0786-41 6" Slotted Din Rail fastened using steel studs

- **Typical System Configuration**
- 4- Din Rail Mounted Fuse Holders 600VDC 30 AMP
 - 4- Din Rail Mounted Terminal Blocks
 - Bus Bars with UL lug

**Fuse holders and terminal blocks added in the field must be UL listed or recognized and meet 600 VDC 30 AMP 110C for fuse holders, 600V 50 AMP 90C for rail mounted terminal blocks and 600 V 175 AMP 90C for Power Distribution Blocks. Use Copper Wire Conductors.



Cover is trimmed to allow conduit or fittings, base is center dimpled for fitting locations.



Model SD 0783-41, wired with Din Rail mounted fuse holders, bus bar and power distribution block.



Model SD 0786-41, wired with Din Rail mounted fuse holders, terminal blocks and bus bars.

GENERAL GUIDELINES

- Always refer to roofing manufacturer's instructions prior to starting work.
- Refer to the American Wood Council's guidelines for Lag pull-out capacities (NDS 2005, Table 11.2A).
- Everest Solar recommends consulting a professional roofer prior to beginning work.
- Installer is responsible for verifying the structural integrity of the roof prior to installation.


ASSEMBLY: STEP BY STEP



1 of 5

Locate the rafters and snap horizontal and vertical lines to mark the installation position for each EverFlash flashing.

Materials required: Tape measure, string line



2 of 5

Drill a pilot hole (1/4" diameter) for the lag bolt. Remove any saw dust and fill the hole with the roofing manufacturer's recommended sealant.


Materials required: Drill



3 of 5

Insert the flashing so the top part is under the next row of shingles and pushed far enough up slope to prevent water infiltration through vertical joint in shingles. The leading edge of flashing must butt against upper row of nails to prevent turning when torqued.

Materials required: EverFlash flashing




4 of 5

Line up pilot hole with EverFlash flashing hole. Insert the lag bolt through the EPDM bonded washer, the L-Foot, the gasketed hole in the flashing and into the rafter.



5 of 5

Torque: The range is between 8.3 - 11.6 lb-ft depending on the type of wood and time of year. The visual indicator for proper torque is when the EPDM on the underside of the bonded washer begins to push out the sides as the washer compresses. If using an impact wrench to install the fasteners be careful not to over torque the fastener. You may need to stop and use a ratchet to finish the install.



Ready!

Install Everest Mounting System (refer to CrossRail 48/80 installation manual)

The EverFlash is simple and fast to install. Please contact us for further assistance:

SERVICE-HOTLINE + 1 760.301.5300

Everest Solar Systems, LLC
3809 Ocean Ranch Blvd., Suite 111
Oceanside, CA 92056
Service-Hotline +1.760.301.5300
info@everest-solarsystems.com
www.everest-solarsystems.com

EverFlash Technical Flyer | L51 0015
Product images are for illustrative purposes only. Specifications are subject to change without notice. All products are UL listed. © 2015 Everest Solar Systems, LLC. All rights reserved.



SIGORA SOLAR LLC
490 WESTFIELD RD STE A
CHARLOTTEVILLE, VA 22901

REVISIONS

| DESCRIPTION | DATE | REV |
|-------------|------------|-----|
| INITIAL | 08/06/2020 | |
| | | |
| | | |
| | | |
| | | |
| | | |

DATE:08/06/2020

PROJECT NAME & ADDRESS

JEAN BRADLEY
RESIDENCE
308 WEST E ST,
ERWIN, NC 28339

DRAWN BY

ESR

SHEET NAME

EQUIPMENT
SPECIFICATION

SHEET SIZE

ANSI B
11" X 17"

SHEET NUMBER

PV-12

RSTC Enterprises, Inc • 2219 Heimstead Road • Eau Claire, WI 54703
For product information call 1(866) 367-7782