



Dixie-Denning Supply Co.



705 South Wall Street

Benson, NC 27504

Ph. 919-894-3824

Fax 919-894-2871

TOP: Request for Inspection

Date: 10/7/2020

Harnett County Inspections Department

We have run a pressure test at **347 Chic Ennis Rd Coats NC**
The pressure held at **50PSI** for approximately 20 MINS.

Dixie Denning supplied carbon monoxide detector .
Customer already had a carbon monoxide detector X .

Sincerely,

Mike Denning
License # 21095

Permit # ERES-2009-0049