GENERAL NOTES

CODES AND STANDARDS

1. ALL WORK SHALL COMPLY WITH 2017 NATIONAL ELECTRIC CODE (NEC), 2018 NORTH CAROLINA BUILDING CODE (NCBC), 2018 NORTH CAROLINA RESIDENTIAL CODE (NCRC), PLUMBING CODE (NCPC), AND ALL STATE AND LOCAL BUILDING, ELECTRICAL, AND PLUMBING CODES

2. DRAWINGS HAVE BEEN DETAILED ACCORDING TO UL LISTING REQUIREMENTS.

SITE NOTES / OSHA REGULATION

1. A LADDER SHALL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS. 2. THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM WITH NO STORAGE BATTERIES

3. THE SOLAR PV INSTALLATION SHALL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS.

4. ROOF COVERINGS SHALL BE DESIGNED, INSTALLED, AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SHALL SERVE TO PROTECT THE BUILDING OR STRUCTURE.

SOLAR CONTRACTOR

1. MODULE CERTIFICATIONS WILL INCLUDE UL1703, IEC61646, IEC61730.

2. IF APPLICABLE, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE MARKED GROUNDING LUG HOLES PER THE MANUFACTURERS' INSTALLATION REQUIREMENTS.

3. AS INDICATED BY DESIGN, OTHER NRTL LISTED MODULE GROUNDING DEVICES MAY BE USED IN PLACE OF STANDARD GROUNDING LUGS AS SHOWN IN MANUFACTURER DOCUMENTATION AND APPROVED BY THE AH.I

4. CONDUIT AND WIRE SPECIFICATIONS ARE BASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT UP-SIZING AS REQUIRED BY FIELD CONDITIONS.

5. CONDUIT POINT OF PENETRATION FROM EXTERIOR TO INTERIOR TO BE INSTALLED AND SEALED WITH A SUITABLE SEALING COMPOUND.

6. DC WIRING LIMITED TO MODULE FOOTPRINT W/ ENPHASE AC SYSTEM.

7. ENPHASE WIRING SYSTEMS SHALL BE LOCATED AND SECURED UNDER THE ARRAY W/ SUITABLE WIRING CLIPS.

8. MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC UNLESS NOT AVAILABLE.

9. ALL INVERTERS, MOTOR GENERATORS, PHOTOVOLTAIC MODULES, PHOTOVOLTAIC PANELS, AC PHOTOVOLTAIC MODULES, DC COMBINERS, DC-TO-DC CONVERTERS, SOURCE CIRCUIT COMBINERS, AND CHARGE CONTROLLERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER 690.4 (B).

10. ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE

11. TERMINALS AND LUGS WILL BE TIGHTENED TO MANUFACTURER TORQUE SPECIFICATIONS (WHEN PROVIDED) IN ACCORDANCE WITH NEC CODE 110.14(D) ON ALL ELECTRICAL CONNECTIONS.

EQUIPMENT LOCATIONS


1. PROPER ACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PER SECTION INEC 110.261.

2. EQUIPMENT INSTALLED IN DIRECT SUNLIGHT MUST BE RATED FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY [NEC 690.31 (A)] AND [NEC TABLE 310.15 (B)].

3. ADDITIONAL AC DISCONNECTS SHALL BE PROVIDED WHERE THE INVERTER IS NOT ADJACENT TO THE UTILITY AC DISCONNECT, OR NOT WITHIN SIGHT OF THE UTILITY AC DISCONNECT.

4. ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES.

5. ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE



DESIGN CRITERIA WIND SPEED: 115 MPH **GROUND SNOW LOAD: 15 PSF** WIND EXPOSURE FACTOR: C SEISMIC DESIGN CATEGORY: B

SITE SPECIFICATIONS CONSTRUCTION - V-B ZONING: RESIDENTIAL

SHEET INDEX **PV1 - COVER SHEET PV2 - PROPERTY PLAN** PV3 - SITE PLAN (IF NEEDED) **PV8 - LABELS & LOCATIONS**

SCOPE OF WORK

AERIAL VIEW


INSTALLATION OF UTILITY INTERACTIVE PHOTOVOLTAIC SOLAR SYSTEM

11.05 kW DC PHOTOVOLTAIC SOLAR ARRAY **ROOF TYPE: Comp Shingle** MODULES: (34) REC Solar REC325TP3M INVERTER(S): Enphase IQ7-60-2-US,----**RACKING: Unirac SFM Infinity**




PERMIT ISSUER: Harnett County

PV1





1		
LEGEND		
INV INVERTER & DC DISCONNECT	BLUE	RAVEN
SUB (E) SUBPANEL	DEVE	SOLAR
LC (N) LOAD CENTER	1403 N RESEARCH	H WAY, BUILDING J
AC AC DISCONNECT	- ,	UT 84097
		77-4480 VENSOLAR.COM
MSP MAIN SERVICE PANEL	HEREIN CONTAIN	THE INFORMATION
	ANYONE	IE BENEFIT OF E EXCEPT AR NOR SHALL IT
TS TRANSFER SWITCH	BE DISCLOSED PART TO OTH	IN WHOLE OR IN IERS OUTSIDE
C COMBINER BOX/AGGREGATOR	EXCEPT IN CONN	ORGANIZATION, EC TION WITH THE THE RESPECTIVE
(PV) PV REVENUE METER	EQUIPMENT, WRITTEN PE	WITHOUT THE RMISSION OF
FIRE SETBACK	BLUERAVEN	NSOLAR LLC.
EMT CONDUIT RUN (TO BE DETERMINED IN FIELD)	NAB	CEP
PV WIRE STRING	-	ALLATION
PROPERTY LINE	Scott	SSIONAL ^{Gurney} 719-015866
SCALE: 3/64" = 1'-0"		ACTOR:
0' 21' 42' 64' 128'		ELD OPS 98.6700
	<u>SITE INFORMATION:</u> Jim Mossop 251 Piney Grove Rawls Rd	Fuquay Varina, North Carolina 27526
	DRAWING BY	or Sink
	DATE	ber 7, 2020
	PROJECT NUMBER	8698
	SHEET NAME PROPER	TY PLAN
	PAGE NUMBER	REVISION






Digitally signed by John Calvert Date: 2020.09.09 08:32:36 -06'00'







34 INVERTERS x 240 W AC = 8.16 kW AC PANEL WATTAGE = 325 W DC



INTERCONNECTION NOTES

1. ONE OF THE METHODS THAT FOLLOWS SHALL BE USED TO DETERMINE THE RATINGS OF BUSBARS AND PANELBOARDS. (a) THE SUM OF 125 PERCENT OF THE INVERTER(S) OUTPUT CIRCUIT CURRENT AND THE RATING OF THE OVERCURRENT DEVICE PROTECTING THE BUSBAR SHALL NOT EXCEED THE AMPACITY OF THE BUS BAR. (b) WHERE TWO SOURCES, ONE THE UTILITY AND THE OTHER AN INVERTER ARE LOCATED AT OPPOSITE ENDS OF A BUSBAR THAT CONTAINS LOADS, THE SUM OF 125 PERCENT OF THE INVERTER(S) OUTPUT CIRCUIT CURRENT AND THE RATING OF THE OVERCURRENT DEVICE PROTECTING THE BUSBAR SHALL NOT EXCEED 120 PERCENT OF THE AMPACITY OF THE BUSBAR [NEC 705.12].



Utility Company: Duke Energy NC Per

(34) Er

rc-er, Thhn/Thwn-2, CU. WG BARE, CU (EGC)	MAX	15.0 A AC 240 V AC		
		EXTERIOR	BLUE	RAVEN
				CH WAY, BUILDING J , UT 84097
				377-4480 AVENSOLAR.COM
(34) REC Solar REC325TP3 UL 1703 COMPLIANT Enphase IQ7-60-2-US MICRO IN UL 1741 COMPLIANT MODULES MAX FOR ALL SUB- UIT(S) TO COMPLY WITH VRIS	VERTERS BRANCH		HEREIN CONTAI USED FOR T ANYON BLUERAVENSO BE DISCLOSEL PART TO OT RECIPIENTS EXCEPT IN CONI SALE AND USE C EQUIPMENT WRITTEN P BLUERAVE	THE INFORMATION NED SHALL NOT BE HE BENEFIT OF HE EXCEPT LAR NOR SHALL IT DIN WHOLE OR IN HERS OUTSIDE ORGANIZATION, NECTION WITH THE OF THE RESPECTIVE , WITHOUT THE ERMISSION OF ENSOLAR LLC.
(1) CIRCUIT OF 10 MODULES			scot # PV-01 CONTI BRS FI	SSIONAL tt Gurney 1719-015866 RACTOR: ELD OPS -98.6700
(1) CIRCUIT OF 9 MODULES				h Carolina 27526 11.05 kW DC
			SITE INFORMATION: Jim Mossop 251 Dinav Grove Rawle Rd	Fuquay Varina, North Caroli DC SYSTEM SIZE: 11.05 k
				or Sink
			DATE	nber 7, 2020
			PROJECT NUMBER	48698
				LINE DIAG.
ermit Issuer:Harnett Co	ounty		PAGE NUMBER	REVISION

MODULE SPECIFICATIONS REC	Solar REC325TP3M	DESIGN LOCATION AND TEMPERATURES							CONDUCTOR SIZE CALCULATIONS
RATED POWER (STC)	325 W	TEMPERATURE DATA SOURCE			ASH	HRAE 2%	AVG. HIG	HTEMP	
MODULE VOC	39.5 V DC	STATE			1.000			Carolina	
MODULEVMP	34.1 V DC	CITY						Varina	
MODULE IMP	9.54 A DC	WEATHER STATION				SEYMOL	JR-JOHNS	and the second	
MODULE ISC	10.36 A DC	ASHRAE EXTREME LOW TEMP (°C)				Schnot		-10	· · · · · · · · · · · · · · · · · · ·
VOC CORRECTION	-0.28 %/°C	ASHRAE 2% AVG. HIGH TEMP (°C)						35	
VMP CORRECTION	-0.37 %/*C	ASHRAE 2/8 AVG. HIGH TEWP (C)						55	JUNCTION BOX TO MAX. SHORT CIRCUIT CURRENT (ISC) = 15.0 A AC
SERIES FUSE RATING	20 A DC	SYSTEM ELECTRICAL SPECIFICATIONS	CIR 1	CIR 2	CID 2	CID A	CIRE	CIR 6	JUNCTION BOX (2) MAX. CURRENT (ISC X1.25) = 18.8 A AC 800-377-4480
· 김 영화가 2016년 2월 2017년 2월 2018년 2월 2018	·····································					CIR 4	CIR 5	CIRD	WWW BI UERAVENSOLA
ADJ. MODULE VOC @ ASHRAE LOW TEMP	43.4 V DC	NUMBER OF MODULES PER MPPT	15	10	9				CONDUCTOR (UF-B, COPPER (60°C)) = 10 AWG
ADJ. MODULE VMP @ ASHRAE 2% AVG. HIGH TEMP	28.8 V DC	DC POWER RATING PER CIRCUIT (STC)	4875	3250	2925	W.FC			LONDOCTOR RATING = 30 A HEREIN CONTAINED SHALL
	07.14	TOTAL MODULE NUMBER			34 MOD				CONDUIT FILL DERATE = 1 USED FOR THE BENEF
	Q7 Microinverters	STC RATING OF ARRAY	15.0	10.0	11050W	DC			AMB. TEMP. AMP. CORRECTION = 0.96 BLUERAVENSOLAR NOR S BE DISCLOSED IN WHOLE
POWER POINT TRACKING (MPPT) MIN/MAX 22		AC CURRENT @ MAX POWER POINT (IMP	1	10.0	9.0				ADJUSTED AMP. = 28.8 > 18.8 PART TO OTHERS OUT
MAXIMUM INPUT VOLTAGE	48 V DC	MAX. CURRENT (IMP X 1.25)	18.75	12.5	11.25				JUNCTION BOX TO MAX. SHORT CIRCUIT CURRRENT (ISC) = 15.0 A AC RECIPIENTS ORGANIZA EXCEPT IN CONNECTION V
MAXIMUM DC SHORT CIRCUIT CURRENT	15 A DC	OCPD CURRENT RATING PER CIRCUIT	20	20	20		<u> </u>		COMBINER BOX (3) MAX. CURRENT (ISC X1.25) = 18.8 A AC SALE AND USE OF THE RES
MAXIMUM USABLE DC INPUT POWER	350 W	MAX. COMB. ARRAY AC CURRENT (IMP)			34.0				CONDUCTOR (UF-B, COPPER (60°C)) = 10 AWG WRITTEN PERMISSION
MAXIMUM OUTPUT CURRENT	1 A AC	MAX. ARRAY AC POWER			8160W	AC			CONDUCTOR RATING = 30 A BLUERAVENSOLAR L
AC OVERCURRENT PROTECTION	20 A		15285-122-14						CONDUIT FILL DERATE = 0.8
MAXIMUM OUTPUT POWER	240 W	AC VOLTAGE RISE CALCULATIONS	DIST (FT)		VRISE(V)			IQ7-10	
CEC WEIGHTED EFFICIENCY	97 %	VRISE SEC. 1 (MICRO TO JBOX)	36	12 Cu.	1.45		0.61%		ADJUSTED AMP. = 23.04 > 18.8
		VRISE SEC. 2 (JBOX TO COMBINER BOX)	65	10 Cu.	2.48	242.48	1.03%		COMBINER BOX TO INVERTER RATED AMPS = 34.0 A AC
AC PHOTOVOLATIC MODULE MARKING (NEC 690.52	2)	VRISE SEC. 3 (COMBINER BOX TO POI)	35	6 Cu.	1.21	241.21	0.51%		MAIN PV OCPD (15) MAX. CURRENT (RATED AMPS X1.25) = 42.5 A AC PROFESSION
NOMINAL OPERATING AC VOLTAGE	240 V AC	TOTAL VRISE			5.14	245.14	2.14%		CONDUCTOR (THWN-2, COPPER (75°C TERM.)) = 6 AWG Scott Gumey #PV-011719-01586
NOMINAL OPERATING AC FREQUENCY	47 - 68 HZ AC								CONDUCTOR RATING = 65 A #PV-011719-015860
MAXIMUM AC POWER	240 VA AC	PHOTOVOLTAIC AC DISCONNECT OUTPU	LABEL (NI	EC 690.54)					CONDUIT FILL DERATE = 1 CONTRACTOR
MAXIMUM AC CURRENT	1.0 A AC	AC OUTPUT CURRENT					34.0	A AC	AMB. TEMP. AMP. CORRECTION = 0.96 BRS FIELD OP
MAXIMUM OCPD RATING FOR AC MODULE	20 A AC	NOMINAL AC VOLTAGE					240	V AC	ADJUSTED AMP. = 62.4 > 42.5 385.498.6700
GROUNDING NOTES 1. A GROUNDING ELECTRODE SYSTEM IN ACCORDANCI [NEC 250-50] THROUGH [NEC 250-60] SHALL BE PROVIDE GROUNDING ELECTRODE SYSTEM OF EXISTING BUILDIN BONDED TO AT THE SERVICE ENTRANCE. IF EXISTING S OR INADEQUATE, OR IS ONLY METALLIC WATER PIPING, GROUNDING ELECTRODE WILL BE USED AT THE INVERT CONSISTING OF A UL LISTED 8 FT GROUND ROD WITH A 2. THE GROUNDING ELECTRODE CONDUCTOR SHALL B DAMAGE BETWEEN THE GROUNDING ELECTRODE AND SMALLER THAN #6 AWG COPPER WIRE PER NEC 250-644 CONDUCTOR WILL BE CONTINUOUS, EXCEPT FOR SPLIC WITHIN LISTED EQUIPMENT PER [NEC 250.64C.]. 3. GROUNDING ELECTRODE CONDUCTORS SHALL BE N NO GREATER THAN #6 AWG COPPER AND BONDED TO T ELECTRODE TO PROVIDE FOR A COMPLETE SYSTEM. 4. PV SYSTEM SHALL BE GROUNDED IN ACCORDANCE	D. PER NEC, NG MAY BE USED AND YSTEM IS INACCESSII A SUPPLEMENTAL TER LOCATION CORN CLAMP. E PROTECTED FROM THE PANEL (OR INVER 3. THE GROUNDING E CES OR JOINTS AT BU O LESS THAN #8 AWG THE EXISTING GROUN	690.45] AND BE A MINIMUM (SHALL BE USED WHEN EXPOS BLE, 12. GROUNDING AND BONDING CODED GREEN (OR MARKED G 13. ALL CONDUIT BETWEEN TH CONNECTION SHALL HAVE GR PHYSICAL 14. SYSTEM GEC SIZED ACCORDIN LECTRODE INSULATED, #6AWG WHEN EXF SBARS 15. EXPOSED NON-CURRENT O EQUIPMENTS, AND CONDUCTO 6 AND ACCORDANCE WITH 250.134 O DING WIRING & CONDUIT NOTES	ONDUCTOR F #10AWG ED TO DAM/ CONDUCTO REEN IF #4 IE UTILITY A DUNDED BL DING TO [N IG TO [NEC OSED TO D ARRYING M R ENCLOSI R 250.136(A)	WHEN NOT AGE). DRS, IF INS AWG OR L AC DISCON JSHINGS A EC 690.47] 250.166], M AMAGE. IETAL PAR JRES SHAL) REGARDL	T EXPOSED SULATED, SI ARGER) NECT AND T BOTH ENI , [NEC TABL MINIMUM #8/ TS OF MOD L BE GROU LESS OF VO	TO DAMA HALL BE (THE POIN DS. .E 250.66] AWG WHE ULE FRAM INDED IN ILTAGE.	AGE (#6AW COLOR NT OF I, DC EN MES,	/G	690.8] FOR MULTIPLE CONDUCTORS 8. ALL PV DC CONDUCTORS IN CONDUIT EXPOSED TO SUNLIGHT <u>SHALL BE INSTALLED</u> <u>AT LEAST 7/8' ABOVE THE ROOF SURFACE</u> AND DERATED ACCORDING TO [NEC TABLE 310.15 (B)(2)(a), NEC TABLE 310.15(B)(3)(a),& NEC 310.15(B)(3)(c)]. 9. EXPOSED ROOF PV DC CONDUCTORS SHALL BE USE-2, 90°C RATED, WET AND UV RESISTANT, AND UL LISTED RATED FOR 600V, UV RATED SPIRAL WRAP SHALL BE USED TO PROTECT WIRE FROM SHARP EDGES 10. PHASE AND NEUTRAL CONDUCTORS SHALL BE DUAL RATED THHN/THWN-2 INSULATED, 90°C RATED, WET AND UV RESISTANT, RATED FOR 600V 11. 4-WIRE DELTA CONNECTED SYSTEMS HAVE THE PHASE WITH THE HIGHER VOLTAGE TO GROUND MARKED ORANGE OR IDENTIFIED BY OTHER EFFECTIVE MEANS. 12. ALL SOURCE CIRCUITS SHALL HAVE INDIVIDUAL SOURCE CIRCUIT PROTECTION 13. VOLTAGE DROP LIMITED TO 2% FOR DC CIRCUITS AND 3% FOR AC CIRCUITS 14. NEGATIVE GROUNDED SYSTEMS DC CONDUCTORS SHALL BE COLOR CODED AS FOLLOWS: DC POSITIVE- RED (OR MARKED RED), DC NEGATIVE- GREY (OR MARKED GREY) 15. POSITIVE GROUNDED SYSTEMS DC CONDUCTORS COLOR CODED: DC POSITIVE- GREY (OR MARKED GREY), DC NEGATIVE- BLACK (OR MARKED BLACK)
250.122], AND ALL METAL PARTS OR MODULE FRAMES690.46].5. MODULE SOURCE CIRCUITS SHALL BE GROUNDED IN	ACCORDING TO [NEC	APPROVED FOR THE SITE APP 2. BOLTED CONNECTION REQU	LICATIONS	DISCONN	ECTS ON TH			ED I	16. AC CONDUCTORS >4AWG COLOR CODED OR MARKED: PHASE A OR L1- BLACK, PHASE B OR L2- RED, PHASE C OR L3- BLUE, NEUTRAL- WHITE/GRAY
690.42].6. THE GROUNDING CONNECTION TO A MODULE SHALLTHE REMOVAL OF A MODULE DOES NOT INTERRUPT A CONTRUCT A MODULE DOES NOT INTERRUPT A MODULE DOES NOT A MODUL	. BE ARRANGED SUCH	3. ANY CONNECTION ABOVE L I THAT DISALLOWED ABOVE LIVE PAR	TS, MEYERS	S HUBS RE	COMMEND	ED		l	* USE-2 IS NOT INDOOR RATED BUT PV CABLE IS RATED THWN/THWN-2 AND MAY BE USED INSIDE ** USE-2 IS AVAILABLE AS UV WHITE DATE DATE September 7, 2
TO ANOTHER MODULE. 7. EACH MODULE WILL BE GROUNDED USING THE SUPP IDENTIFIED IN THE MANUFACTURER'S INSTALLATION INS		OFF THE ROOF SURFACE IN A	CORDANCI S MOUNTEI	E WITH NE	C 110.2,110. //ROOF SUF	.3(A-B). 30 RFACE TO	00.4) BE USED	FOR	17. RIGID CONDUIT, IF INSTALLED, (AND/OR NIPPLES) MUST HAVE A PULL BUSHING TO PROJECT NUMBER PROTECT WIRES. 80648698 18. IF CONDUIT DETERMINED TO BE RAN THROUGH ATTIC IN FIELD THEN CONDUIT WILL 80648698
8. ENCLOSURES SHALL BE PROPERLY PREPARED WITH AS APPROPRIATE WHEN GROUNDING EQUIPMENT WITH GROUNDING LUGS.			UN WIRES	BE TYPE U	ISE-2, AND S	SINGLE-C	ONDUCTO	R	BE EITHER EMT, FMC, OR MC CABLE IF <u>DC</u> CURRENT COMPLYING WITH NEC 690.31, NEC 250.118(10). DISCONNECTING MEANS SHALL COMPLY WITH 690.13 AND 690.15 19. CONDUIT RAN THROUGH ATTIC WILL BE AT LEAST 18" BELOW ROOF SURFACE
					\mathcal{L}	JUIVALEN	NI, KOUIE		19. CONDOIT RAIN THROUGH AT HE WILL DE AT LEAST TO DELOW ROOF SORTAGE
9. GROUNDING SYSTEM COMPONENTS SHALL BE LISTE		*		EQUIRED	,		,		COMPLYING WITH NEC 230.6(4) AND SECURED NO GREATER THAN 6' APART PER NEC
9. GROUNDING SYSTEM COMPONENTS SHALL BE LISTE GROUNDING DEVISES EXPOSED TO THE ELEMENTS SH/ 10. GROUNDING AND BONDING CONDUCTORS SHALL BI	ALL BE RATED FOR DI	RECT BURIAL. 7. ALL CONDUCTORS AND OCF		EQUIRED	,		,		





1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUERAVENSOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNEC TION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUERAVENSOLAR LLC.



CONTRACTOR: BRS FIELD OPS 385.498.6700

SITE INFORMATION: Jim Mossop 251 Piney Grove Rawls Rd Fuquay Varina, North Carolina 27526 DC SYSTEM SIZE: 11.05 kW DC

DRAWING BY

DATE

Taylor Sink

0 1 1 7

September 7, 2020

PROJECT NUMBER

80648698

SHEET NAME

MBD CALCS.

PAGE NUMBER

PV7

REVISION

WARNING ELECTRIC SHOCK HAZARD TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

DIRECT CURRENT

PHOTOVOLTAIC POWER SOURCE

PHOTOVOLTAIC SYSTEM

AC DISCONNECT

WARNING

DUAL POWER SUPPLY

SOURCES: UTILITY GRID AND

PV SOLAR ELECTRIC SYSTEM

WARNING

INVERTER OUTPUT CONNECTION

DO NOT RELOCATE

THIS OVERCURRENT

DEVICE

RATED AC OUTPUT CURRENT

NOMINAL OPERATING AC VOLTAGE

VDC

AMPS

V

MAXIMUM VOLTAGE

MAX CIRCUIT CURRENT

LABEL 1 FOR PV DISCONNECTING MEANS WHERE ALL TERMINALS OF THE DISCONNECTING MEANS MAY BE ENERGIZED IN THE OPEN POSITION. [NEC 690.13(B), NEC 705.22]

AT EACH DC DISCONNECTING MEANS, INCLUDING THE

AT POINT OF INTERCONNECTION, MARKED AT AC

IF INTERCONNECTING ON THE LOAD SIDE, INSTALL THIS

UTILITY AND THE SOLAR PV SYSTEM: THE MAIN SERVICE

LABEL ANYWHERE THAT IS POWERED BY BOTH THE

DC DISCONNECT AT THE INVERTER.

[NEC 690.53, NEC 690.13(B)]

DISCONNECTING MEANS

PANEL AND SUB-PANELS.

[NEC 705.12(B)(2)(3)(b)]

[NEC 705.12(B)(3)]

LABEL

[NEC 690.54, NEC 690.13 (B)]

LABEL :

WARNING: PHOTOVOLTAIC POWER SOURCE

SOLAR PV SYSTEM EQUIPPED

WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN

SWITCH TO THE "OFF" POSITION TO

SHUT DOWN PV SYSTEM

AND REDUCE

SHOCK HAZARD

TURN RAPID SHUTDOWN SWITCH

IN THE ARRAY

LABEL 7

AT DIRECT-CURRENT EXPOSED RACEWAYS, CABLE TRAYS, COVERS AND ENCLOSURES OF JUNCTION BOXES, AND OTHER WIRING METHODS; SPACED AT MAXIMUM 10FT SECTION OR WHERE SEPARATED BY ENCLOSURES, WALLS, PARTITIONS, CEILINGS, OR FLOORS. [NEC 690.31(G)(3&4)]

FOR PV SYSTEMS THAT SHUT DOWN THE ARRAY AND CONDUCTORS LEAVING THE ARRAY: SIGN TO BE LOCATED ON OR NO MORE THAN 3 FT AWAY FROM SERVICE DISCONNECTING MEANS TO WHICH THE PV SYSTEMS ARE CONNECTED AND SHALL INDICATE THE LOCATION OF ALL IDENTIFIED RAPID SHUTDOWN SWITCHES IF NOT AT THE SAME LOCATION. [NEC 690.56(C)(1)(A)]

FOR PV SYSTEMS THAT ONLY SHUT DOWN CONDUCTORS LEAVING THE ARRAY: SIGN TO BE LOCATED ON OR NO MORE THAN 3 FT AWAY FROM SERVICE DISCONNECTING MEANS TO WHICH THE PV SYSTEMS ARE CONNECTED AND SHALL INDICATE THE LOCATION OF ALL IDENTIFIED RAPID SHUTDOWN SWITCHES IF NOT AT THE SAME LOCATION. [NEC 690.56(C)(1)(B)]

EXISTING SUB PANEL

(IF WHERE POINT OF

INTERCONNECTION

(1)

(3)&(4)

(5)

(ONLY IF PV

ITERCONNECTIO

ONSISTS OF LOA

SIDE BREAKER)

BREAKER USED

IS MADE

SIGN LOCATED AT RAPID SHUT DOWN DISCONNECT SWITCH [NEC 690.56(C)(3)].

WARNING POWER TO THIS BUILDING IS ALSO SUPPLIED FROM MAIN DISTRIBUTION

UTILITY DISCONNECT LOCATED

A WARNING

MAIN DISTRIBUTION UTILITY DISCONNECT(S)

POWER TO THIS BUILDING IS ALSO SUPPLIED

FROM A ROOF MOUNTED SOLAR ARRAY WITH A RAPID SHUTDOWN DISCONNECTING MEANS GROUPED AND LABELED WITHIN LINE OF SITE

AND 10 FT OF THIS LOCATION.

POWER TO THIS BUILDING IS ALSO SUPPLIED FROM ROOF MOUNTED SOLAR ARRAY, SOLAR ARRAY RAPID SHUTDOWN DISCONNECT IS LOCATED OUTSIDE NEXT TO UTILITY METER.


PERMANENT DIRECTORY TO BE LOCATED AT MAIN SERVICE EQUIPMENT DENOTING THE LOCATION OF THE PV RAPID SHUTDOWN SYSTEM DISCONNECTING MEANS IF SOLAR ARRAY RAPID SHUT DOWN DISCONNECT SWITCH IS NOT GROUPED AND WITHIN LINE OF SITE OF MAIN SERVICE DISCONNECTING MEANS. [NEC 705.10, NEC 690.56(C)(1)]

ABEL 14

WARNING


PHOTOVOLTAIC SYSTEM **COMBINER PANEL**

DO NOT ADD LOADS



PV OUTPUT CIRCUITS (1)(3) (6)(11)

(14)



PLACED ADJACENT TO THE BACK-FED BREAKER FROM THE INVERTER IF TIE IN CONSISTS OF LOAD SIDE CONNECTION TO BUSBAR. ´o o

AWARNING


THIS EQUIPMENT FED BY MULTIPLE SOURCES. TOTAL RATING OF ALL OVERCURRENT DEVICES, EXCLUDING MAIN SUPPLY OVERCURRENT DEVICE, SHALL NOT EXCEED AMPACITY OF BUSBAR.

LABELING NOTES

- LABELS CALLED OUT ACCORDING TO ALL COMMON CONFIGURATIONS. ELECTRICIAN TO DETERMINE EXACT REQUIREMENTS IN THE FIELD PER CURRENT NEC AND LOCAL CODES AND MAKE APPROPRIATE ADJUSTMENTS
- LABELING REQUIREMENTS BASED ON THE 2017 NATIONAL ELECTRIC CODE, OSHA STANDARD 19010 145 ANSI 7535
- MATERIAL BASED ON THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION 3
- LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED AND 4 SHALL NOT BE HANDWRITTEN [NEC 110.21]
- 5 LABELS TO BE A MINIMUM LETTER HEIGHT OF 3/8", WHITE ON RED BACKGROUND; REFLECTIVE, AND PERMANENTLY AFFIXED [IFC 605.11.1.1]

(ONLY IF 3 OR MORE SUPPLY SOURCES TO A BUSBAR) SIGN LOCATED AT LOAD CENTER IF IT

CONTAINS 3 OR MORE POWER SOURCES. [NEC 705.12(B)(2)(3)(C)]



AC DISCONNECT

(3)

(10)

(1)

(12) OR

PLACARD

INTEGRATED DC DISCONNECT

*ELECTRICAL DIAGRAM SHOWN ABOVE IS FOR LABELING PURPOSES ONLY. NOT AN ACTUAL REPRESENATION OF EQUIPMENT AND CONNECTIONS TO BE INSTALLED. LABEL LOCATIONS PRESENTED MAY VERY DEPENDING ON TYPE OF INTERCONNECTION METHOD AND LOCATION PRESENTED ON PV5 OF 3 LINE DIAGRAM. PV5 LINE DIAGRAM TO REFLECT ACTUAL REPRESENTATION OF PROPOSED SCOPE OF WORK.



N NO.

n



BREAKER USED

(11) OR (13)

OR PLACARD

(5)

(ONLY IF PV

NTERCONNECTIO

CONSISTS OF LOAD

SIDE BREAKER)





LAB<u>EL 11</u>

PERMANENT DIRECTORY TO BE LOCATED AT MAIN SERVICE EQUIPMENT LOCATION IF ALL ELECTRICAL POWER SOURCE DISCONNECTING MEANS (SOLAR ARRAY RAPID SHUTDOWN SWITCH) ARE GROUPED AND IN LINE OF SITE OF MAIN SERVICE DISCONNECTING MEANS. [NEC 690.56(C) & NEC 705.10].

PERMANENT DIRECTORY TO BE LOCATED AT SOLAR ARRAY RAPID SHUTDOWN SWITCH DENOTING THE LOCATION OF THE SERVICE EQUIPMENT LOCATION IF SOLAR ARRAY RAPID SHUT DOWN DISCONNECT SWITCH IS NOT GROUPED AND WITHIN LINE OF SITE OF MAIN SERVICE DISCONNECTING MEANS. [NEC 705.10]

LABEL 13

PERMANENT DIRECTORY TO BE LOCATED AT AC COMBINER PANEL [NEC 110.21(B)]

X				
2	B	С)	(


S)			
		JUNCTION BOX	
		OR COMBINER E	BOX
		(7)	
$\begin{pmatrix} 1 \end{pmatrix}$			
(2)	$ $ \bigcirc		
	- 0 T		-



1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUERAVENSOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION. EXCEPT IN CONNEC TION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUERAVENSOLAR LLC.



CONTRACTOR: **BRS FIELD OPS** 385.498.6700

526 БС 27 Carolina k∨ Rawls Rd 11.05 North **INFORMATION:** SIZE: Grove | Varina, STEM 3 Jim Mossop Piney Fuquay SYS ш 251 SIT Ю

DRAWING BY

DATE

Taylor Sink

September 7, 2020

PROJECT NUMBER

80648698

SHEET NAME

LABELS

PAGE NUMBER PV8

REVISION

Data Sheet **Enphase Microinverters** Region: AMERICAS

Enphase IQ 7 and IQ 7+ **Microinverters**



The high-powered smart grid-ready Enphase IQ 7 Micro[™] and Enphase IQ 7+ Micro[™] dramatically simplify the installation process while achieving the highest system efficiency.

Part of the Enphase IQ System, the IQ 7 and IQ 7+ Microinverters integrate with the Enphase IQ Envoy[™], Enphase IQ Battery[™], and the Enphase Enlighten[™] monitoring and analysis software.

IQ Series Microinverters extend the reliability standards set forth by previous generations and undergo over a million hours of power-on testing, enabling Enphase to provide an industry-leading warranty of up to 25 years.

Easy to Install

- · Lightweight and simple
- Faster installation with improved, lighter two-wire cabling
- Built-in rapid shutdown compliant (NEC 2014 & 2017)

Productive and Reliable

- · Optimized for high powered 60-cell/120 half-cell and 72cell/144 half-cell* modules
- More than a million hours of testing
- · Class II double-insulated enclosure
- UL listed

Smart Grid Ready

- Complies with advanced grid support, voltage and frequency ride-through requirements
- · Remotely updates to respond to changing grid requirements
- Configurable for varying grid profiles
- Meets CA Rule 21 (UL 1741-SA)

* The IQ 7+ Micro is required to support 72-cell/144 half-cell modules.

Enphase IO 7 and IO 7+ Microinverters

Enphase IQ 7 and IQ 7+ Mid	croinverters	5	
INPUT DATA (DC)	IQ7-60-2-US		IQ7PLUS-72-2
Commonly used module pairings ¹	235 W - 350 W +		235 W - 440 W
Module compatibility	60-cell/120 half- only	-cell PV modules	60-cell/120 ha cell/144 half-c
Maximum input DC voltage	48 V		60 V
Peak power tracking voltage	27 V - 37 V		27 V - 45 V
Operating range	16 V - 48 V		16 V - 60 V
Min/Max start voltage	22 V / 48 V		22 V / 60 V
Max DC short circuit current (module Isc)	15 A		15 A
Overvoltage class DC port	П		II
DC port backfeed current	0 A		0 A
PV array configuration			onal DC side protec 20A per branch circ
OUTPUT DATA (AC)	IQ 7 Microinve	rter	IQ 7+ Microi
Peak output power	250 VA		295 VA
Maximum continuous output power	240 VA		290 VA
Nominal (L-L) voltage/range ²	240 V /	208 V /	240 V /
	211-264 V	183-229 V	211-264 V
Maximum continuous output current	1.0 A (240 V)	1.15 A (208 V)	1.21 A (240 V)
Nominal frequency	60 Hz		60 Hz
Extended frequency range	47 - 68 Hz		47 - 68 Hz
AC short circuit fault current over 3 cycles	5.8 Arms		5.8 Arms
Maximum units per 20 A (L-L) branch circuit ³	16 (240 VAC)	13 (208 VAC)	13 (240 VAC)
Overvoltage class AC port			
AC port backfeed current	18 mA		18 mA
Power factor setting	1.0		1.0
Power factor (adjustable)	0.85 leading 0	00 0	0.85 leading
EFFICIENCY	@240 V	@208 V	@240 V
Peak efficiency	97.6 %	97.6 %	97.5 %
CEC weighted efficiency	97.0 %	97.0 %	97.0 %
MECHANICAL DATA			•
Ambient temperature range	-40°C to +65°C		
Relative humidity range	4% to 100% (con	0,	
Connector type	· ·		additional Q-DCC-5
Dimensions (HxWxD)	212 mm x 175 m	,	ithout bracket)
Weight	1.08 kg (2.38 lbs	,	
Cooling	Natural convecti	on - No rans	
Approved for wet locations	Yes		
Pollution degree	PD3		
Enclosure			ion resistant polym
Environmental category / UV exposure rating	NEMA Type 6 / c	outdoor	
FEATURES			
Communication	Power Line Com	munication (PL	C)
Monitoring	Both options rec	uire installation	nten monitoring opti of an Enphase IQ Er
Disconnecting means	The AC and DC o disconnect requ		been evaluated and
Compliance	CAN/CSA-C22.2 This product is l 2017, and NEC 2	741/IEEE1547, F 2 NO. 107.1-01 JL Listed as PV I 020 section 690	CC Part 15 Class B, Rapid Shut Down Eq .12 and C22.1-2015 1 installed according

CERTIFIED

To learn more about Enphase offerings, visit enphase.com

1. No enforced DC/AC ratio. See the compatibility calculator at https://enphase.com/en-us/support/module-compatibility. Nominal voltage range can be extended beyond nominal if required by the utility.
 Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.



To learn more about Enphase offerings, visit enphase.com

© 2020 Enphase Energy. All rights reserved. Enphase, the Enphase logo, Enphase IQ 7, Enphase IQ 7+, Enphase IQ Battery, Enphase Enlighten, Enphase IQ Envoy, and other trademarks or service names are the trademarks of Enphase Energy, Inc. Data subject to change. 2020-08-12

2	-	U	S	

N + alf-cell and 72cell PV modules

ection required; rcuit oinverter

208 V / 183-229 V) 1.39 A (208 V)

11 (208 VAC)

. 0.85 lagging

@208 V 97.3 % 97.0 %

5 adapter

neric enclosure

tions.

Envov

nd approved by UL for use as the load-break

ICES-0003 Class B,

quipment and conforms with NEC 2014, NEC Rule 64-218 Rapid Shutdown of PV Systems, ng manufacturer's instructions.





1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



CONTRACTOR: **BRS FIELD OPS** 385.498.6700

HEET NAME SPEC SHEET

AGE NUMBER


REVISION

0

SS

Enphase **IQ Combiner 3**

(X-IQ-AM1-240-3)





The **Enphase IQ Combiner 3**[™] with Enphase IQ Envoy[™] consolidates interconnection equipment into a single enclosure and streamlines PV and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.

Smart

- Includes IQ Envoy for communication and control
- Flexible networking supports Wi-Fi, Ethernet, or cellular
- Optional AC receptacle available for PLC bridge
- Provides production metering and optional consumption monitoring

Simple

- · Reduced size from previous combiner
- Centered mounting brackets support single stud mounting
- Supports back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- 80 A total PV or storage branch circuits

Reliable

- Durable NRTL-certified NEMA type 3R enclosure
- Five-year limited warranty
- UL listed

Enphase IQ Combiner 3

MODEL NUMBER	
IQ Combiner 3 X-IQ-AM1-240-3	IQ Combiner 3 with Enphase IQ Envoy™ printed c production metering (ANSI C12.20 +/- 0.5%) and
ACCESSORIES and REPLACEMENT PARTS (no	t included, order separately)
Enphase Mobile Connect [™] CELLMODEM-03 (4G/12-year data plan) – CELLMODEM-01 (3G/5-year data plan) CELLMODEM-M1 (4G based LTE-M/5-year data plan) Consumption Monitoring* CT CT-200-SPLIT	Split core current transformers enable whole how
* Consumption monitoring is required for Enphase Storage Systems Wireless USB adapter COMMS-KIT-01	s Installed at the IQ Envoy. For communications with Enpower [™] smart switch. Includes USB cable for co and allows redundant wireless communication wi
Circuit Breakers BRK-10A-2-240 BRK-15A-2-240 BRK-20A-2P-240	Supports Eaton BR210, BR215, BR220, BR230, B Circuit breaker, 2 pole, 10A, Eaton BR210 Circuit breaker, 2 pole, 15A, Eaton BR215 Circuit breaker, 2 pole, 20A, Eaton BR220
EPLC-01	Power line carrier (communication bridge pair), o
XA-PLUG-120-3	Accessory receptacle for Power Line Carrier in IC
XA-ENV-PCBA-3	Replacement IQ Envoy printed circuit board (PCE
ELECTRICAL SPECIFICATIONS	
Rating	Continuous duty
System voltage	120/240 VAC, 60 Hz
Eaton BR series busbar rating	125 A
Max. continuous current rating (output to grid)	65 A
Max. fuse/circuit rating (output)	90 A
Branch circuits (solar and/or storage)	Up to four 2-pole Eaton BR series Distributed Ge
Max. continuous current rating (input from PV)	64 A
Max. total branch circuit breaker rating (input)	80A of distributed generation / 90A with IQ Envo
Production Metering CT	200 A solid core pre-installed and wired to IQ En
MECHANICAL DATA	
Dimensions (WxHxD)	49.5 x 37.5 x 16.8 cm (19.5" x 14.75" x 6.63"). Hei
Weight	7.5 kg (16.5 lbs)
Ambient temperature range	-40° C to +46° C (-40° to 115° F)
Cooling	Natural convection, plus heat shield
Enclosure environmental rating	Outdoor, NRTL-certified, NEMA type 3R, polycark
Wire sizes	 20 A to 50 A breaker inputs: 14 to 4 AWG copp 60 A breaker branch input: 4 to 1/0 AWG copp Main lug combined output: 10 to 2/0 AWG copp Neutral and ground: 14 to 1/0 copper conduct Always follow local code requirements for conduct
Altitude	To 2000 meters (6,560 feet)
INTERNET CONNECTION OPTIONS	
Integrated Wi-Fi	802.11b/g/n
Ethernet	Optional, 802.3, Cat5E (or Cat 6) UTP Ethernet ca
Cellular	Optional, CELLMODEM-01 (3G) or CELLMODEM- (not included)
COMPLIANCE	
Compliance, Combiner	UL 1741, CAN/CSA C22.2 No. 107.1, 47 CFR, Par Production metering: ANSI C12.20 accuracy class
Compliance, IQ Envoy	UL 60601-1/CANCSA 22.2 No. 61010-1


To learn more about Enphase offerings, visit enphase.com

© 2018 Enphase Energy. All rights reserved. Enphase, the Enphase logo, IQ Combiner 3, and other trademarks or service

To learn more about Enphase offerings, visit enphase.com

circuit board for integrated revenue grade PV d optional* consumption monitoring (+/- 2.5%).	BLUE	RAVEN
with data plan for systems up to 60		H WAY, BUILDING J UT 84097
exico, Puerto Rico, and the US Virgin Islands, nstallation area.) ome consumption metering (+/- 2.5%).		77-4480 VENSOLAR.COM
ith Enphase Encharge [™] storage and Enphase connection to IQ Envoy or Enphase IQ Combiner [™] vith Encharge and Enpower. BR240, BR250, and BR260 circuit breakers. quantity - one pair IQ Combiner 3 (required for EPLC-01)	HEREIN CONTAIN USED FOR TH ANYONE EXCE SOLAR NOF DISCLOSED IN W TO OTHERS OUT ORGANIZATIO CONNECTION WII USE OF THE EQUIPMENT, WRITTEN PERM	THE INFORMATION IED SHALL NOT BE BE BENEFIT OF PT BLUE RAVEN & SHALL IT BE (HOLE OR IN PART "SIDE RECIPIENTS DN, EXCEPT IN TH THE SALE AND RESPECTIVE WITHOUT THE MISSION OF BLUE OLAR LLC.
CB) for Combiner 3		
	PROFES	
eneration (DG) breakers only (not included)	BRS FIE	ACTOR: ELD OPS 98.6700
oy breaker included		
nvoy		
eight is 21.06" (53.5 cm with mounting brackets).		
when not a construction		
rbonate construction per conductors per conductors opper conductors otors ductor sizing.		
cable (not included) /-03 (4G) or CELLMODEM-M1 (4G based LTE-M)		
art 15, Class B, ICES 003 ass 0.5 (PV production)		
	SHEET NAME	HEET
e names are the ENPHASE .		
	SS	0

REC TWINPEAK 3 MONO BLACK SERIES





WARRANTY			
	Standard	RECE	ProTrust
Installed by an REC Certified Solar Professional	No	Yes	Yes
System Size	Any	≤25 kW .	25-500 kW
Product Warranty (yrs)	20	25	25
Power Warranty (yrs)	25	25	25
Labor Warranty (yrs)	0	25	10
Power in Year 1	97.5%	97.5%	97.5%
Annual Degradation	0.7%	0.7%	0.7%
Power in Year 25 See warranty document	80.7% s for details	80.7% Some con	80.7% ditions apply.

REC Group is an international pioneering solar energy company dedicated to empowering Consumers with iternational puncturing solar energy Company decidates to empowering consumers with clean, affordable solar power in order to facilitate globale energy transitions. Committed to quality and innovation, REC offers photovoltaic modules with leading high quality, backed by an exceptional low warranty claims rate of less than 100pm. Founded in Norway in 1996, REC employs 2,000 people and has an annual solar panel capacity of 1.8 GW. Withover 10 GW installed worldwide, REC is empowering more than 16 million people with clean solar energy. REC Groupis a Bluestar Elkem company withheadquarters in Norway, operational headquarters in Singapore, and regional bases in North America, Europe, and Asia-Pacific.

N REC

REC TWINPEAK 3 MONO BLACK

PREMIUM SOLAR PANELS WITH SUPERIOR PERFORMANCE

REC TwinPeak 3 Mono Black Series solar panels feature an innovative design with high panel efficiency and power output, enabling customers to get the most out of the space used for the installation.

Combined with industry-leading product quality and the reliability of a strong and established European brand, REC TwinPeak 3 Mono Black panels are ideal for residential and commercial rooftops worldwide.



OUTPUT PER M²
















IN SHADED CONDITIONS

PID FREE

SYSTEM COSTS





pe.eaton.com

General Duty Non-Fusible Safety Switch

DG222UGB

UPC:782114731130

Dimensions:

- · Height: 7 IN
- · Length: 6.41 IN
- Width: 8.4 IN

Weight:6 LB

Notes:WARNING! Switch is not approved for service entrance unless a neutral kit is installed.

Warranties:

 Eaton Selling Policy 25-000, one (1) year from the date of installation of the Product or eighteen (18) months from the date of shipment of the Product, whichever occurs first.

Specifications:

- Type: General Duty/Non-Fusible
- · Amperage Rating: 60A
- · Enclosure: NEMA 1
- · Enclosure Material: Painted steel
- · Fuse Configuration: Non-fusible
- · Number Of Poles: Two-pole
- · Number Of Wires: Two-wire
- · Product Category: General Duty Safety Switch
- Voltage Rating: 240V

Supporting documents:

- Eatons Volume 2-Commercial Distribution
- Eaton Specification Sheet DG222UGB

Certifications:

UL Listed

Product compliance: No Data





1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM


CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



CONTRACTOR: BRS FIELD OPS 385.498.6700

SHEET NAME SPEC SHEET PAGE NUMBER SS 0

SYSTEM BONDING & GROUNDING INSTALLATION GUIDE PAGE



Star Washer is **Single Use Only**

TERMINAL TORQUE, Install Conductor and

S

torque to the following: 4-6 AWG: 35in-lbs 8 AWG: 25 in-lbs 10-14 AWG: 20 in-lbs

LUG DETAIL & TORQUE INFO Ilsco Lay-In Lug (GBL-4DBT)

- 10-32 mounting hardware
- Torque = 5 ft-lb •
- AWG 4-14 Solid or Stranded



TERMINAL TORQUE, **Install Conductor and** torque to the following: 4-14 AWG: 35in-lbs

LUG DETAIL & TORQUE INFO Ilsco Flange Lug(SGB-4)

- 1/4" mounting hardware
- Torque = 75 in-lb
- AWG 4-14 Solid or Stranded

WEEBLUG Single Use Only




TERMINAL TORQUE, Install Conductor and torque to the following: 6-14 AWG: 7ft-lbs

LUG DETAIL & TORQUE INFO Wiley WEEBLug (6.7)

- 1/4" mounting hardware
- Torque = 10 ft-lb
- AWG 6-14 Solid or Stranded


NOTE: ISOLATE COPPER FROM ALUMINUM CONTACT TO PREVENT CORROSION

System bonding is accomplished through modules. System grounding accomplished by attaching a ground lug to any module at a location on the module specified by the module manufacturer.




E-W BONDING PATH:

E-W module to module bonding is accomplished with 2 pre-installed bonding pins which engage on the secure side of the MicrorailTM and splice.



N-S BONDING PATH:

N-S module to module bonding is accomplished with bonding clamp with 2 integral bonding pins. (refer also to alternate method)




TRIMRAIL BONDING PATH:

Trimrail to module bonding is accomplished with bonding clamp with integral bonding pin and bonding T-bolt. (refer also to alternate method)











1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BI USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVE! SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PAR TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



CONTRACTOR: **BRS FIELD OPS** 385.498.6700

HEET NAME SPEC SHEET

REVISION

AGE NUMBER SS



UL CODE COMPLIANCE NOTES Installation guide Page

SYSTEM LEVEL FIRE CLASSIFICATION

The system fire class rating requires installation in the manner specified in the SUNFRAME MICRORAIL (SFM) Installation Guide. SFM has been classified to the system level fire portion of UL 1703. This UL 1703 classification has been incorporated into the UL 2703 product certification. SFM has achieved Class A, B & C system level performance for low slope & steep sloped roofs when used in conjunction with type 1 and type 2 modules. Class A, B & C system level fire

performance is inherent in the SFM design, and no additional mitigation measures are required. The fire classification rating is valid for any roof pitch. There is no required minimum or maximum height limitation above the roof deck to maintain the Class A, B & C fire rating for SFM. SUNFRAME MICRORAIL[™] components shall be mounted over a fire resistant roof covering rated for the application.

Module Type	Roof Slope	System Level Fire Rating	Microrail Direction	Module Orientation	Mitigation Red
Type 1 and Type 2	Steep Slope & Low Slope	Class A, B & C	East-West	Landscape OR Portrait	None Require


UL2703 TEST MODULES

See page "S" for a list of modules that were electrically and mechanically tested or qualified with the SUNFRAME MICRORAIL (SFM) components outlined within this Installation Guide.

- Maximum Area of Module = 22.3 sqft
- UL2703 Design Load Ratings:
 - Downward Pressure 113 PSF / 5400 Pa a)
 - Upward Pressure 50 PSF / 2400 Pa b)
 - c) Down-Slope Load - 30 PSF / 1400 Pa
- Tested Loads:
 - Downward Pressure 170 PSF / 8000 Pa a)
 - b) Upward Pressure - 75 PSF / 3500 Pa
 - Down-Slope Load 45 PSF / 2100 Pa c)
- Maximum Span = 6ft
- Use with a maximum over current protection device OCPD of 30A
- System conforms to UL Std 2703, certified to LTR AE-001-2012
- Rated for a design load of 2400 Pa / 5400 Pa with 24 inch span

LABEL MARKINGS

- System fire class rating: See installation instructions for installation requirements to achieve a specified system fire class rating with Unirac.
- Unirac SUNFRAME MICRORAIL[™] is listed to UL 2703.
- All splices within a system are shipped with marking indicating date and location of manufacture.





equired ired



1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BI USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PAR TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.

> NABCE CERTIFIED **PV INSTALLATION** PROFESSIONAL Scott Gurney # PV-011719-015866

> > CONTRACTOR: **BRS FIELD OPS** 385.498.6700

HEET NAME SPEC SHEET

AGE NUMBER

REVISION

SS

TESTED / CERTIFIED MODULE LIST INSTALLATION GUIDE PAGE

Manufacture	Module Model / Series	Manufacture	Module Model / Series	Manufacture	Module Model / Series
Aleo Astronergy	P-Series CHSM6612P, CHSM6612P/HV, CHSM6612M, CHSM6612M/HV, CHSM6610M (BL)(BF)/(HF), CHSM72M-HC	JA Solar	JAP6 60-xxx, JAM6-60-xxx/SI, JAM6(K)-60/ xxx, JAP6(k)-72-xxx/4BB, JAP72SYY-xxx/ZZ, JAP6(k)-60-xxx/4BB, JAP60SYY-xxx/ZZ, JAM6(k)-72-xxx/ZZ, JAM72SYY-xxx/ZZ, JAM6(k)-60-xxx/ZZ, JAM60SYY-xxx/ZZ. i. YY: 01, 02, 03, 09, 10 ii. ZZ: SC, PR, BP, HiT, IB, MW	REC	PEAK Energy Series, PEAK Energy BLK2 Series, PEAK Energy 72 Series, TwinPeak 2 Series,
Auxin	AXN6M610T, AXN6P610T, AXN6M612T & AXN6P612T				TwinPeak 2 BLK2 Series, TwinPeak Series
Axitec	AXI Power, AXI Premium, AXI Black Premium			Renesola	Vitrus2 Series & 156 Series
Boviet	BVM6610, BVM6612	Jinko	JKM & JKMS Series	Risen	RSM Series
BYD	P6K & MHK-36 Series	Kyocera	KU Series	S-Energy	SN72 & SN60 Series (40mm)
	CS6V-M, CS6P-P, CS6K-M, CS5A-M, CS6K-MS, CS6U-P, CS6U-M, CS6X-P, CS6K-MS, CS6K-M, CS6K-P, CS6P-P, CS6P-M, CS3U-P, CS3U-MS, CS3K-P, CS3K-MS, CS1K-MS, CS3K,		LG xxx S1C-A5, LG xxx N1C-A5,	Seraphim	SEG-6 & SRP-6 Series
			LGxxxQ1C(Q1K)-A5, LGxxxN1C(N1K)-A5,	Sharp	NU-SA & NU-SC Series
			LGxxxS1CA5, LGxxxA1C-A5, LGxxxN2T-A4,SilfabLGxxxN2T-A5, LGxxxN2W-A5SolariaLGxxxS2W-A5, LGxxxE1C-A5, LGxxxS2W-G4SolarWorldLGxxxN1C(N1K)-G4, LGxxxN2W-G4,Sonali	Silfab	SLA, SLG & BC Series
Canadian Solar				Solaria	PowerXT
	CS3U, CS3U-MB-AG, CS3K-MB-AG, CS6K,	LG Electronics		SolarWorld	Sunmodule Protect,
	CS6U, CS3L, CS3W, CS1H-MS, CS1U-MS				Sunmodule Plus
Centrosolar America	C-Series & E-Series			Sonali	SS 230 - 265
	CT2xxMxx-01, CT2xxPxx-01,		LGxxxN1K(N1C)-V5, LGxxxQ1C(N2W)-V5,	Suntech	STP
CertainTeed	CTxxxMxx-02, CTxxxM-03, CTxxxMxx-04, CTxxxHC11-04	LONGI	LR6-60 & LR6-72 Series,	Suniva	MV Series & Optimus Series
			LR4-60 & LR4-72 Series Sun Edison/Flextronics	F-Series, R-Series & FLEX FXS Series	
Dehui	DH-60M	Mission Solar Energy	MSE Series	SunPower	X-Series, E-Series & P-Series
Eco Solargy	Orion 1000 & Apollo 1000	Mitsubishi	MJE & MLE Series	Talogup	TP572, TP596, TP654, TP660,
FreeVolt	Mono PERC	Neo Solar Power Co.	D6M & D6P Series	Talesun	TP672, Hipor M, Smart
GCL	GCL-P6 & GCL-M6 Series	Panasonic	VBHNxxxSA15 & SA16, VBHNxxxSA17 & SA18, VBHNxxxSA17(E/G) & SA18E, VBHNxxxKA01 & KA03 & KA04, VBHNxxxZA01, VBHNxxxZA02, VBHNxxxZA03, VBHNxxxZA04	Tesla	SC, SC B, SC B1, SC B2
Hansol	TD-AN3, TD-AN4, UB-AN1, UD-AN1			Trina	PA05, PD05, DD05, DE06, DD06, PE06, PD14, PE14, DD14, DE14, DE15, PE15H
				Upsolar	UP-MxxxP(-B), UP-MxxxM(-B)
Heliene	36M, 60M, 60P, 72M & 72P Series			URE	D7MxxxH8A, D7KxxxH8A, D7MxxxH7A
HT Solar	Solar HT60-156(M) (NDV) (-F), HT 72-156(M/P)			Vikram	Eldora, Solivo, Somera
Hyundai	KG, MG, TG, RI, RG, TI, MI, HI & KI Series	Peimar	SGxxxM (FB/BF)	Waaree	AC & Adiya Series
ITEK	iT, iT-HE & iT-SE Series	Phono Solar	PS-60, PS-72	Winaico	WST & WSP Series
Japan Solar	JPS-60 & JPS-72 Series	Q.Cells	Plus, Pro, Peak, G3, G4, G5, G6(+), G7, G8(+) Pro, Peak L-G2, L-G4, L-G5, L-G6, L-G7	Yingli	YGE & YLM Series

S

Please see the SFM UL2703Construction Data Report at Unirac.com to ensure the exact solar module selected is approved for use with SFM. SFM Infinity is not compatible with module frame height of less than 32mm and more than 40mm. See page J for further information.





1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



CONTRACTOR: BRS FIELD OPS 385.498.6700

HEET NAME SPEC SHEET

PAGE NUMBER

REVISION

SS

intertek

AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: Unirac, Inc Manufacturer: 1411 Broadway Blvd NE Address: Address: Albuquerque, NM 87102 USA **Country: Country:** Klaus Nicolaedis Contact: Contact: Todd Ganshaw 505-462-2190 Phone: Phone: 505-843-1418 FAX: NA FAX: klaus.nicolaedis@unirac.com Email: Email: toddg@unirac.com Party Authorized To Apply Mark: Same as Manufacturer **Report Issuing Office:** Lake Forest, CA Control Number: 5003705 Authorized by: Intertek This document supersedes all previous Authorizations to Mark for the noted Report Number. This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect. Intertek Testing Services NA Inc. 545 East Algonguin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672 Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels [UL 2703: 2015 Ed.1] Standard(s):

Photovoltaic Module Racking Systems [CSA LTR AE-001:2012 Ed.2012/10/23]

Photovoltaic Mounting System, Sun Frame Microrail Installation Guide, PUB2020MAY04 Product: Brand Name: Unirac Unirac SFM Models:

ATM for Report 102393982LAX-002

Page 1 of 2

ATM Issued: 2-Jun-2020 ED 16.3.15 (20-Apr-17) Mandatory

intertek

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Unirac, Inc		Manufacturer:
Address:	1411 Broadway Blvd N Albuquerque, NM 871		Address:
Country: Contact: Phone: FAX: Email:	USA Klaus Nicolaedis Todd Ganshaw 505-462-2190 505-843-1418 NA klaus.nicolaedis@unir toddg@unirac.com	ac.com	Country: Contact: Phone: FAX: Email:
Party Authoria Report Issuin	zed To Apply Mark: g Office:	Same as Manufacture Lake Forest, CA	Cloud
Control Numb	per: <u>5003705</u>	Authorized by:	for L. Matthew S



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

> Intertek Testing Services NA Inc. 545 East Algonquin Road, Arlington Heights, IL 60005 Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	Mounting Systems, Mounting Devices, Clamping/Retention Devices, an Plate Photovoltaic Modules and Panels [UL 2703: 2015 Ed.1]
	Photovoltaic Module Racking Systems [CSA LTR AE-001:2012 Ed.201
Product:	Photovoltaic Mounting System, Sun Frame Microrail Installation Guide,
Brand Name:	Unirac
Models:	Unirac SFM

ATM for Report 102393982LAX-002

Page 1 of 2

AUTHORIZATION TO MARK

den ladynsti

nd Ground Lugs for Use with Flat-

12/10/23]

PUB2020MAY04

ATM Issued: 2-Jun-2020 ED 16.3.15 (20-Apr-17) Mandatory



1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.



CONTRACTOR: **BRS FIELD OPS** 385.498.6700


HEET NAME SPEC SHEET PAGE NUMBER

REVISION

SS

S

SYSTEM COMPONENTS INSTALLATION GUIDE PAGE



Trimrail[™] and Module Clips

Sub-Components:

- 1. Trim Rail
- 2. Module Clip
- 3. T-Bolt
- Tri-Drive Nut 4.

Trimrail™

Functions:

- Required front row structural support (with module clips)
- Module mounting
- Installation aid ٠
- . Aesthetic trim

Features:

- Mounts directly to L-feet ٠
- Aligns and captures module leading edge .
 - Supports discrete module thicknesses from 32, 33, 35, 38, and 40mm


Module Clips

Functions:

- Required front row structural support (with trimrail)
- Module mounting •

Features:

- Mounts to Trimrail[™] with T-bolt and tri-drive nut
- Manually adjustable to fit module thicknesses 32, 33, 35, ٠ 38, and 40mm.



Trimrail[™] Flashkit

Sub-Components:

L-Foot Hex bolt Tri-drive nut Channel Nut Scocket Head Cap Screw 3"Channel/Slider w/grommet 3" Wide Flashing Structural Screw & SS EPDM Washer

Functions:

- Attach Trimrail[™] to roof attachment / flashing
- Patented roof sealing technology at roof attachment point •

Features:

- Slot provides vertical adjustments to level array
- Slider provides north/south adjustment along the slope of the roof
- Shed and Seal Technology

Trimrail[™] Splice

Sub-Components:


- 1. Structural Splice Extrusion
- 2. Bonding Clip

Functions:

- Front row structural support
- Installation aid

Features:

- Tool-less installation





1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM


CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.

Structurally connects 2 pieces of Trimrail[™] Electrically bonds 2 pieces of Trimrail[™]

Aligns and connects Trimrail[™] pieces

CERTIFIED PV INSTALLATION
PROFESSIONAL
Scott Gurney # PV-011719-015866
CONTRACTOR:
BRS FIELD OPS 385.498.6700
300.430.0700
SHEET NAME
SPEC SHEET
SPEC SHEET PAGE NUMBER REVISION SS 0

SYSTEM COMPONENTS INSTALLATION GUIDE PAGE



SFM Slider Flashkit

S

Sub-Components:


- 1. Slider w/grommet
- 2. Structural Screw & SS EPDM washer
- 3. 3" Wide Flashing

Functions:

- Patented Shed & Seal roof sealing technology at roof attach-. ment point
- For use with compatible 2" Microrail or 8" Attached Splices ٠

Features:

- . Slider provides north/south adjustment along the slope of the roof
- Shed and Seal Technology ٠




Module-to-Module N-S Bonding

Sub-Components:

- 1. Clamp
- Bonding Pins (2) 2.
- 3. 5/16" Socket Head Cap Screw
- 4. Clamp Base

Functions/ Features:

- Row to row bonding
- Single Use Only
- Fits module sizes 32-40mm




Trim -to- Module Bonding Clamp and Floating Trim Clamp

Sub-Components:

- 1. Wedge
- Bonding Pin 2.
- 3. T-Bolt 4.
- Nut Cast Base 5.

Functions/Features:

- Module to Trimrail[™] bonding single use only •
- Attaches Trimrail[™] to module when fewer than 2 rafter attachment points are available
- Fits module sizes 32-40mm
- Fits module sizes 32-40mm




Wire Bonding Clip w/ 8AWG

Functions:

- Row to row bonding
- Module to Trimrail[™] bonding
- Single Use Only

Features:

Tool-less installation



MLPE Mounting Assembly

Sub-Components:

- 1. MLPE Mount Base
- 2. 5/16 Socket Head Cap Screw
- 3. Bonding Pin


Functions:

- MLPE to module bonding

Features:

UL2703 Recognized

MLPE = Module Level Power Electronics, e.g. microinverter or power optimizer



Securely mounts MLPE to module frames

Mounts easily to typical module flange



1403 N RESEARCH WAY, BUILDING J OREM, UT 84097

800-377-4480 WWW.BLUERAVENSOLAR.COM

CONFIDENTIAL - THE INFORMATION HEREIN CONTAINED SHALL NOT BE USED FOR THE BENEFIT OF ANYONE EXCEPT BLUE RAVEN SOLAR NOR SHALL IT BE DISCLOSED IN WHOLE OR IN PART TO OTHERS OUTSIDE RECIPIENTS ORGANIZATION, EXCEPT IN CONNECTION WITH THE SALE AND USE OF THE RESPECTIVE EQUIPMENT, WITHOUT THE WRITTEN PERMISSION OF BLUE RAVEN SOLAR LLC.




CONTRACTOR: **BRS FIELD OPS** 385.498.6700


HEET NAME SPEC SHEET

AGE NUMBER SS

REVISION 0









Place flashings

PILOT HOLES: marked attachement points

Drill pilot holes for lag screws or structural screws (as necessary) at





INSTALL SLIDERS AND TRIMRAIL ROOF ATTACHMENTS:

• Insert flashings per manufacturer instructions

NOTE: Use Lag screw or structural fastener with a maximum diameter of 5/16"

- Attach sliders to rafters •
- Verify proper row to row spacing for module size (Mod NS + 1") ٠
- Ensure that TrimrailTM roof attachments in each row have sufficient • engagement with slider dovetails for proper attachment.

