

HTE# Eres 2005-0066

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Peter De Nicola PHONE # 919-300-7976

ADDRESS 919 N MAIN ST MOORESVILLE N.C. 28115

NAME OF MOBILE HOME PARK OR S/D _____

NAME OF OWNER (IF DIFFERENT) JONATHAN SZABADY

ADDRESS OF OWNER (IF DIFFERENT) 218 Roberts RD Sanford N.C. 27332

PROPERTY LOCATION: STATE ROAD NAME AND # OR Roberts RD

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

Solar Install

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Marshall JR PERMS
Signature of Inspector

1-20-21
Date