

NEC Standard Electrical Load Calculation for Single Family Dwellings

(Only for Service Ratings of 120/240V, 225 Amps Max)

Owner: Tim McKenzie Location: 234 Oakridge Duncan Rd
Fuquay Varina, NC 27526


Total Floor Area of Dwelling (NEC 220.12) 2750 SQFT.

Factor	Quantity	Volt Amperes (VA)
"General Lighting"		
1. General Lighting (SQFT X 3 VA/SQ FT (Table 220.12))	3 X 2750 sqft	8250
2. Small Appliance Circuits (1500 VA per circuit) (NEC 220.52(A)) (minimum 2)	1500 X 2	3000
3. Laundry Circuit (1500 VA per circuit) (NEC 220.52(B))	1500 X 1	1500
4. Total General Lighting Load (Add lines 1, 2 & 3):		12750
5. First 3000 VA @ 100%:		3000
6. Total General Lighting Load - 3000 = 9750 @ 35% =		3412
7. Net General Lighting Load (Per NEC 220.42) (Add lines 5 & 6):		6412
*Fixed Appliances (if insufficient space, use back):		
• Garbage Disposal	YES	NO
• Bathroom Fan		
• Microwave		
• Dishwasher	1	1200
• Other:		
• Other:		
Total		1200
8. 3 or less Appliances, Total Appliance VA; 4 or more Appliances, 75% of Total Appliance VA (NEC 220.53):		
*Other Loads (including motors, EV charger(s), etc.)		
9. Electric Range (8000VA or Nameplate)**	YES	NO
10. HVAC		8000
11. Electric Oven		3000
12. Electric Dryer (5000 VA minimum)**		5000
13. Electric Vehicle Charger	✓	
14. Other:		
15. Other:		
16. 25% of largest motor (NEC 430.24)		
Total Service Load Volt-Amperes (VA) (Add lines 7, 8 & 9 thru 16) =		23612
Total Service Load Volt-Amperes / 240-volts =		98.3 Amperes
***Service Rating (Amperes) =		98 AMPS

* For every "YES" answer, indicate VA rating of equipment

** Nameplate rating must be used if larger

*** Service Rating shall be greater than or equal to the Service load



Parnell Electric Inc.

6400 Allie Cooper Road
Godwin, NC 28344

As a covered entity under Title II of the Americans with Disabilities Act, the City of Los Angeles does not discriminate on the basis of disability and, upon request will provide reasonable accommodation to ensure equal access to its programs, services and activities.