



Current  
Renewables  
Engineering

12/31/2020

Go Solar Power, 933 Clint Moore Road,, Boca Raton FL 33487

Subject: Structural Certification for Installation of Residential Solar  
re job: Dawkins, Andre, 232 Old Montague, Cameron, NC 28326

Attn.: To Whom It May Concern

A field observation was performed to document the existing framing of the above mentioned address. From the field observation, the existing roof structure was observed as:

**ROOF 1:** Shingle roofing supported by 2x4 Truss @ 24 in. OC spacing. The roof is sloped at approximately 45 degrees and has a max beam span of 8 ft between supports.

Design Criteria:

Code: 2018 NC Building Code (ASCE 7-10)

Ult Wind Speed:	125 mph	Ground Snow:	10 psf
Exposure Cat:	B	Min Roof Snow:	NA psf

After review of the field observation report and based on our structural capacity calculations in accordance with applicable building codes, the existing roof framing supporting the proposed solar panel layout has been determined to be:

**ROOF 1:** adequate to support the imposed loads. Therefore, no structural upgrades are required.

Current Renewables Engineering Inc.  
Professional Engineer  
info@currentrenewableseng.com

