Each section below to be filled out by whomever performing work Must be owner or licensed contractor Address company name & phone must match

Harnett County Central Permitting PO Box 65 Lillington NC 27546 910 893 7525 Fax 910 893 2793 www harnett org/permits

Application for Residential Building and Trades Permit

Owner's Name	Date
Site Address	
Directions to job site from Lillington	
Subdivision	Lot
Description of Proposed Work	
Heated SF Inheated SF Finished Bonus Room? General Contractor Information	Crawl Space Slab <u>n</u>
Building Contractor's Company Name	Telephone
Address	Email Address
License # Electrical Contractor Information	on.
Description of Work Service Size	Amps T-PoleYesNo
Electrical Contractor's Company Name	Telephone
Address	Email Address
License # Mechanical/HVAC Contractor Inform	nation
Description of Work	
Mechanical Contractor's Company Name	Telephone
Address	Email Address
License # Plumbing Contractor Information	on .
Description of Work	# Baths
Plumbing Contractor's Company Name	Telephone
Address	Email Address
License # Insulation Contractor Information	on
Insulation Contractor's Company Name & Address	Telephone

I hereby certify that I have the authority to make necessary application, that the application is correct and that-the construction will conform to the regulations in the Building Electrical Plumbing and Mechanical codes and the Harnett County Zoning Ordinance I state the information on the above contractors is correct as known to me and that by signing below I have obtained all subcontractors permission to obtain these permits and if any changes occur including listed contractors site plan number of bedrooms building and trade plans Environmental Health permit changes or proposed use changes I certify it is my responsibility to notify the Harnett County Central Permitting Department of any and all changes EXPIRED PERMIT FEES - 6 Months to 2 years permit re-issue fee is \$150 00 After 2 years re-issue fee is as per current fee schedule 12/1/2020 Signature of Owner/Contractor/Officer(s) of Corporation Affidavit for Worker's Compensation N C G S 87-14 The undersigned applicant being the Officer/Agent of the Contractor or Owner **General Contractor** Do hereby confirm under penalties of perjury that the person(s) firm(s) or corporation(s) performing the work set forth in the permit Has three (3) or more employees and has obtained workers compensation insurance to cover them Has one (1) or more subcontractors(s) and has obtained workers compensation insurance to cover them Has one (1) or more subcontractors(s) who has their own policy of workers compensation insurance covering themselves Has no more than two (2) employees and no subcontractors While working on the project for which this permit is sought it is understood that the Central Permitting Department issuing the permit may require certificates of coverage of worker's compensation insurance prior to issuance of the permit and at any time during the permitted work from any person firm or corporation carrying out the work Company On Name NC SOLAR NOW Inc

Sign w/Title /

Permit Coordinator Date 12/1/2020

nitial	Application	Date:	

Application #	

CU#

COUNTY OF HARNETT RESIDENTIAL LAND USE APPLICATION

Central Permitting

108 E. Front Street, Lillington, NC 27546

Phone: (910) 893-7525 ext:2 Fax: (910) 893-2793 www.harnett.org/permits

A RECORDED SURVEY MAP, RECORDED DEED (OR OFFER TO PURCHASE) & SITE PLAN ARE REQUIRED WHEN SUBMITTING A LAND USE APPLICATION LANDOWNER:____ Mailing Address: State: Zip: Contact No: Email: APPLICANT*: Mailing Address:_____ City: _____ State: ___ Zip: ____ Contact No: _____ Email: ____ *Please fill out applicant information if different than landowner CONTACT NAME APPLYING IN OFFICE: PROPERTY LOCATION: Subdivision: _____ Lot #:____ Lot Size: State Road #_____ State Road Name: _____ _____ Map Book & Page: _____/ PIN: Parcel: Zoning:______ Flood Zone:_____ Watershed:_____ Deed Book & Page:____ / ____Power Company*: _____ PROPOSED USE: Monolithic SFD: (Size ____x ___) # Bedrooms: __ # Baths: __ Basement(w/wo bath): ___ Garage: ___ Deck: ___ Crawl Space: ___ Slab: ___ Slab: ___ (Is the bonus room finished? (___) yes (___) no w/ a closet? (___) yes (___) no (if yes add in with # bedrooms) Mod: (Size ____x ___) # Bedrooms ___ # Baths ___ Basement (w/wo bath) ___ Garage: ___ Site Built Deck: ___ On Frame ___ Off Frame (Is the second floor finished? (___) yes (___) no Any other site built additions? (___) yes (___) no Manufactured Home: ___SW __DW __TW (Size____x ___) # Bedrooms: ____ Garage: ___(site built?___) Deck: ___(site built?___) Duplex: (Size ____x ___) No. Buildings: _____ No. Bedrooms Per Unit: _____ Home Occupation: # Rooms: Use: Hours of Operation: #Employees: Closets in addition? () yes () no Addition/Accessory/Other: (Size x) Use: Water Supply: _____ County ____ Existing Well _____ New Well (# of dwellings using well ______) *Must have operable water before final Sewage Supply: _____ New Septic Tank (Complete Checklist) _____ Existing Septic Tank (Complete Checklist) _____ County Sewer Does owner of this tract of land, own land that contains a manufactured home within five hundred feet (500') of tract listed above? (___) yes (___) no Does the property contain any easements whether underground or overhead () yes () no Structures (existing or proposed): Single family dwellings: _____ Manufactured Homes:_____ Other (specify):_____ **Required Residential Property Line Setbacks:** Comments: Front Minimum_____ Actual____ Rear Closest Side Sidestreet/corner lot

Nearest Building on same lot

SPECIFIC DIRECTIONS TO THE PROPERTY FROM LILLINGTON:		
If normite are granted I garee to conform to all ordinances and laws of the Chats of Newton	Constitution and the second second the second secon	ta a section of the section of
If permits are granted I agree to conform to all ordinances and laws of the State of North I hereby state that forego∤ng statements are accurate and correct to the best of my knowle	carolina regulating such work and the specificat edge. Permit subject to revocation if false inform	ions of plans submitted nation is provided.
Sid to Nethernall	12/1/2020	,
Signature of Owner's Agent	Date	

^{***}It is the owner/applicants responsibility to provide the county with any applicable information about the subject property, including but not limited to: boundary information, house location, underground or overhead easements, etc. The county or its employees are not responsible for any incorrect or missing information that is contained within these applications.***

^{**}This application expires 6 months from the initial date if permits have not been issued**



	PV MATERIAL SUMMARY: DI	STRIBUTOR	
Ø	Q.PEAK DUO BLK-G6+335	29	
Part of	P340	29	
	SE10000H-US000BNU4	1	1
	SE-CELL-B-R05-US-S-S2	1	R
	XR-10-168B	4	
	XR-10-204B	10	I
1	XR-10-SPLC-M1	6	
	UFO-CL-01-B1	70	
	UFO-STP-32MM-B1	24	
K	XR-LUG-03-A1	6	
	4 IN QB1	55	1
	GC66803 Geocel Sealant	4	(
	SOLADECK 0799-5B	3	













CLIENT INFO

ANDREW BOWMAN 180 LYNCH AVENUE LILLINGTON,NC 27546

PROJECT INFO

DC INPUT:	9.72 kW
AC EXPORT:	10.00 kW
DOLINSPT, METHOD:	OPTION 2

CODE REFERENCES

NATION ELECTRICAL CODE v. 2017
NC FIRE PROTECTION CODE v. 2018
NC BUILDING CODE v. 2018
NC RESIDENTIAL CODE v. 2018
ACSE v. 7-10

1	CLIFFT IVID EV	
	SNOW:	15 PSF
	EXPOSURE:	В
	RISK CATEGORY:	11
	WIND SEED.	11/ /VIF11

SITE CONDITIONS

SHEET INDEX


PV-1: COVER SHEET
PV-2: PV STRUCTURAL
PV-3: PV ELECTRICAL
PV-4: PV EQUIPMENT LABELS
PV-5: PV INSTALL GUIDE

DESIGNER INFO

DESIGNER	CRM
ENGINEER	AWK
DATE	11/14/2020
VERSION	P1

PV SYSTEM COVER PAGE

PV-1.1




-QUICKBOLT ROOF HOOKS

STATEMENT OF STRUCTURAL COMPLIANCE

THE EXISTING ROOF STRUCTURE HAS BEEN DESIGNED TO SUPPORT THE ADDITIONAL LOADS OF THE PROPOSED PV SYSTEM. IN ADDITION, THE RACKING AND FASTENING SYSTEM SHALL BE CAPABLE OF SECURING THE SYSTEM TO THE STRUCTURE UNDER DESIGN CONDITIONS WHEN INSTALLED PROPERLY AND IN ACCORDANCE WITH THE RACKING AND FASTENING ARRANGEMENT DETAILED WITHIN THESE DRAWINGS.


NAME: ANDREW W. KING, PE

SIGNED:



PV MODULE FRAME IRONRIDGE UNIVERSAL FASTENING OBJECT IRONRIDGE RAIL IRONRIDGE RAIL	IRONRIDGE STOPPER SLEEVE INTEGRATED HARDWARE BONDING PV MODULE FRAME IRONRIDGE RAIL	PV MODULE BY OTHERS IRONRIDGE RAIL INTEGRATED HARDWARE BONDING BUILDING STRUCTURE QUICKBOLT
---	---	--

1 ROOF FASTENER DETAIL NOT TO SCALE



PV MODULES		
MAKE	HANWHA Q-CELL	
MODEL	Q.PEAK DUO BLK-G6 335	
WIDTH	40.6"	
LENGTH	68.5"	
THICKNESS	32 mm	
WEIGHT	43.9 LBS.	
ARRAY AREA	431 SQFT.	
ARRAY WEIGHT	1078 LBS.	

ROOF SUMMARY		
STRUCTURE:		
TYPE	TRUSSES	
MATERIAL	SOUTHERN PINE #2	
SIZE	2" X 6"	
SPACING	24 IN O.C.	
TOTAL SPAN	170 IN	
PITCH	12/12	
DENSITY	30 LBS./CU.FT.	
DECKING:		
TYPE	OSB	
MATERIAL	COMPOSITE	
THICKNESS	7/16 IN	
WEIGHT	1.60 LBS/SQFT	
ROOFING:		
TYPE	ARCH SHINGLE	
MATERIAL	ASPHAULT	
WEIGHT	2.3 LBS./SQFT.	

ROOF MOUNT SUMMARY		
MAXIMUM	MOUNT SPACING	RAIL OVERHAN
WIND ZONE 1	72 IN	19 IN
WIND ZONE 2	48 IN	19 IN
WIND ZONE 3	48 IN	19 IN

ROOF LOADING		
GROUND SNOW LOAD:	15 LBS./SQFT.	
LIVE LOAD	20 LBS./SQFT.	
DEAD LOAD		
ROOFING	3.9 LBS/SQFT.	
PV ARRAY	2.5 LBS./SQFT.	
TOTAL	6.4 LBS./SQFT.	
WIND LOAD:		
UPLIFT ZONE 1	-26.9 LBS./SQFT.	
UPLIFT ZONE 2	-32.4 LBS./SQFT.	
UPLIFT ZONE 3	-32.4 LBS./SQFT.	
DOWNWARD	24.7 LBS./SQFT.	
FASTENER LOAD:		
UPLIFT ZONE 1	-443 LBS.	
UPLIFT ZONE 2	-356 LBS	
UPLIFT ZONE 3	-356 LBS	
DOWNWARD	407 LBS	

ROOF MOUNT & FASTENER		
ROOF MOUNT:		
MAKE	QUICKBOLT	
MODEL	4 IN QB1	
MATERIAL	STAINLESS / EPDM	
FASTENER:		
MAKE	SOLAR ROOF HOOK	
MODEL	HANGER BOLT	
MATERIAL	304 SS	
SIZE	5/16-18 X 5-1/4"	
GENERAL:		
WEIGHT	0.56 LBS.	
FASTENERS PER MOUNT	1	
MAX. PULL-OUT FORCE	960.0 LBS.	
SAFETY FACTOR	2	
DESIGN PULL-OUT FORCE	480.0 LBS.	

MOUNTING RAILS	
MAKE	IRONRIDGE
MODEL	XR10
MATERIAL	ALUMINUM
WEIGHT	0.425 LBS/IN
SPACING	34 IN





CLIENT INFO	
ANDREW BOWMAN	
180 LYNCH AVENUE	
LILLINGTON,NC 27546	

PROJECT INFO	
DC INPUT:	9.72 kW
AC EXPORT:	10.00 kW
DOLINSPT, METHOD:	OPTION 2

CODE REFERENCES
NATION ELECTRICAL CODE v. 2017 NC FIRE PROTECTION CODE v. 2018 NC BUILDING CODE v. 2018 NC RESIDENTIAL CODE v. 2018
NC FIRE PROTECTION CODE v. 2018
NC BUILDING CODE v. 2018
NC RESIDENTIAL CODE v. 2018
ACSE v. 7-10

	SHEET INDEX		
	SNOW:	15 PSF	
	EXPOSURE:	В	
1	RISK CATEGORY:	11	
1	WIND SPEED:	117 MPH	
	SITE CONDITIONS		
ł			


PV-2:	PV STRUCTURAL
PV-3:	PV ELECTRICAL
PV-4:	PV EQUIPMENT LABELS
PV-5:	PV INSTALL GUIDE

PV-1: COVER SHEET

DESIGNER INFO	
DESIGNER	CRM
ENGINEER	AWK
DATE	11/14/2020
VERSION	P1

PV SYSTEM STRUCTURAL

PV-2.1




STATEMENT OF STRUCTURAL COMPLIANCE


THE EXISTING ROOF STRUCTURE HAS BEEN DESIGNED TO SUPPORT THE ADDITIONAL LOADS OF THE PROPOSED PV SYSTEM. IN ADDITION, THE RACKING AND FASTENING SYSTEM SHALL BE CAPABLE OF SECURING THE SYSTEM TO THE STRUCTURE UNDER DESIGN CONDITIONS WHEN INSTALLED PROPERLY AND IN ACCORDANCE WITH THE RACKING AND FASTENING ARRANGEMENT DETAILED WITHIN THESE DRAWINGS.

NAME:	ANDREW W. KING, PE	
SIGNED:		


ROOF STRUCTURAL MEMBER (TYP.)

16" O.C.





ROOF FASTENER DETAIL NOT TO SCALE



ROOF B ARRAY LAYOUT
1/8" = 1'-0"

PV MODULES		
MAKE	HANWHA	
MODEL	Q.PEAK DUO BLK-G6+335	
WIDTH	40.60 IN	
LENGTH	68.50 IN	
THICKNESS	32 MM	
WEIGHT	43.90 LBS.	
ARRAY AREA	97 SQFT.	
ARRAY WEIGHT	241 LBS.	

ROOF SUMMARY		
STRUCTURE:		
TYPE	RAFTERS	
MATERIAL	SOUTHERN PINE #2	
SIZE	2 X 8	
SPACING	16 IN O.C.	
EFFECTIVE SPAN	114 IN	
PITCH	12/12	
DENSITY	30 LBS./CU.FT.	
DECKING:		
TYPE	OSB	
MATERIAL	COMPOSITE	
THICKNESS	7/16 IN	
WEIGHT	1.60 LBS/SQFT	
ROOFING:		
TYPE	ASPHALT SHINGLE	
MATERIAL	ASPHALT	
WEIGHT	2.30 LBS./SQFT.	

ROOF MOUNT SUMMARY					
MAXIMUM (IN)	MOUNT SPACING	RAIL OVERHANG			
WIND ZONE 1	64 IN	19 IN			
WIND ZONE 2	48 IN	19 IN			
WIND ZONE 3	48 IN	19 IN			

ROOF LOADING				
GROUND SNOW LOAD:	15 LBS./SQFT.			
LIVE LOAD	20 LBS./SQFT.			
DEAD LOAD				
ROOFING	3.9 LBS/SQFT.			
PV ARRAY	2.5 LBS./SQFT.			
TOTAL	6.4 LBS./SQFT.			
WIND LOAD:				
UPLIFT ZONE 1	-26.9 LBS./SQFT.			
UPLIFT ZONE 2	-32.4 LBS./SQFT.			
UPLIFT ZONE 3	-32.4 LBS./SQFT.			
DOWNWARD	24.7 LBS./SQFT.			
FASTENER LOAD:				
UPLIFT ZONE 1	-407 LBS.			
UPLIFT ZONE 2	-368 LBS			
UPLIFT ZONE 3	-368 LBS			
DOWNWARD	374 LBS			

ROOF MOUNT & FASTENER				
ROOF MOUNT:				
MAKE	QUICKBOLT			
MODEL	4 IN QB1			
MATERIAL	STAINLESS / EPDM			
FASTENER:				
MAKE	SOLAR ROOF HOOK			
MODEL	HANGER BOLT			
MATERIAL	304 SS			
SIZE	5/16-18 X 5-1/4"			
GENERAL:				
WEIGHT	0.56 LBS.			
FASTENERS PER MOUNT	1			
MAX. PULL-OUT FORCE	960.0 LBS.			
SAFETY FACTOR	2			
DESIGN PULL-OUT FORCE	480.0 LBS.			

MOUNTING RAILS			
MAKE IRONRIDGE			
XR10			
ALUMINUM			
0.425 LBS/IN			
SPACING 34 IN			





CLIENT INFO
ANDREW BOWMAN
180 LYNCH AVENUE
LILLINGTON NC 27546

	PROJECT INFO				
Ì	DC INPUT:	9.72 kW			
	AC EXPORT:	10.00 kW			
	DOLINSPT METHOD:	OPTION 2			

Ĺ	CODE REFERE	:NCES				
BS./SQFT.		NATION ELECTRICAL CODE v. 2017				
BS./SQFT.	NC FIRE PROTECTION CO					
	NC BUILDING CODE v. 2	018				
_BS/SQFT.	NC RESIDENTIAL CODE v. 2018					
.BS./SQFT.	ACSE v. 7-10					
.BS./SQFT.						
	SITE CONDITIONS					
LBS./SQFT.	WIND SPEED: 117 MPH					
LRS /SOFT	TTILL SI EED.					

	WIND SPEED:	117 MPH			
_	RISK CATEGORY:	II			
_	EXPOSURE:	В			
_	SNOW:	15 PSF			
	SHFFT INDEX				
_	OTTLET II VD L/V				

PV-1:	COVER SHEET
PV-2:	PV STRUCTURAL
PV-3:	PV ELECTRICAL

PV-4: PV EQUIPMENT LABELS PV-5: PV INSTALL GUIDE

DESIGNER INFO		
DESIGNER	CRM	
ENGINEER	AWK	
DATE	11/14/2020	
VERSION	P1	

PV SYSTEM STRUCTURAL

PV-2.2

	CONDUCTOR SCHEDULE									
TAG	CURRENT CARRYING CONDUCTORS		GROUNDING CONDUCTORS		CONDUIT/RACEWAY			NOTES		
IAU	QTY.	SIZE	INSULATION	QTY.	SIZE	INSULATION	QTY.	SIZE	LOCATION	NOILS
C1	4	10 AWG	PV WIRE	1	6 AWG	BARE	-	-	FREE AIR	1
C2	4	10 AWG	THWN	1	10 AWG	THWN	1	3/4"	EXT/INT	2,4
C3	3	6 AWG	THWN	1	10 AWG	THWN	1	3/4"	EXTERIOR	2,4
XC	-	-	-	-	-	-	-	-	-	3

- MANUFACTURER PROVIDED, UL LISTED WIRING HARNESS FOR USE ON EXPOSED ROOFS
- CONDUIT SIZE SHOWN IS CODE MINIMUM. LARGER SIZES ARE ALLOWED.
- EXISTING CONDUCTORS, FIELD VERIFY
 EQUIPMENT TERMINAL RATING SHALL BE A MINIMUM OF 75°C AT BOTH END OF CONDUCTOR

PV MODULE				
MAKE	HANWHA			
MODEL	Q.PEAK DUO BLK-G6+335			
NOM. POWER (PNOM)	335 WATTS			
NOM. VOLT. (VMPP)	33.6 VOLTS			
O.C. VOLT (VOC)	40.4 VOLTS			
MAX. SYS. VOLT.	1000 VOLTS			
NOM. CURR. (IMPP)	10.0 AMPS			
S.C. CURR. (ISC)	10.5 AMPS			
TEMP. COEF. (PMPP)	36 %/C			
TEMP. COEF. (Voc)	27 %/C			
MAX SERIES FUSE	20 AMPS			

SUB PANEL (EXISTING)		
MAKE	SQUARE D	
MODEL	QOC30UF	
ENCL. RATING	NEMA 1	
VOLT. RATING	240 VOLTS	
BUS RATING	200 AMPS	
UL LIST. (Y/N)	YES	
MAIN BREAKER (Y/N)	YES (NEW)	
MAIN BREAKER RATING	200 AMPS	

• INSTALL 200A MAIN BREAKER

MODULE OPTIMIZER		
MAKE	SOLAREDGE	
MODEL	P340	
DC INPUT:		
NOM. POWER	340 WATTS	
VOLT. RANGE	8 to 48	
MAX. CURR.	11.0 AMPS	
DC OUTPUT:		
NOM. POWER	340 WATTS	
MAX. VOLT.	60 VOLTS	
MAX. CURR.	15 AMPS	
MIN-MAX STRING	8-25 OPTIMIZERS	
UL LIST. (Y/N)	YES	

JUNCTION BOX		
MAKE	SOLADECK	
PROTECT. RATING	NEMA TYPE 3R	
UL LIST. (Y/N)	YES	


METER COMBO (EXISTING)		
MAKE	SQUARE D	
MODEL	0 0 3 2 8 6 7	
ENCL. RATING	NEMA 3R	
VOLT. RATING	240	
BUS RATING	200 AMPS	
UL LIST. (Y/N)	YES	
MAIN BREAKER (Y/N)	YES	
MAIN BREAKER RATING	200 AMPS	

- BACK-FEED SOLAR OUTPUT VIA 60A BREAKER AT THE OPPOSITE END OF THE BUS BAR FROM EXISTING POWER SOURCE
- DISCONNECT SWITCH

DC / AC INVERTER		
MAKE	SOLAREDGE	
MODEL	SE10000H-US000BNU4	
DC INPUT:		
MAX POWER	15500 WATTS	
VOLT. RANGE	400-480	
NOM. VOLT.	400 VOLTS	
MAX. CURRENT	27 AMPS	
STRING INPUTS	3 STRINGS	
AC OUTPUT:		
MAX. POWER	10000 WATTS	
NOM. POWER	10000 WATTS	
NOM. VOLT.	211-240-264	
MAX. CURR.	42.00 AMPS	
DC DISC. (Y/N)	YES	
RAPID SHUTDOWN (Y/N)	YES	
PROTECT. RATING	NEMA TYPE 4X	
UL LIST. (Y/N)	YES	
CONSUMPTION MONITOR	No	

AC DISCONNECT		
MAKE GENERIC		
MODEL NA		
ENCL. RATING NEMA 3R		
VOLT. RATING 240 VOLTS		
AMP RATING 60 AMPS		
UL LIST. (Y/N) YES		
FUSED (Y/N) NO		
FUSE RATING N/A		

- MAIN BREAKER SERVES AS SERVICE
- LOAD-BREAK RATED
- VISIBLE OPEN
- LOCKABLE IN OPEN POSITION
- INSTALL ADJACENT TO METER
 DISCONNECT TO BE READILY ACCESSIBLE
 TO UTILITY COMPANY PERSONNEL AT ALL TIMES



MAKE	SOLAREDGE	
MODEL	SE10000H-US000BNU4	
DC INPUT:		
MAX POWER	15500 WATTS	
VOLT. RANGE	400-480	
NOM. VOLT.	400 VOLTS	
MAX. CURRENT	27 AMPS	111111
STRING INPUTS	3 STRINGS	
AC OUTPUT:		
MAX. POWER	10000 WATTS	SE 1035
NOM. POWER	10000 WATTS	
NOM. VOLT.	211-240-264	O 25'46.
MAX. CURR.	42.00 AMPS	1,914
DC DISC. (Y/N)	YES	10000
) SHUTDOWN (Y/N)	YES	7.00
ROTECT. RATING	NEMA TYPE 4X	= / : °//SF
UL LIST. (Y/N)	YES	3
UMPTION MONITOR	No] # Y(033
		EL.XL
AC DISC	ONNECT	1 6 1/2 VG

NA NA	20,111,111
NEMA 3R	<i>W</i> 1
240 VOLTS	CLIENT INFO
60 AMPS	CLIENT INFO
YES	ANDREW BOWMAN
NO	180 LYNCH AVENUE
N/A	LILLINGTON,NC 27546

PROJECT INFO	
DC INPUT:	9.72 kW
AC EXPORT:	10.00 kW
DOLINSPT, METHOD:	OPTION 2

CODE REFERENCES

NATION ELECTRICAL CODE v. 2017 NC FIRE PROTECTION CODE v. 2018 NC BUILDING CODE v. 2018 NC RESIDENTIAL CODE v. 2018 ACSE v. 7-10

SITE CONDITIONS	
WIND SPEED:	117 MPH
RISK CATEGORY:	П
EXPOSURE:	В
 SNOW:	15 PSF

SHEET INDEX

PV-1: COVER SHEET PV-2: PV STRUCTURAL PV-3: PV ELECTRICAL PV-4: PV EQUIPMENT LABELS

PV-5:	PV INSTALL GUIDE
1	

DESIGNER INFO	
DESIGNER	CRM
ENGINEER	AWK
DATE	11/14/2020
VERSION	P1

PV SYSTEM ELECTRICAL

PV-3.1

ELECTRICAL SCHEMATIC

WARNING

ELECTRIC SHOCK HAZARD

TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

NEC 690.13 (B)
PLACE ON PV SYSTEM DISCONNECTING MEANS.

MARNING

POWER SOURCE **OUTPUT CONNECTION** DO NOT RELOCATE THIS **OVERCURRENT DEVICE**

NEC 705.12 (B)(2)(3)(b)
PLACE ADJACENT TO BACK-FED BREAKER

⚠WARNING

DUAL POWER SUPPLY

SOURCES: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM

NEC 705.12 (B)(3) PLACE ON ALL EQUIPMENT THAT IS SUPPLIED BY BOTH POWER SOURCES

WARNING: PHOTOVOLTAIC POWER SOURCE

NEC 690.31 (G)(3)&(4)
PLACE ON ALL JUNCTION BOXES, EXPOSED RACEWAYS, AND OTHER WIRING METHODS EVERY 10' AND ON EVERY SECTION SEPARATED BY ENCLOSURES, WALLS, PARTITIONS, CEILINGS, OR FLOORS.


RAPID SHUTDOWN **SWITCH FOR SOLAR PV SYSTEM**

PLACE ON RAPID SHUTDOWN SWITCH OR EQUIPMENT VITH INTEGRATED RAPID SHUTDOWN *REFLECTIVE

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD

IN THE ARRAY



NEC 690.56 (C)(1)(a)

PLACE WITHIN 3FT OF SERVICE DISCONNECTING MEANS TO WHICH THE PV SYSTEMS ARE CONNECTED AND SHALL INDICATE THE LOCATIONS OF RAPID SHUTDOWN SWITCHES

PV SYSTEM DISCONNECT

NEC 690.13 (B) PLACE ON PV SYSTEM DISCONNECTING MEANS.

∴ WARNING

DO NOT ADD LOADS

PLACE ON METER COMBO

PHOTOVOLTAIC POWER SOURCE

OPERATING AC VOLTAGE 240 \

MAXIMUM OPERATING AC OUTPUT CURRENT

> NEC 690 54 PLACE ON INTERCONNECTION

DIRECT CURRENT PHOTOVOLTAIC POWER SOURCE

MAXIMUM VOLTAGE 600 VDC MAX CIRCUIT CURRENT 30.0 AMPS

NEC 690 53

PLACE ON ALL DC DISCONNECTING MEANS

WARNING

THIS EQUIPMENT FED BY MULTIPLE SOURCES THE TOTAL RATING OF ALL OVERCURRENT DEVICES EXCLUDING MAIN SUPPLY OVERCURRENT DEVICE SHALL NOT EXCEED THE AMPACITY OF THE BUSBAR.

> NEC 705 12 (B)(2)(c) PLACE ON METER COMBO

LABEL NOTES

- 1. LABELS SHOWN ARE HALF THEIR ACTUAL REQUIRED SIZE.
- LABEL MATERIAL SHALL BE SUITABLE FOR THE EQUIPMENT 2. ENVIRONMENT.
- DC CONDUIT SHALL BE MARKED WITH REQUIRED LABEL EVERY 10 3.
- LABELS WILL BE APPLIED IN ACCORDANCE WITH THE NEC. SOME LABELS MAY NOT BE NECESSARY.

DC WIRING NOTES

- CONDUCTORS SHALL BE COPPER, RATED AT NOT LESS THAN 600 VOLTS FOR RESIDENTIAL CONSTRUCTION AND NOT LESS THAN 1000 VOLTS FOR COMMERCIAL CONSTRUCTION.
- MINIMUM SIZE SHALL BE #10 AWG UNLESS OTHERWISE NOTED ON THE DRAWINGS.
- EXPOSED WIRING CONDUCTOR INSULATION SHALL BE TYPE PV WIRE, USE-2, OR RHW-2 WHERE THE OUTER LAYER OF THE INSULATION IS UV, SUNLIGHT, AND MOISTURE RESISTANT.
- EXTERIOR WIRING CONDUCTOR INSULATION SHALL BE TYPE THWN-2 AND INSTALLED IN ELECTRICAL METALLIC TUBING(EMT) OR RIGID POLYVINYL CHLORIDE CONDUIT(PVC). ALTERNATIVELY, METAL CLAD CABLE(MC) CAN BE USED AS WELL WHEN RATED FOR USE IN WET LOCATIONS.
- INTERIOR WIRING CONDUCTOR INSULATION SHALL BE TYPE THHN-2 AND INSTALLED IN ELECTRICAL METALLIC TUBING(EMT), FLEXIBLE METAL CONDUIT(FMC), OR METAL CLAD CABLE(MC).
- USE SCHEDULE 40 PVC OUTDOORS WHERE NOT SUBJECT TO PHYSICAL DAMAGE OR BELOW FLOOR SLAB. USE SCHEDULE 80 PVC OUTDOORS WHERE SUBJECT TO PHYSICAL DAMMAGE
- MINIMUM CONDUIT SIZE TO BE 1/2".
- WIRING METHODS TO CONFORM TO ARTICLES 330, 334, 348, 350, 352, 356, AND 358 OF THE 2017 NEC.

AC WIRING NOTES

- CONDUCTORS SHALL BE COPPER RATED AT NOT LESS THAN 600 VOLTS.
- MINIMUM SIZE SHALL BE #14 AWG UNLESS OTHERWISE NOTED ON THE 2. DRAWINGS
- EXTERIOR WIRING CONDUCTOR INSULATION SHALL BE TYPE THWN AND INSTALLED IN ELECTRICAL METALLIC TUBING(EMT), RIGID POLYVINYL CHLORIDE CONDUIT(PVC), LIQUID-TIGHT FLEXIBLE METAL CONDUIT(LFMC), OR LIQUID-TIGHT FLEXIBLE NON-METALLIC CONDUIT(LFNC). ALTERNATIVELY, METAL CLAD CABLE(MC) CAN BE USED AS WELL WHEN RATED FOR USE IN WET LOCATIONS.
- INTERIOR WIRING CONDUCTOR INSULATION SHALL BE TYPE THHN AND INSTALLED IN ELECTRICAL METALLIC TUBING(EMT), FLEXIBLE METAL CONDUIT(FMC), METAL CLAD CABLE(MC), OR ROMEX.
- USE SCHEDULE 40 PVC OUTDOORS WHERE NOT SUBJECT TO PHYSICAL DAMAGE OR BELOW FLOOR SLAB. USE SCHEDULE 80 PVC OUTDOORS WHERE SUBJECT TO PHYSICAL DAMMAGE
- MINIMUM CONDUIT SIZE TO BE 1/2".
- WIRING METHODS TO CONFORM TO ARTICLES 330, 334, 348, 350, 352, 356, AND 358 OF THE 2017 NEC.

CONSTRUCTION NOTES

- ALL WORK IS TO BE PERFORMED IN ACCORDANCE WITH THE NEC, STATE, AND LOCAL APPLICABLE CODES. FOLLOW MANUFACTURER'S INSTALLATION INSTRUCTIONS, BEST
- PRACTICES, AND SPECIFICATIONS. ENSURE REQUIRED MAINTENANCE ACCESS AND CLEARANCES ARE
- MAINTAINED.
- WIRES SHALL BE RATED AND LABELED "SUNLIGHT RESISTANT" WHERE EXPOSED TO AMBIENT CONDITIONS.
- FUSES 0 600 AMPS SHALL BE UL CLASS "RK-1" LOW PEAK DUAL ELEMENT TIME DELAY WITH 200,000 AMPERE INTERRUPTING RATING AS MANUFACTURED BY BUSSMANN, UNLESS NOTED OTHERWISE.
- ALL TERMINALS/LUGS SHALL BE 75° RATED. ALL TERMINALS, SPLICING CONNECTORS, LUGS, ETC SHALL BE IDENTIFIED FOR USE WITH THE MATERIAL (CU/AL) OF THE CONDUCTOR AND SHALL BE PROPERLY INSTALLED
- PROVIDE A PULLWIRE IN ALL EMPTY CONDUITS.
- ALL PENETRATIONS THROUGH EXTERIOR ROOFS SHALL BE FLASHED IN A WATERPROOF MANNER.
- ALL PENETRATIONS THROUGH ATTIC FIRE BARRIERS SHALL BE SEALED WITH FIRE-BARRIER SEALANT CAULK.
- 10. SUPPORT ALL CONDUIT AND EQUIPMENT IN ACCORDANCE W/ NEC. ANY SUSPENDED MATERIALS SHALL BE DIRECTLY SUPPORTED BY THE **BUILDING STRUCTURE.**
- 11. METAL CONDUIT COUPLINGS CAN BE COMPRESSION TYPE, THREADED, OR BE SET-SCREW TYPE. PLASTIC CONDUIT COUPLINGS TO BE SOCKET GLUED TYPE.
- 12. A COMPLETE GROUNDING SYSTEM SHALL BE PRESENT OR PROVIDED AND INSTALLED IN ACCORDANCE WITH ARTICLE 250 OF THE NEC, AND AS SHOWN ON THE DRAWINGS.
- 13. EACH ELECTRICAL APPLIANCE SHALL BE PROVIDED WITH A NAMEPLATE GIVING THE IDENTIFYING NAME AND THE RATING IN VOLTS AND AMPERES, OR VOLTS AND WATTS. IF THE APPLIANCE IS TO BE USED ON A SPECIFIC FREQUENCY OR FREQUENCIES, IT SHALL BE SO MARKED. WHERE MOTOR OVERLOAD PROTECTION EXTERNAL TO THE APPLIANCES IS REQUIRED, THE APPLIANCE SHALL BE SO MARKED.
- 14. WHERE APPLICABLE, GROUNDING ELECTRODE CONDUCTOR TO BE CONTINUOUS. GROUNDING CRIMPS TO BE IRREVERSIBLE.
- 15. PHOTOVOLTAIC SYSTEMS SHALL BE PERMANENTLY MARKED AT VARIOUS EQUIPMENT LOCATIONS TO IDENTIFY THAT A PHOTOVOLTAIC SYSTEM IS INSTALLED AND THAT VARIOUS DANGERS ARE PRESENT.
- 16. EACH PHOTOVOLTAIC SYSTEM DISCONNECTING MEANS SHALL BE PERMANENTLY MARKED TO IDENTIFY IT AS A PHOTOVOLTAIC SYSTEM DISCONNECT.
- 17. WHERE ALL TERMINALS OF A DISCONNECTING MEANS MAY BE ENERGIZED IN THE OPEN POSITION, A WARNING SIGN SHALL BE MOUNTED ON OR ADJACENT TO THE DISCONNECT.
- 18. A PERMANENT LABEL FOR THE DIRECT-CURRENT PHOTOVOLTAIC POWER SOURCE SHALL BE PROVIDED AT THE DC DISCONNECT MEANS.
- 19. A PERMANENT PLAQUE OR DIRECTORY, DENOTING ALL ELECTRIC POWER SOURCES SERVING THE PREMISES, SHALL BE INSTALLED AT EACH SERVICE EQUIPMENT LOCATION AND AT LOCATIONS OF ALL POWER PRODUCTION SOURCES.
- 20. ALL MODULE GROUND CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH NEC SECTION 690.4 (C)
- 21. A NORTH CAROLINA REGISTERED DESIGN PROFESSIONAL WILL BE REQUIRED TO SEAL THE STRUCTURAL DESIGN AT THE TIME OF PERMIT APPLICATION IF ANY OF THE FOLLOWING EXIST AND ARE ATTESTED TO BY THE APPLICANT:
 - I. THE WEIGHT OF THE PV SYSTEM EXCEEDS THREE (3) POUNDS PER SQUARE FOOT(PSF)
 - II. THE ROOF POSSESSES MORE THAN ONE (1) LAYER OF ASPHALT
 - III. THE ROOFING MATERIAL CONSISTS OF A TYPE OTHER THAN ASPHALT SHINGLES OR METAL
 - IV. THE ROOF IS LOCATED IN A 140 MPH OR GREATER WIND ZONE





CLIENT INFO

ANDREW BOWMAN 80 LYNCH AVENUE ILLINGTON.NC 27546

PROJECT INFO

DC INPUT:	9.72 kW
AC EXPORT:	10.00 kW
DOLINSPT, METHOD:	OPTION 2
	-

CODE REFERENCES

NATION ELECTRICAL CODE v. 2017 NC FIRE PROTECTION CODE v. 2018 NC BUILDING CODE v. 2018 NC RESIDENTIAL CODE v. 2018 ACSE v. 7-10

SITE CONDITIONS

WIND SPEED:	117 MPH
RISK CATEGORY:	П
EXPOSURE:	В
SNOW:	15 PSF

SHEET INDEX

V-1: COVER SHEET PV-2: PV STRUCTURAL


PV-3: PV ELECTRICAL V-4: PV EOUIPMENT LABELS

PV-5: PV INSTALL GUIDE

DESIGNER INFO

DESIGNER	CRM
ENGINEER	AWK
DATE	11/14/2020
VERSION	P1

PV SYSTEM **EQUIPMENT LABELS**



© 2019 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.





CLIENT INFO

ANDREW BOWMAN 180 LYNCH AVENUE LILLINGTON,NC 27546

PROJECT INFO

DC INPUT:	9.72 kW
AC EXPORT:	10.00 kW
DOLINSPT, METHOD:	OPTION 2

CODE REFERENCES

NATION ELECTRICAL CODE v. 2017 NC FIRE PROTECTION CODE v. 2018 NC BUILDING CODE v. 2018 NC RESIDENTIAL CODE v. 2018 ACSE v. 7-10

SITE CONDITIONS

WIND SPEED): 117 MPH
RISK CATEGO	ORY:
EXPOSURE:	В
SNOW:	15 PSF

SHEET INDEX

PV-1: COVER SHEET
PV-2: PV STRUCTURAL
PV-3: PV ELECTRICAL
PV-4: PV EQUIPMENT LABELS

DESIGNER INFO

DESIGNER	CRM
ENGINEER	AWK
DATE	11/14/2020
VERSION	P1

PV SYSTEM INSTALL **GUIDE**

PV-5.1







Q.ANTUM TECHNOLOGY: LOW LEVELIZED COST OF ELECTRICITY

Higher yield per surface area, lower BOS costs, higher power classes, and an efficiency rate of up to 19.5%.



INNOVATIVE ALL-WEATHER TECHNOLOGY

Optimal yields, whatever the weather with excellent low-light and temperature behavior.



ENDURING HIGH PERFORMANCE

Long-term yield security with Anti LID and Anti PID Technology 1, Hot-Spot Protect and Traceable Quality $Tra.Q^{TM}$.



EXTREME WEATHER RATING

High-tech aluminum alloy frame, certified for high snow (5400 Pa) and wind loads (4000 Pa).



A RELIABLE INVESTMENT

Inclusive 25-year product warranty and 25-year linear performance warranty².



STATE OF THE ART MODULE TECHNOLOGY

Q.ANTUM DUO combines cutting edge cell separation and innovative wiring with Q.ANTUM Technology.


THE IDEAL SOLUTION FOR:





 $^{^{\}rm 1}$ APT test conditions according to IEC/TS 62804-1:2015, method B (–1500 V, 168 h)

² See data sheet on rear for further information




ELECTRICAL CHARACTERISTICS

PO	VER CLASS			330	335	340	345		
MIN	INIMUM PERFORMANCE AT STANDARD TEST CONDITIONS, STC1 (POWER TOLERANCE +5 W / -0 W)								
	Power at MPP ¹	P _{MPP}	[W]	330	335	340	345		
_	Short Circuit Current ¹	I _{sc}	[A]	10.41	10.47	10.52	10.58		
mun	Open Circuit Voltage ¹	V _{oc}	[V]	40.15	40.41	40.66	40.92		
Mini	Current at MPP	MPP	[A]	9.91	9.97	10.02	10.07		
2	Voltage at MPP	V_{MPP}	[V]	33.29	33.62	33.94	34.25		
	Efficiency ¹	η	[%]	≥18.4	≥18.7	≥19.0	≥19.3		
MIN	IMUM PERFORMANCE AT NORMAL	OPERATING COND	OITIONS, NMC)T ²					
	Power at MPP	P _{MPP}	[W]	247.0	250.7	254.5	258.2		
트	Short Circuit Current	I _{sc}	[A]	8.39	8.43	8.48	8.52		
Minimu	Open Circuit Voltage	V _{oc}	[V]	37.86	38.10	38.34	38.59		
	Current at MPP	MPP	[A]	7.80	7.84	7.89	7.93		
	Voltage at MPP	V _{MPP}	[V]	31.66	31.97	32.27	32.57		

¹Measurement tolerances P_{MPP} ±3%; I_{SC}; V_{OC} ±5% at STC: 1000 W/m², 25±2°C, AM 1.5 according to IEC 60904-3 • ²800 W/m², NMOT, spectrum AM 1.5


Q CELLS PERFORMANCE WARRANTY



At least 98% of nominal power during first year. Thereafter max. 0.54% degradation per year. At least 93.1% of nominal power up to 10 years. At least 85% of nominal power up to 25 years.

All data within measurement tolerances. Full warranties in accordance with the warranty terms of the Q CELLS sales organization of your respective country.

PERFORMANCE AT LOW IRRADIANCE



Typical module performance under low irradiance conditions in comparison to STC conditions (25 °C, 1000 W/m²)

TEMPERATURE COEFFICIENTS							
Temperature Coefficient of I _{SC}	α	[%/K]	+0.04	Temperature Coefficient of Voc	β	[%/K]	-0.27
Temperature Coefficient of Pupa	v	[%/K]	-0.36	Normal Module Operating Temperature	NMOT	[°F]	109+5.4 (43+3°C)

PROPERTIES FOR SYSTEM DESIGN

Maximum System Voltage V _{SYS}	[V]	1000 (IEC)/1000 (UL)	Safety Class	II
Maximum Series Fuse Rating	[A DC]	20	Fire Rating based on ANSI/UL 1703	C (IEC)/TYPE 2 (UL)
Max. Design Load, Push / Pull ³	[lbs/ft ²]	75 (3600 Pa) / 55 (2667 Pa)	Permitted Module Temperature	-40°F up to +185°F
Max. Test Load, Push/Pull ³	[lbs/ft²]	113 (5400 Pa)/84 (4000 Pa)	on Continuous Duty	(-40°C up to +85°C)
³ See Installation Manual			•	

QUALIFICATIONS AND CERTIFICATES

PACKAGING INFORMATION

UL 1703, VDE Quality Tested, CE-compliant, IEC 61215:2016, IEC 61730:2016, Application Class II, U.S. Patent No. 9,893,215 (solar cells)







Number of Modules per Pallet	32
Number of Pallets per 53' Trailer	28
Number of Pallets per 40' HC-Container	24
Pallet Dimensions (L×W×H)	71.5 × 45.3 × 48.0 in (1815 × 1150 × 1220 mm)
Pallet Weight	1505lbs (683kg)

Note: Installation instructions must be followed. See the installation and operating manual or contact our technical service department for further information on approved installation and use of this product.

Specifications subject to technical changes © Q CELLS Q.PEAK DUO BLK-G6+_330-345_2019-06_Rev01_NA

Power Optimizer

For North America

P320 / P340 / P370 / P400 / P405 / P505





POWER OPTIMIZER

PV power optimization at the module-level

- Specifically designed to work with SolarEdge inverters
- Up to 25% more energy
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch losses, from manufacturing tolerance to partial shading
- Flexible system design for maximum space utilization

- / Fast installation with a single bolt
- Next generation maintenance with modulelevel monitoring
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System (PVRSS)
- Module-level voltage shutdown for installer and firefighter safety



/ Power Optimizer **For North America**

P320 / P340 / P370 / P400 / P405 / P505

Optimizer model (typical module compatibility)	P320 (for 60-cell modules)	P340 (for high- power 60-cell modules)	P370 (for higher- power 60 and 72-cell modules)	P400 (for 72 & 96- cell modules)	P405 (for thin film modules)	P505 (for higher current modules)			
INPUT	'	•	'	•	•				
Rated Input DC Power ⁽¹⁾	320	340	370	400	405	505	W		
Absolute Maximum Input Voltage (Voc at lowest temperature)	4	18	60	80	125 ⁽²⁾	87(2)	Vdc		
MPPT Operating Range	8 -	48	8 - 60	8 - 80	12.5 - 105	12.5 - 87	Vdc		
Maximum Short Circuit Current (Isc)		11		10	0.1	14	Adc		
Maximum DC Input Current		13.75		12	2.5	17.5	Adc		
Maximum Efficiency			99	9.5			%		
Weighted Efficiency			98.8			98.6	%		
Overvoltage Category				I					
OUTPUT DURING OPER	RATION (POWE	R OPTIMIZER C	ONNECTED TO	OPERATING SO	LAREDGE INVE	RTER)			
Maximum Output Current			1	5			Adc		
Maximum Output Voltage		6	50		8	5	Vdc		
INVERTER OFF) Safety Output Voltage per Power Optimizer			1 ±	0.1			Vdc		
STANDARD COMPLIAN	ICE								
EMC		FC	CC Part15 Class B, IEC6	51000-6-2, IEC61000-6	5-3				
Safety			IEC62109-1 (class	s II safety), UL1741					
Material			UL94 V-0 ,	UV Resistant					
RoHS			Y	es					
INSTALLATION SPECIFI	CATIONS								
Maximum Allowed System Voltage			10	00			Vdc		
Compatible inverters		All So	olarEdge Single Phase	and Three Phase inv	erters				
Dimensions (W x L x H)	129	x 153 x 27.5 / 5.1 x 6	x 1.1	129 x 153 x 33.5 / 5.1 x 6 x 1.3	129 x 159 x 49.5 / 5.1 x 6.3 x 1.9	129 x 162 x 59 / 5.1 x 6.4 x 2.3	mm / in		
Weight (including cables)		630 / 1.4		750 / 1.7	845 / 1.9	1064 / 2.3	gr / lb		
Input Connector			Single or o	dual MC4 ⁽³⁾					
Input Wire Length				/ 0.52			m / ft		
Output Wire Type / Connector			Double Insu	lated / MC4					
Output Wire Length	0.9 /	2.95		1.2	/ 3.9		m / ft		
Operating Temperature Range			-40 - +85 /	′ -40 - +185			°C / °F		
Protection Rating		IP68 / NEMA6P							
Relative Humidity		0 - 100							

Date Rated power of the module at STC will not exceed the optimizer "Rated Input DC Power". Modules with up to +5% power tolerance are allowed

⁽²⁾ NEC 2017 requires max input voltage be not more than 80V (3) For other connector types please contact SolarEdge

PV System Design Using a SolarEdge Inverter ⁽⁴⁾⁽⁵⁾		Single Phase HD-Wave Single phase		Three Phase 208V	Three Phase 480V	
Minimum String Length P320, P340, P370, P400		8	3	10	18	
(Power Optimizers)	P405 / P505	6)	13 (12 with SE3K)	14	
Maximum String Length (Power Optimizers)		25		25	50(6)	
Maximum Power per String		5700 (6000 with SE7600-US - SE11400- US) 5250		6000 ⁽⁷⁾	12750 ⁽⁸⁾	W
Parallel Strings of Different Lengths or Orientations			١	/es		

⁽a) For detailed string sizing information refer to: http://www.solaredge.com/sites/default/files/string_sizing_na.pdf
(b) It is not allowed to mix P405/P505 with P320/P340/P370/P400 in one string
(c) A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement
(c) For SE14.4KUS/SE43.2KUS: It is allowed to install up to 6,500W per string when 3 strings are connected to the inverter (3 strings per unit for SE43.2KUS) and when the maximum power difference between the strings is up to 1,000W
(d) For SE30KUS/SE33.3KUS/SE66.6KUS/SE100KUS: It is allowed to install up to 15,000W per string when 3 strings are connected to the inverter (3 strings per unit for SE66.6KUS/SE100KUS) and when the maximum power difference between the strings is up to 2,000W



Single Phase Inverter with HD-Wave Technology

for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US





Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Record-breaking efficiency
- Quick and easy inverter commissioning directly from a smartphone using the SolarEdge SetApp
- Fixed voltage inverter for longer strings
- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12

- UL1741 SA certified, for CPUC Rule 21 grid compliance
- Extremely small
- Built-in module-level monitoring
- Outdoor and indoor installation
- Optional: Revenue grade data, ANSI C12.20 Class 0.5 (0.5% accuracy)



NVERTERS

/ Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US

Model Number	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
APPLICABLE TO INVERTERS WITH PART NUMBER	SEXXXXH-XXXXXBXX4							
OUTPUT								
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
Maximum AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
AC Output Voltage MinNomMax. (211 - 240 - 264)	✓	✓	✓	✓	✓	✓	✓	Vac
AC Output Voltage MinNomMax. (183 - 208 - 229)	-	✓	-	✓	-	-	✓	Vac
AC Frequency (Nominal)		59.3 - 60 - 60.5 ^(t)						Hz
Maximum Continuous Output Current @240V	12.5	16	21	25	32	42	47.5	А
Maximum Continuous Output Current @208V	=	16	-	24	-	-	48.5	А
Power Factor		1, adjustable -0.85 to 0.85						
GFDI Threshold		1					А	
Utility Monitoring, Islanding Protection, Country Configurable Thresholds	Yes							
INPUT								
Maximum DC Power @240V	4650	5900	7750	9300	11800	15500	17650	W
Maximum DC Power @208V	-	5100	-	7750	-	-	15500	W
Transformer-less, Ungrounded	Yes							
Maximum Input Voltage	480 Vdc					Vdc		
Nominal DC Input Voltage	380			400			Vdc	
Maximum Input Current @240V ⁽²⁾	8.5	10.5	13.5	16.5	20	27	30.5	Adc
Maximum Input Current @208V ⁽²⁾	-	9	-	13.5	-	-	27	Adc
Max. Input Short Circuit Current	45 Adc							
Reverse-Polarity Protection		Yes						
Ground-Fault Isolation Detection	600kΩ Sensitivity							
Maximum Inverter Efficiency	99 99.2 9					%		
CEC Weighted Efficiency	99 @ 240V 98.5 @ 208V						%	
Nighttime Power Consumption		< 2.5					W	

 $^{^{\}mbox{\tiny (1)}}$ For other regional settings please contact SolarEdge support

⁽²⁾ A higher current source may be used; the inverter will limit its input current to the values stated

/ Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US


Model Number	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
ADDITIONAL FEATURES								
Supported Communication Interfaces		RS485, Ethernet, ZigBee (optional), Cellular (optional)						
Revenue Grade Data, ANSI C12.20		Optional ⁽³⁾						
Inverter Commissioning		with the Se	tApp mobile applicati	on using built-in Wi-F	i Access Point for loca	al connection		
Rapid Shutdown - NEC 2014 and 2017 690.12	Automatic Rapid Shutdown upon AC Grid Disconnect							
STANDARD COMPLIANCE								
Safety		UL1741, UL1741 SA, UL1699B, CSA C22.2, Canadian AFCI according to T.I.L. M-07						
Grid Connection Standards		IEEE1547, Rule 21, Rule 14 (HI)						
Emissions	FCC Part 15 Class B							
INSTALLATION SPECIFICAT	TIONS							
AC Output Conduit Size / AWG Range	1" Maximum / 14-6 AWG 1" Maximum /14-4 AWG					n /14-4 AWG		
DC Input Conduit Size / # of Strings / AWG Range	1" Maximum / 1-2 strings / 14-6 AWG 1" Maximum / 1-3 strings / 14-6 AW				strings / 14-6 AWG			
Dimensions with Safety Switch (HxWxD)	17.7 x 14.6 x 6.8 / 450 x 370 x 174 21.3 x 14.6 x 7.3 / 540 x 370 x 185			/ 540 x 370 x 185	in / mm			
Weight with Safety Switch	22 .	/ 10	25.1 / 11.4	26.2	/ 11.9	38.8	/ 17.6	lb/kg
Noise	< 25			<50		dBA		
Cooling	Natural Convection							
Operating Temperature Range	-40 to +140 / -40 to +60 ⁽⁴⁾				°F/°C			
Protection Rating	NEMA 4X (Inverter with Safety Switch)							

⁽³⁾ Revenue grade inverter P/N: SExxxxH-US000BNC4



^(a) Full power up to at least 50°C /122°F; for power de-rating information refer to: https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf

FLUSH MOUNT



CONTENTS

DISCLAIMER	1	
RATINGS	2	
MARKINGS	2	
CHECKLIST	3	
1. ATTACH BASES	4	
2. PLACE RAILS	4	
3. SECURE LUGS	5	
4. SECURE MODULES	5	
CAMO	6	
EXPANSION JOINTS	7	
ELECTRICAL DIAGRAM	7	
FLASHFOOT2	8	
ALL TILE HOOK	8	
KNOCKOUT TILE	8	
FLAT ROOF ATTACHMENT	9	
END CAPS	9	
WIRE CLIPS	9	
FLUSH STANDOFFS	9	ļ

DISCLAIMER

MICROINVERTER KITS

FRAMELESS MODULE KITS

MODULE COMPATIBILITY

This manual describes proper installation procedures and provides necessary standards required for product reliability. Warranty details are <u>available on website</u>. All installers must thoroughly read this manual and have a clear understanding of the installation procedures prior to installation. Failure to follow these guidelines may result in property damage, bodily injury or even death.

SYSTEMS USING ENPHASE MICROINVERTERS OR SUNPOWER AC MODULES

SYSTEMS USING PHAZR MICROSTORAGE PRODUCTS

IT IS THE INSTALLER'S RESPONSIBILITY TO:

- Ensure safe installation of all electrical aspects of the array. All electrical installation and procedures should be
 conducted by a licensed and bonded electrician or solar contractor. Routine maintenance of a module or panel shall
 not involve breaking or disturbing the bonding path of the system. All work must comply with national, state and local
 installation procedures, product and safety standards.
- Comply with all applicable local or national building and fire codes, including any that may supersede this manual.
- Ensure all products are appropriate for the installation, environment, and array under the site's loading conditions.
- Use only IronRidge parts or parts recommended by IronRidge; substituting parts may void any applicable warranty.
- Review the <u>Design Assistant</u> and <u>Certification Letters</u> to confirm design specifications.
- Ensure provided information is accurate. Issues resulting from inaccurate information are the installer's responsibility.
- Ensure bare copper grounding wire does not contact aluminum and zinc-plated steel components, to prevent risk of galvanic corrosion.
- If loose components or loose fasteners are found during periodic inspection, re-tighten immediately. If corrosion is found, replace affected components immediately.
- Provide an appropriate method of direct-to-earth grounding according to the latest edition of the National Electrical Code, including NEC 250: Grounding and Bonding, and NEC 690: Solar Photovoltaic Systems.
- Disconnect AC power before servicing or removing modules, AC modules, microinverters and power optimizers.
- Review module manufacturer's documentation for compatibility and compliance with warranty terms and conditions.

10

10

10

11

11

UL 2703 LISTED



#5003807

Intertek

- Conforms to STD UL 2703 (2015) Standard for Safety First Edition: Mounting Systems, Mounting Devices, Clamping/ Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels.
- Max Overcurrent Protective Device (OCPD) Rating: 25A
- Max Module Size: 24ft²
- Module Orientation: Portrait or Landscape
- CAMO Specific Allowable Design Load Rating: 50 PSF downward, 50 PSF upward, 15 PSF lateral
- System Level Allowable Design Load Rating: meets minimum requirements of the standard (10 PSF downward, 5 PSF upward, 5 PSF lateral). Actual system structural capacity is defined by PE stamped certification letters.

CLASS A SYSTEM FIRE RATING PER UL 1703

- · Any Roof Slope with Module Types 1, 2, and 3
- Any module-to-roof gap is permitted, with no perimeter guarding required. This rating is applicable with any third-party attachment.
- Class A rated PV systems can be installed on Class A, B, and C roofs without affecting the roof fire rating.

WATER SEAL RATINGS: UL 441 & TAS 100(A)-95 (FLASHFOOT2, ALL TILE HOOK, KNOCKOUT TILE)


- · Tested and evaluated without sealant.
- Any roofing manufacturer approved sealant is allowed. Ratings applicable for roof slopes between 2:12 and 12:12


STRUCTURAL CERTIFICATION


Designed and Certified for Compliance with the International Building Code & ASCE/SEI-7

MARKINGS

Product markings are located on the 3/8" flange hex nut or Grounding Lug bolt head.







PRE-INSTALLATION

Verify module compatibility. See Page 10 for info.

TOOLS REQUIRED

- Cordless Drill (non-impact)
- Impact Driver (for lag bolts)
- Torque Wrench (0-250 in-lbs)
- 5/16" Socket
- 7/16" Socket
- 1/2" Socket
- String Line

TORQUE VALUES

- FlashFoot2 Lag Bolts (7/16" Socket): Fully Seat
- Bonded Splice Screws (5/16" Socket): 20 in-lbs
- Grounding Lug Nuts (7/16" Socket): 80 in-lbs
- Grounding Lug Terminal Screws (7/16" Socket): 20 in-lbs П
- Universal Fastening Object (7/16" Socket): 80 in-lbs
- Expansion Joint Nuts (7/16" Socket): 80 in-lbs
- Flush Standoffs (1/2" Socket): 132 in-lbs
- Microinverter Kit Nuts (7/16" Socket): 80 in-lbs П
- Frameless Module Kit Nuts (7/16" Socket): 80 in-lbs
- 3/8" Bonding Hardware Nuts (7/16" Socket): 250 in-lbs
- All Tile Hook Lags (7/16" Socket): Fully Seat
- All Tile Hook Carriage Bolts (7/16" Socket): 132 in-lbs
- Knockout Tile Lags (1/2" Socket): Fully Seat
- Knockout Tile Nuts (1/2" Socket): 132 in-lbs
- Flat Roof Attachment Nuts (9/16" Socket): 250 in-lbs


IRONRIDGE COMPONENTS



XR Rail



Bonded Splice



L-Foot



UFO



Stopper Sleeve




CAMO



FlashFoot2



Grounding Lug



Expansion Joint



End Cap




Wire Clip



Flush Standoff



Microinverter Kit




3/8" Bonding Hardware




Frameless Module Kit



Frameless End/Mid Clamp




All Tile Hook






All Tile Hook Flashing



Knockout Tile



Flat Roof Attachment



Membrane Flashing

If using previous version of: FlashFoot, Integrated Grounding Mid Clamps, Grounding Lug, End Clamps, and Expansion Joints please refer to Alternate Components Addendum (Version 1.20).


1. ATTACH BASES



For composition roofs, refer to FlashFoot2 install instructions on page 8. For tile roofs, refer to All Tile Hook and Knockout Tile install instructions on page 8 and 9. For flat roofs, refer to Flat Roof Attachment install instructions on page 9. When using approved third party attachments, refer to manufacturer's install instructions.

Tested or evaluated third-party roof attachments:

- Anchor Products U-Anchor
- S-5! Standing Seam Metal Roof Clamps Certification of metal roof clamps includes bonding to both painted and galvalume metal roofs. Tighten S-5! and S-5! Mini set screws to 130-150 in-lbs (≥ 24 gauge) or 160-180 in-lbs (22 gauge) roofs.



Tighten S-5! M10 bolt to 240 in-lbs or S-5! Mini M8 bolt to 160 in-lbs. Use the following fastening guidelines for other S-5! roof clamps: ProteaBracket™ - firmly seat roof screws and tighten hinge bolt to 225 in-lbs; RibBracket™ - firmly seat roof screws and tighten M8 bolt (M8-1.25 x 22mm sold separately) to 160 in-lbs; and SolarFoot™ - firmly seat roof screws and tighten M8 flange nut to 160 in-lbs.

- EcoFasten Green Fasten GF-1 Anchors
- Rooftech RT-Mini Attach to L-foot using 5/16-18 x 1.25" stainless steel bolt and nut torqued to 132 in-lbs.
- QuickMount PV Roof Mounts QMLM/QMLM ST and <u>Tile Hooks</u> Tile Hook attaches to XR Rail using 3/8" Bonding Hardware Kit torqued to 250 in-lbs.
- Quickscrews Solar Roof Hooks, Ejot Aluminum Roof Hooks, Unirac Creotecc Tile Hooks, or Solarhooks Attach to XR Rails with L-Foot or 3/8" Bonding Hardware Kit torqued to 250 in-lbs.

В

· Pegasus Comp Mount - Attach to XR Rail using 3/8" Bonding Hardware kit torqued to 250 in-lbs.

2. PLACE RAILS

A. CONNECT SPLICES

Use Bonded Splices, when needed, to join multiple sections of rail. Insert Bonded Splice 6" into first rail and secure with two self-drilling screws, spacing them approximately 1" apart and tightening to **20 in-lbs**. Slide second rail over Bonded Splice and secure with two more self-drilling screws.

- Rows exceeding 100 feet of rail must use Expansion Joints.
- For XR10 and XR100 rails, insert screws along the provided lines.
- Refer to Structural Certification letters for rail splice location requirements.
- Screws can be inserted on front or back of rails.

Torque to 20 in-lbs 1"

B. PREPARE HARDWARE


Slide square-headed bolts into side-facing rail slot. Space out bolts to match attachment spacing.

- Tape ends of rail, to keep bolts from sliding out while moving.
- If using T-bolts, carry hardware onto roof and proceed.



Drop rail with hardware into roof attachment. Level rail at desired height, then torque to **250 in-lbs**.

Rail can face either upslope or downslope on roof.




reload and Space

3. SECURE LUGS

Insert T-bolt in top rail slot and torque hex nut to **80 in-lbs**. Install a minimum 10 AWG solid copper or stranded grounding wire. Torque terminal screw to **20 in-lbs**.

- Ground Lugs are only needed on one rail per continuous row of modules, regardless of row length (unless frameless modules are being used, see Page 9).
- If using Enphase microinverters or Sunpower AC modules, Grounding Lugs may not be needed. See Page 9 for more info.
- Grounding Lugs can be installed anywhere along the rail and in either orientation shown. If installing lug underneath modules in areas with ground snow loads greater than 40 psf, place lug within 4 inches module frame edge.



4. SECURE MODULES

A. SECURE FIRST END

Place first module in position on rails, a minimum of 1" from rail ends. Snap Stopper Sleeves onto UFO. Fasten module to rail using the UFO, ensuring that the UFO is hooked over the top of the module. Torque to **80 in-lbs**.

- Parameter Ensure rails are square before placing modules.
- Value of Hold Stopper Sleeves on end while torquing to prevent rotation.
- If using CAMO instead of UFO + Stopper Sleeve, refer to Page 6 for CAMO installation procedure.

B. SECURE NEXT MODULES


Place UFO into each rail, placing them flush against first module. Slide second module against UFO. Torque to **80 in-lbs**. Repeat for each following module.


- When reinstalling UFO, move modules a minimum of 1/16" so UFOs are in contact with a new section of module frame.
- When UFOs are loosened and re-tightened, ensure UFO T-bolt bottoms out in rail channel before re-torquing UFO to achieve full engagement between T-bolt and rail.
- **♀** If using Wire Clips, refer to Page 9.


C. SECURE LAST END

Place last module in position on rails, a minimum of 1" from rail ends. Snap Stopper Sleeves onto UFO. Secure UFO Clamps on rails, ensuring they are hooked over top of module. Torque to **80 in-lbs**.

- **♀** Hold Stopper Sleeves on end while torquing to prevent rotation.
- Repeat all steps for each following row of modules, leaving a minimum 3/8" gap between rows.
- If using CAMO instead of UFO + Stopper Sleeve, refer to Page 6 for CAMO installation procedure.









Slide CAMO into rail channel far enough to clear the module frame. CAMO requires 6" of clearance from end of rail.




B. PLACE MODULE

Place module on rails (module cells not shown for clarity). When installing CAMO the module can overhang the rail no more than 1/4".




C. PULL TOWARDS END

Pull CAMO towards rail ends, at 45 degree angle, so the bonding bolt contacts the module flange edge.



D. SECURE TO FRAME


Rotate handle with an upwards motion until CAMO snaps into rail channel. Ensure CAMO bonding pins are fully seated on top of module frame.



FRAME COMPATIBILITY

CAMO has been tested or evaluated with all modules listed in the Module Compatibility section having frames within the referenced dimensions. Be sure the specific module being used meets the dimension requirements.

 ♥ For installations with Hanwha Q CELLS modules with 32 mm frame heights, the maximum ground snow is 45 PSF (33 PSF module pressure).



EXPANSION JOINTS




GROUNDING STRAP EXPANSION JOINT


Grounding Strap Expansion Joints are required for thermal expansion of rows exceeding 100 feet of rail.

Insert Internal Splice into first rail and secure with screw. Assemble and secure Grounding Strap 3/8" from rail end. Slide second rail over Internal Splice leaving 1" gap between rails. Attach other end of Grounding Strap with hardware, and torque hex nuts to **80 in-lbs**.

- Second Bonded Splice screw is <u>not</u> used with Expansion Joints.
- On not install module over top of expansion joint location.



ELECTRICAL DIAGRAM




*Grounding Lugs and wire are not required in systems using certain Enphase microinverters or certain Sunpower modules. Equipment grounding is achieved with the Engage cable for Enphase or the AC module cable system for Sunpower via their integrated EGC.

FLASHFOOT2

Locate roof rafters and mark locations on roof. Drill 1/4" pilot holes and backfill with approved sealant. Slide flashing between 1st and 2nd course of shingles, ensuring flashing doesn't overhang the downhill shingle. Line up with pilot hole and insert supplied lag bolt with washer through flashing. Fully seat lag bolt. Place Cap onto flashing in desired orientation for E/W or N/S rails and rotate 180 degrees until it locks into place.


- Rail can be installed on either side of FlashFoot2 Cap.
- Standalone FlashFoot2 manual available on website.



ALL TILE HOOK

Remove tile and mark rafter. Position base over rafter, adjust arm if necessary and torque hardware to 132 in-lbs (11 ft-lbs). Use base as guide to drill 1/4" pilot holes, back fill with roofing manufacturer's approved sealant, then insert lag bolts and tighten until fully seated. Replace tiles and notch as necessary to ensure proper fit. Attach rails to either side of slot using bonding hardware and torque to 250 in-lbs (21-ft-lbs).

- Position arm near the center of valley for curved tiles.
- Position arm away from seam of joining flat tiles.
- Parameter Ensure top of hook does not extend above rail.
- ☑ IronRidge offers an optional aluminum deck flashing. Refer to All Tile Hook Flashing Installation Manual. Other approved flashing methods include user supplied adhesive backed flexible flashing.
- Standalone All Tile Hook manual available on website.



KNOCKOUT TILE

Remove tile and mark rafter. Use base as guide to drill 1/4" pilot hole and fill with roofing manufacturer's approved sealant. Insert lag bolt with bonded washer through base and drive until fully seated. Insert Tile Replacement Flashing, lower onto base and apply pressure over the threaded post until it dimples the flashing. Place L-Foot over dimple and tap with hammer to punch threaded post through the flashing. Ensure punched pieces of flashing are cleared away. Form flashing as needed to sit flush with surrounding tiles, position L-Foot in desired orientation and torque hardware to 132 in-lbs (11 ft-lbs). Attach rail to either side of L-Foot with bonding hardware and torque to 250 in-lbs (21 ft-lbs).

- $\ensuremath{ \mathbb{V} }$ Base can be installed parallel or perpendicular to rafter.
- L-foot can be installed facing any direction.
- Parameter Energy Ensure L-Foot does not extend above rail.
- If deck level flashing is required, approved flashing methods include user supplied adhesive backed flexible flashing.
- Standalone Knockout Tile manual available on website.














FLAT ROOF ATTACHMENT

Flat Roof Attachment can be used with an L-foot for flush mounting modules on low sloped roofs. Mark locations for Flat Roof Attachment. Screws should be installed symmetrically to each other. If using a membrane flashing, remove the silicone washer's protective liner prior to attaching the membrane. Attach L-foot with washers and 3/8" hardware torqued to **250 in-lbs (21 ft-lbs)**. Seal attachment and/or membrane per roofing manufacturer's requirements.

- ▼ Type, size, and quantity of roof screws to be specified by Structural Engineer. Fastener size not to exceed #15.
- Membrane flashing available for TPO, PVC, and KEE roofs. Ensure membrane flashing is compatible with existing roofing material.
- If membrane flashing is not used, only washer on top of L-Foot is required.
- **◊** Standalone Flat Roof Attachment manual available on website.




END CAPS

End Caps add a completed look and keep debris and pests from collecting inside rail.

Firmly press End Cap onto rail end.


End Caps come in sets of left and right. Check that the proper amount of each has been provided.



WIRE CLIPS


Wire Clips offer a simple wire management solution.


Firmly press Wire Clip into top rail slot. Run electrical wire through open clip. Snap closed once all wires have been placed.



FLUSH STANDOFFS

Attach Standoffs to roof locations with lag bolts (not included). Place flashing over Standoff. Attach L-Foot on Standoff washer with hardware. Torque to **132 in-lbs (11 ft-lbs)**.





MICROINVERTER KITS

Use IronRidge's Microinverter Kit to bond compatible microinverters and power optimizers to the racking system.

Insert Microinverter Kit T-bolt into top rail slot. Place compatible microinverter or power optimizer into position and tighten hex nut to **80 in-lbs**.

If installing in areas with ground snow loads greater than 40 psf, install MLPE devices directly next to module frame edge.

COMPATIBLE PRODUCTS

Enphase


M250-72, 250-60, M215-60, C250-72, S230, S280, IQ 6, IQ 6+, IQ 7, IQ 7+, IQ 7X, Q Aggregator

Darfon

MIG240, MIG300, G320, G640

Solar Edge

P300, P320, P340, P370, P400, P405, P505, P600, P700, P730, P800p, P800s, P850, P860



SYSTEMS USING ENPHASE MICROINVERTERS OR SUNPOWER AC MODULES

IronRidge systems using approved Enphase products or SunPower modules eliminate the need for lay-in lugs and field installed equipment grounding conductors (EGC). This solution meets the requirements of UL 2703 for bonding and grounding and is included in this listing.

The following Sunpower modules are included in this listing: Modules with model identifier Ab-xxx-YY and InvisiMount (G5) 46mm frame; where "A" is either E, or X; "b" can be 17, 18, 19, 20, 21, or 22; and "YY" can be C-AC, D-AC, BLK-C-AC, or BLK-D-AC.


The following Enphase products are included in this listing: Microinverters M250-72, M250-60, M215-60, C250-72, and Engage cables ETXX-240, ETXX-208, ETXX-277.

- A minimum of two inverters mounted to the same rail and connected to the same Engage cable are required.
- The microinverters or Sunpower AC modules must be used with a maximum 20 A branch rated overcurrent protection device (OCPD).
- If an AC module is removed from a circuit for maintenance, you must first disconnect AC power and then install a temporary EGC to bridge the gap by inserting an AC extension cable (or via other NEC-compliant means), in order to maintain effective ground continuity to subsequent modules.

SYSTEMS USING PHAZR MICROSTORAGE PRODUCTS

Bonding and grounding is achieved via the IronRidge system when using the Microinverter Kit. Running a separate equipment grounding conductor to the PHAZRs is not required.

If installing in areas with ground snow loads greater than 40 psf and underneath a module, install PHAZR devices as close as possible to module frame edge.




FRAMELESS MODULE KITS



Insert Frameless Kit T-bolt in top rail slot. Place star washer over T-bolt, allowing it to rest on top of rail. Secure module clamps with a hex nut and torque to **80 in-lbs**.

- **?** Tested or evaluated module clamps:
 - Sunforson silver or black SFS-UTMC-200(B) mid and SFS-UTEC-200(B) end clamps.
 - Sunpreme silver or black mid and end clamps with part numbers 7500105X where "X" is 1, 5, 6 or 7.
 - IronRidge silver or black mid and end clamps with part numbers FMLS-XC-001-Y where "X" is E or M and "Y" is B or blank.
- ♥ Follow module manufacturer's installation instructions to install the module clamps.
- Frameless modules require using a Grounding Lug on every rail.
- ∇ For Sunpreme Modules Only: If required to use slide prevention hardware, see Module Slide Prevention Addendum (Version 1.10).



MODULE COMPATIBILITY

The Flush Mount System may be used to ground and/or mount a PV module complying with UL 1703 only when the specific module has been evaluated for grounding and/or mounting in compliance with the included instructions. Unless otherwise noted, "xxx" refers to the module power rating and both black and silver frames are included in the certification.

MAKE	MODELS
Amerisolar	Modules with 35, 40 and 50mm frames and model identifier ASbYxxxZ; where "b" can be 5 or 6; "Y" can be M, P, M27, P27, M30, or P30; and "Z" can be blank, W or WB.
Astronergy Solar	Modules with 35, 40, and 45mm frames and model identifier aaSM66yyPzz-xxx; where "aa" can be CH or A; "yy" can be either 10 or 12; and "zz" can be blank, HV, (BF) or (BL). Frameless modules with model identifier CHSM6610P(DG)-xxx.
Auxin	Modules with 40mm frames and model identifier AXN6y6zAxxx; where "y" can be M or P; "z" can be 08, 09, 10, 11, or 12; and "A" can be F or T.
Axitec	Modules with 35 and 40mm frames and model identifier AC-xxxY/aa-ZZ; where "Y" can be M or P; "aa" can be 125 or 156; and "ZZ" can be 54S, 60S or 72S.
Boviet	Modules with 40mm frames and model identifier BVM66aaYY-xxx; where "aa" can be 9, 10 or 12; and "YY" is M or P.
BYD	Modules with 35mm frames and model identifier BYDxxxAY-ZZ; where "A" can be M6, P6, or PH; "Y" can be C or K; and "ZZ" can be 30 or 36.
Canadian Solar	Modules with 30, 35 and 40mm frames and model identifier CSbY-xxxZ; where "b" can be 1, 3 or 6; "Y" can be H, K, P, U, V, or X; and "Z" can be M, P, MS, PX, M-SD, P-AG, P-SD, MB-AG, PB-AG, MS-AG, or MS-SD. Frameless modules with model identifier CSbY-xxx-Z; where "b" can be 3 or 6; "Y" is K, P, U, or X; and "Z" can be M-FG, MS-FG, P-FG, MB-FG, or PB-FG.
CertainTeed	Modules with 35 and 40mm frames and model identifier CTxxxYZZ-AA; where "Y" can be M or P; "ZZ" can be 00,01, 10, or 11; and "AA" can be 01, 02 or 03.
CSUN	Modules with 35 and 40mm frames and model identifier YYxxx-zzAbb; where "YY" is CSUN or SST; "zz" is blank, 60, or 72; "A" is blank, P or M; and "bb" is blank, BB, BW, or ROOF.
Ecosolargy	Modules with 35, 40, and 50mm frames and model identifier ECOxxxYzzA-bbD; where "Y" can be A, H, S, or T; "zz" can be 125 or 156; "A" can be M or P; "bb" can be 60 or 72; and "D" can be blank or B.
ET Solar	Modules with 35, 40, or 50mm frames and model identifier ET-Y6ZZxxxAA; where "Y" is P, L, or M; "ZZ" is 60 or 72; and "AA" is WB, WW, BB, WBG, WWG, WBAC, WBCO, WWCO, WWBCO or BBAC.

MODULE COMPATIBILITY

Flex	Modules with 35, 40, or 50mm frames and model identifier FXS-xxxYY-ZZ; where "xxx" is the module power rating; "YY" is BB or BC; and "ZZ" is MAA1B, MAA1W, MAB1W, SAA1B, SAA1W, SAC1B, SAC1W, SAD1W, SBA1B, SBA1W, SBC1B, or SBC1W.
GCL	Modules with 35 and 40mm frames and and model identifier GCL-a6/YY xxx; where "a" can be M or P; and "YY" can be 60, 72, or 72H.
GigaWatt Solar	Modules with 40mm frames and model identifier GWxxxYY; where "YY" is either PB or MB.
Hansol	Modules with 35 and 40mm frames and model identifier HSxxxYY-zz; where "YY" can be TB, TD, UB or UD; and "zz" can be AN1, AN3, AN4.
Hanwha Solar	Modules with 40, 45, or 50mm frames and model identifier HSLaaP6-YY-1-xxxZ; where "aa" is either 60 or 72; "YY" is PA or PB; and "Z" is blank or B.
Hanwha Q CELLS	Modules with 32, 35, 40, and 42mm frames and model identifier aaYY-ZZ-xxx; where "aa" can be Q. or B.; "YY" can be PLUS, PRO, PEAK, LINE PRO, LINE PLUS, or PEAK DUO; and "ZZ" can be G3, G3.1, G4, G4.1, L-G2, L-G2.3, L-G3, L-G3.1, L-G3y, L-G4, L-G4.2, L-G4y, LG4.2/TAA, BFR-G3, BLK-G3, BFR-G3.1, BLK-G3.1, BFR-G4, BFR-G4.1, BFR G4.3, BLK-G4.1, G4/SC, G4.1/SC, G4.1/TAA, G4.1/MAX, BFR G4.1/TAA, BFR G4.1/TAA, BLK G4.1/TAA, BLK G4.1/SC, EC-G4.4, G5, BLK-G5, L-G5.1, L-G5.2, L-G5.2/H, L-G5.3, G6, BLK-G6, L-G6, LG6.1, LG6.2, or LG6.3.
Heliene	Modules with 40mm frames and model identifier YYZZxxx; where "YY" is 36, 60, 72, or 96; and "ZZ" is M, P, or MBLK.
Hyundai	Modules with 35, 40 and 50mm frames and model identifier HiS-YxxxZZ; where "Y" can be M or S; and "ZZ" can be KI, MI, MF, MG, SG, RI, RG(BF), RG(BK), TI, or TG.
Itek	Modules with 40 or 50mm frames and model identifier IT-xxx-YY; where "YY" is blank, HE, or SE, or SE72.
JA Solar	Modules with 35, 40 and 45mm frames and model identifier JAyyzz-bb-xxx/aa; where "yy" can be M, P, M6 or P6; "zz" can be blank, (K), (L), (R), (V), (BK), (FA), (TG), (FA)(R), (L)(BK), (L)(TG), (R)(BK), (R) (TG), (V)(BK), (BK)(TG), or (L)(BK)(TG); "bb" can be 48, 60, 72, 60S01, 60S02, 60S03, 72S01, 72S02, 72S03; and "aa" can be MP, SI, SC, PR, PR/1500V, 3BB, 4BB, 4BB/RE, 4BB/1500V, 5BB.
Jinko	Modules with 35 and 40mm frames and model identifier JKMYxxxZZ-aa; where "Y" can either be blank or S; "ZZ" can be P, PP, M; and "aa" can be blank, 60, 60B, 60H, 60L, 60BL, 60HL, 60HBL, 60-J4, 60B-J4, 60B-EP, 60(Plus), 60-V, 60-MX, 72, 72-V, 72H-V, 72L-V, 72HL-V or 72-MX. Frameless modules with model identifier JKMxxxPP-DV.
Kyocera	Modules with 46mm frames and model identifier KYxxxZZ-AA; where "Y" is D or U; "ZZ" is blank, GX, or SX; and "AA" is LPU, LFU, UPU, LPS, LPB, LFB, LFBS, LFB2, LPB2, 3AC, 3BC, 3FC, 4AC, 4BC, 4FC, 4UC, 5AC, 5BC, 5FC, 5UC, 6BC, 6FC, 8BC, 6MCA, or 6MPA.
LG	Modules with 35, 40, and 46mm frames LGxxxYaZ-bb; where "Y" can be A, E, N, Q, S; "a" can be 1 or 2; "Z" can be C, K, T, or W; and "bb" can be A3, A5, B3, G3, G4, K4, or V5.
Longi	Modules with 40 and 45mm frames and model identifier LR6-YYZZ-xxxM; where "YY" can be 60 or 72; and "ZZ" can be BK, BP, HV, PB, PE, or PH.
Mission Solar	Modules with 40mm frames and model identifier MSExxxZZaa; where "ZZ" can be MM, SE, SO or SQ; and "aa" can be 1J, 4J, 4S, 5K, 5T, 6J, 6S, 6W, 8K, 8T, or 9S.
Mitsubishi	Modules with 46mm frames and model identifier PV-MYYxxxZZ; where "YY" is LE or JE; and "ZZ" is either HD, HD2, or FB.
Motech	IM and XS series modules with 40, 45, or 50mm frames.
Neo Solar Power	Modules with 35mm frames and model identifier D6YxxxZZaa; where "Y" can be M or P; "ZZ" can be B3A, B4A, E3A, E4A, H3A, H4A; and "aa" can be blank, (TF), ME or ME (TF).
Panasonic	Modules with 35 and 40mm frames and model identifier VBHNxxxYYzzA; where "YY" can be either SA or KA; "zz" can be either 01, 02, 03, 04, 06, 06B, 11, 11B, 15, 15B, 16, 16B, 17, or 18; and "A" can be blank, E or G.
Peimar	Modules with 40mm frames and model identifier SGxxxYzz; where "Y" can be M or P; and "zz" can be blank, (BF), or (FB).
Phono Solar	Modules with 35, 40, or 45mm frames and model identifier PSxxxY-ZZ/A; where "Y" is M or P; "ZZ" is 20 or 24; and "A" is F, T or U.

MODULE COMP	ATIBILITY
Prism Solar	Frameless modules with model identifier BiYY-xxxBSTC; where "YY" can be 48, 60, 60S, 72 or 72S.
REC Solar	Modules with 30, 38 and 45mm frames and model identifier RECxxxYYZZ; where "YY" can be M, NP, PE, TP, TP2M, TP2SM, or TP2S; and "ZZ" can be blank, Black, BLK, BLK2, SLV, or 72.
Renesola	Modules with 35, 40 or 50mm frames and model identifier JCxxxY-ZZ; where "Y" is F, M or S; and "ZZ" is Ab, Ab-b, Abh, Abh-b, Abv, Abv-b, Bb, Bb-b, Bbh, Bbh-b, Bbv, Bbv-b, Db, or Db-b.
Renogy	Modules with 40 or 50mm frames and model identifier RNG-xxxY; where "Y" is D or P.
S-Energy	Modules with 40mm frames and model identifier SNxxxY-ZZ; where "Y" is M or P; and "ZZ" is 10, or 15.
Seraphim Energy Group	Modules with 40mm frames and model identifier SEG-6YY-xxxZZ; where "YY" can be MA, MB, PA, PB; and "ZZ" can be BB, WB, or WW.
Seraphim USA	Modules with 40 and 50mm frames and model identifier SRP-xxx-6YY; where "YY" can be MA, MB, PA, PB, QA-XX-XX, and QB-XX-XX.
Sharp	Modules with 35 or 40mm frames and model identifier NUYYxxx; where "YY" is SA or SC.

"ZZ" can be AC, BD, BX, BY, PD, PX, PZ, WX or WZ.

"Z" is M, P, or X.

7, 8, or 9; and "E" is 0, 1 or 2.

can be P or W.

""z"" is either M or P.

100,101,700,1B0, or 1B1; and "Z" is blank or B.

PEG14, DEG5(II), DEG5.07(II), or DEG14(II).

Modules with 38mm frames and model identifier SYY-Z-xxx; where "YY" is SA or LA; SG or LG; and

Modules with 40mm frames and model identifier PowerXT xxxY-ZZ; where "Y" can be R or C; and

Modules with 42mm frames and model identifier STU-xxxYY; where "YY" can be PERC or HJT.

SolarWorld Sunmodule Plus, Protect, Bisun, XL, Bisun, XL, may be followed by mono, poly, duo,

SolarWorld Sunmodule Plus, Protect, Bisun, XL, Bisun, XL, may be followed by mono, poly, duo,

Modules with 35, 40, or 50mm frames and model identifier SE-YxxxZABCDE; where "Y" is B, F, H,

P, R, or Z; "Z" is 0 or 4; "A" is B, C, D, E, H, I, J, K, L, M, or N; "B" is B or W; "C" is A or C; "D" is 3,

Modules with standard (G3 or G4) or InvisiMount (G5) 40 and 46mm frames with model identifier SPR-Zb-xxx-YY; where "Z" is either A, E, P or X; "b" can be blank, 17, 18, 19, 20, 21, or 22; and

Sunpreme modules with 35 and 40mm frames and model identifier SNPM-AxB-xxxYzz; where "A" can be G or H; "Y" can be blank or T; and "zz" can be blank, 4BB, SM or 4BB SM. Frameless

modules with model identifier SNPM-GxB-xxxZZ; where "ZZ" can be blank, 4BB, SM or 4BB SM. Modules with 40mm frames and model identifier SYY-xxZ; where "YY" can be MX or ST; and "Z"

Modules with 35 and 40mm frames and model identifier TP6yyZxxx-A; where "yy" can be 60, 72,

Modules with 35, 40 or 46mm frames and model identifier TSM-xxxYYZZ; where "YY" is PA05, PC05, PD05, PA14, PC14, PD14, PE14, or DD05; and "ZZ" is blank, A, A.05, A.08, A.10, A.18, .05,

.08, .10, .18, .08D, .18D, 0.82, A.082(II), .002, .00S, 05S, 08S, A(II), A.08(II), A.05(II), A.10(II), or A.18(II). Frameless modules with model identifier TSM-xxxYY; and "YY" is either PEG5, PEG5.07,

Modules with 35 or 40mm frames and model identifier Wsy-xxxz6; where "y" is either P or T; and

black, bk, or clear; modules with 31, 33 or 46mm frames and model identifier SW-xxx.

Thin film modules with 35mm frames and model identifier STO-xxx or STO-xxxA. Thin film

Modules with 35, 38, 40, 46, or 50mm frames and model identifiers OPTxxx-AA-B-YYY-Z

or MVXxxx-AA-B-YYY-Z; where "AA" is either 60 or 72; "B" is either 4 or 5; "YYY" is either

"YY" can be blank, NE, BLK, COM, C-AC, D-AC, E-AC, BLK-C-AC, or BLK-D-AC.

Vd, Vem, Wdb, Wde, and Wd series modules with 35, 40, or 50mm frames.

Panda, YGE, and YGE-U series modules with 35, 40, or 50 mm frames.

H60 or H72; "Z" can be M, or P; and "A" can be blank, B, or T.

black, bk, or clear; modules with 33mm frames and model identifier SWA-xxx.

frameless modules with model identifier STL-xxx or STL-xxxA.

© 2019 IRO	NRIDGE, INC.	VERSION 2.0

Silfab

Solaria

Stion

SunEdison

Suniva

Sunpower

Sunpreme

Sunspark

Suntech

Talesun

Trina

Winaico

Yingli

SolarTech

SolarWorld AG /

Industries GmbH

SolarWorld Americas Inc.