



VSE Project Number: U3573.3126.201

November 13, 2020

SunPro Solar
ATTENTION: Dean Scott
22171 MCH Road
Mandeville, LA 70471

**REFERENCE: Gina Smith Residence (PROJ-24273): 801 Gregory Circle, Lillington, NC 27546
Solar Array Installation**

To Whom It May Concern:

Per your request, Cameron Alworth, a representative of Vector Structural Engineering, LLC performed a site visit at the address above on November 12, 2020. The purpose of the visit was to observe the existing framing and determine the adequacy of the existing structure to support the proposed installation of solar panels on the roof.

Based upon our review, we conclude that the existing structure is adequate to support the proposed solar panel installation.

Design Parameters

Code: North Carolina Building Code, 2018 Edition (2015 IBC)
Risk Category: II
Design wind speed: 117 mph (3-sec gust) per ASCE 7-10
Wind exposure category: C
Ground snow load: 15 psf

Existing Roof Structure

Roof 1: asphalt shingles over 2x4 manufactured trusses @ 24" O.C. with a roof pitch of 7:12
Roof 2: asphalt shingles over 2x4 manufactured trusses @ 24" O.C. with a roof pitch of 10:12

Connection to Roof

Mounting connection: (1) 5/16" lag screw w/ min. 2.5" embedment into framing at max. 48" o.c. along rails
(2) rails per row of panels, evenly spaced; panel length perpendicular to the rails not to exceed 67 in

Conclusions

Based upon our review, we conclude that the existing structure is adequate to support the proposed solar panel installation. In the area of the solar array, other live loads will not be present or will be greatly reduced (2018 NCBC, Section 1607.12.5). The gravity loads and; thus, the stresses of the structural elements, in the area of the solar array are either decreased or increased by no more than 5%. Therefore, the requirements of Section 807.4 of the 2018 NCEBC (2015 IEBC) are met and the structure is permitted to remain unaltered.



VSE Project Number: U3573.3126.201

Gina Smith Residence

11/13/2020

The solar array will be flush-mounted (no more than 6" above the roof surface) and parallel to the roof surface. Thus, we conclude that any additional wind loading on the structure related to the addition of the proposed solar array is negligible. The attached calculations verify the capacity of the connections of the solar array to the existing roof against wind (uplift), the governing load case. Because the increase in lateral forces is less than 10%, this addition meets the requirements of the exception in Section 807.5 of the 2018 NCEBC (2015 IEBC). Thus the existing lateral force resisting system is permitted to remain unaltered.

Limitations

Installation of the solar panels must be performed in accordance with manufacturer recommendations. All work performed must be in accordance with accepted industry-wide methods and applicable safety standards. The contractor must notify Vector Structural Engineering, LLC should any damage, deterioration or discrepancies between the as-built condition of the structure and the condition described in this letter be found. Connections to existing roof framing must be staggered, except at array ends, so as not to overload any existing structural member. The use of solar panel support span tables provided by others is allowed only where the building type, site conditions, site-specific design parameters, and solar panel configuration match the description of the span tables. The design of the solar panel racking (mounts, rails, etc.) and electrical engineering is the responsibility of others. Waterproofing around the roof penetrations is the responsibility of others. Vector Structural Engineering assumes no responsibility for improper installation of the solar array.

VECTOR STRUCTURAL ENGINEERING, LLC

NC Firm License: COA #P-0742



11/13/2020

Jacob Proctor, P.E.

NC License: 049893 - Expires: 12/31/2020

Project Engineer

Enclosures

JSP/lic



PROJECT: Gina Smith Residence

Components and Cladding Wind Calculations

Label: Solar Panel Array

Note: Calculations per ASCE 7-10

SITE-SPECIFIC WIND PARAMETERS:

Basic Wind Speed [mph]: 117
 Exposure Category: C
 Risk Category: II

Notes:

ADDITIONAL INPUT & CALCULATIONS:

Height of Roof, h [ft]: 15 (Approximate)
 Comp/Cladding Location: Gable Roofs $27^\circ < \theta \leq 45^\circ$
 Enclosure Classification: Enclosed Buildings
 Zone 1 GC_p : 1.0 Figure 30.4-2C (enter negative pressure coefficients)
 Zone 2 GC_p : 1.2
 Zone 3 GC_p : 1.2
 α : 9.5 Table 26.9-1
 z_g [ft]: 900 Table 26.9-1
 K_h : 0.85 Table 30.3-1
 K_{zt} : 1 Equation 26.8-1
 K_d : 0.85 Table 26.6-1
 Velocity Pressure, q_h [psf]: 25.3 Equation 30.3-1
 GC_{pi} : 0 Table 26.11-1

PRESSURES: $p = q_h [(GC_p) - (GC_{pi})]$ Equation 30.9-1

Zone 1, p [psf]: 25.3 psf (1.0 W, Interior Zones, beyond 'a' from roof edge)
 Zone 2, p [psf]: 30.3 psf (1.0 W, End Zones, within 'a' from roof edge)
 Zone 3, p [psf]: 30.3 psf (1.0 W, Corner Zones, within 'a' from roof corner)
 (a= 3 ft)



JOB NO.: U3573.3126.201
SUBJECT: CONNECTION

PROJECT: Gina Smith Residence

Calculate Uplift Forces on Connection

	Pressure (0.6 Dead -0.6 Wind) (psf)	Max Connection Spacing ¹ (ft)	Max Trib. Area ² (ft ²)	Max Uplift Force (lbs)
Zone 1	15.2	4.0	11.2	146
Zone 2	18.2	4.0	11.2	180
Zone 3	18.2	4.0	11.2	180

Calculate Connection Capacity

Lag Screw Size [in]:	5/16	
C _d :	1.6	NDS Table 2.3.2
Embedment ³ [in]:	2.5	
Grade:	SPF (G = 0.42)	
Nominal Capacity [lbs/in]:	205	NDS Table 12.2A
Number of Screws:	1	
Prying Coefficient:	1.4	
Total Capacity [lbs]:	586	

Determine Result

Maximum Demand [lbs]:	180
Lag Screw Capacity [lbs]:	586

Result: **Capacity > Demand. Connection is adequate.**

Notes

1. 'Max Connection Spacing' is the spacing between connections along the rails.
2. 'Max Trib Area' is the product of the 'Max Connection Spacing' and 1/2 the panel width/height perpendicular to the rails. (2) rails per row of panels. Length of panels perpendicular to the rails shall not exceed 67".
3. Embedment is measured from the top of the framing member to the beginning of the tapered tip of the lag screw. Embedment in sheathing or other material is not effective. The length of the tapered tip is not part of the embedment length.



JOB NO.: U3573.3126.201
SUBJECT: GRAVITY LOADS

PROJECT: Gina Smith Residence

CALCULATE ESTIMATED GRAVITY LOADS

Roof Pitch: :12

ROOF DEAD LOAD (D)	Design material weight [psf]	Increase due to pitch	Material weight [psf]
Asphalt Shingles	2.3	1.16	2.0
1/2" Plywood	1.2	1.16	1.0
Framing	3.0		3.0
Insulation	0.5		0.5
1/2" Gypsum Clg.	2.3	1.16	2.0
M, E & Misc	1.5		1.5
Total Original Roof DL	10.8		
PV Array DL	3.5	1.16	3

ROOF LIVE LOAD (Lr)

Existing Design Roof Live Load [psf]	<input type="text" value="20"/>	ASCE 7-10, Table 4-1
Roof Live Load With PV Array [psf]	<input type="text" value="0"/>	2018 NCBC, Section 1607.12.5

SNOW LOAD (S):

Existing w/ Solar Array

	Existing	w/ Solar Array	
Roof Slope [x:12]:	<input type="text" value="7.0"/>	<input type="text" value="7.0"/>	
Roof Slope [°]:	30	30	
Snow Ground Load, p_g [psf]:	<input type="text" value="15"/>	<input type="text" value="15"/>	ASCE 7-10, Section 7.2
Terrain Category:	<input type="text" value="C"/>	<input type="text" value="C"/>	ASCE 7-10, Table 7-2
Exposure of Roof:	<input type="text" value="Fully Exposed"/>	<input type="text" value="Fully Exposed"/>	ASCE 7-10, Table 7-2
Exposure Factor, C_e :	<input type="text" value="0.9"/>	<input type="text" value="0.9"/>	ASCE 7-10, Table 7-2
Thermal Factor, C_t :	<input type="text" value="1.1"/>	<input type="text" value="1.1"/>	ASCE 7-10, Table 7-3
Risk Category:	<input type="text" value="II"/>	<input type="text" value="II"/>	ASCE 7-10, Table 1.5-1
Importance Factor, I_s :	<input type="text" value="1.0"/>	<input type="text" value="1.0"/>	ASCE 7-10, Table 1.5-2
Flat Roof Snow Load, p_f [psf]:	<input type="text" value="10"/>	<input type="text" value="10"/>	ASCE 7-10, Equation 7.3-1
Minimum Roof Snow Load, p_m [psf]:	<input type="text" value="0"/>	<input type="text" value="0"/>	ASCE 7-10, Section 7.3.4
Unobstructed Slippery Surface?	<input type="text" value="No"/>	<input type="text" value="No"/>	ASCE 7-10, Section 7.4
Slope Factor Figure:	<input type="text" value="Figure 7-2b"/>	<input type="text" value="Figure 7-2b"/>	ASCE 7-10, Section 7.4
Roof Slope Factor, C_s :	<input type="text" value="1.00"/>	<input type="text" value="1.00"/>	ASCE 7-10, Figure 7-2
Sloped Roof Snow Load, p_s [psf]:	<input type="text" value="10"/>	<input type="text" value="10"/>	ASCE 7-10, Equation 7.4-1
Design Snow Load, S [psf]:	<input type="text" value="10"/>	<input type="text" value="10"/>	



PROJECT: Gina Smith Residence

Summary of Loads

	Existing	With PV Array
D [psf]	11	14
Lr [psf]	20	0
S [psf]	10	10

Maximum Gravity Loads:

	Existing	With PV Array	
$(D + Lr) / Cd$ [psf]	25	16	ASCE 7-10, Section 2.4.1
$(D + S) / Cd$ [psf]	18	21	ASCE 7-10, Section 2.4.1

(Cd = Load Duration Factor = 0.9 for D, 1.15 for S, and 1.25 for Lr)

Maximum Gravity Load [psf]:	25	21
-----------------------------	----	----

Ratio Proposed Loading to Current Loading:

87%

OK

The gravity loads and; thus, the stresses of the structural elements, in the area of the solar array are either decreased or increased by no more than 5%. Therefore, the requirements of Section 807.4 of the 2018 NCEBC (2015 IEBC) are met and the structure is permitted to remain unaltered.