

# NEW PHOTOVOLTAIC SYSTEM 8.52 KW DC

## 285 LENNIE SMITH RD, FUQUAY-VARINA, NC 27526, USA

### GENERAL NOTES

**1.1.1 PROJECT NOTES:**  
 1.1.2 THIS PHOTOVOLTAIC (PV) SYSTEM SHALL COMPLY WITH THE NATIONAL ELECTRIC CODE (NEC) ARTICLE 690, ALL MANUFACTURERS' LISTING AND INSTALLATION INSTRUCTIONS, AND THE RELEVANT CODES AS SPECIFIED BY THE AUTHORITY HAVING JURISDICTION'S (AHJ) APPLICABLE CODES.  
 1.1.3 THE UTILITY INTERCONNECTION APPLICATION MUST BE APPROVED AND PV SYSTEM INSPECTED PRIOR TO PARALLEL OPERATION  
 1.1.4 GROUND FAULT DETECTION AND INTERRUPTION (GFDI) DEVICE IS INTEGRATED WITH THE MICROINVERTER IN ACCORDANCE WITH NEC 690.41(B)  
 1.1.5 ALL PV SYSTEM COMPONENTS; MODULES, UTILITY-INTERACTIVE INVERTERS, AND SOURCE CIRCUIT COMBINER BOXES ARE IDENTIFIED AND LISTED FOR USE IN PHOTOVOLTAIC SYSTEMS AS REQUIRED BY NEC 690.4: PV MODULES: UL1703, IEC61730, AND IEC61215, AND NFPA 70 CLASS C FIRE INVERTERS: UL 1741 CERTIFIED, IEEE 1547, 929, 519 COMBINER BOX(ES): UL 1703 OR UL 1741 ACCESSORY  
 1.1.6 MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC. IF UNAVAILABLE, MAX DC VOLTAGE CALCULATED ACCORDING TO NEC 690.7.  
 1.1.7 ALL INVERTERS, PHOTOVOLTAIC MODULES, PHOTOVOLTAIC PANELS, AND SOURCE CIRCUIT COMBINERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER 690.4 (D). SHALL BE INSTALLED ACCORDING TO ANY INSTRUCTIONS FROM LISTING OR LABELING [NEC 110.3].  
 1.1.8 ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE. IF EXPOSED TO SUNLIGHT, IT SHALL BE UV RESISTANT. ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS REQUIRED BY THE NEC AND AHJ.

**1.2.1 SCOPE OF WORK:**  
 1.2.2 PRIME CONTRACTOR IS RESPONSIBLE FOR THE DESIGN AND SPECIFICATIONS OF THE GRID-TIED PHOTOVOLTAIC SYSTEM RETROFIT. PRIME CONTRACTOR WILL BE RESPONSIBLE FOR COLLECTING EXISTING ONSITE REQUIREMENTS TO DESIGN, SPECIFY, AND INSTALL THE EXTERIOR ROOF-MOUNTED PORTION OF THE PHOTOVOLTAIC SYSTEMS DETAILED IN THIS DOCUMENT

**1.3.1 WORK INCLUDES:**  
 1.3.2 PV RACKING SYSTEM INSTALLATION - UNIRAC SOLAR  
 1.3.3 PV MODULE AND INVERTER INSTALLATION - LG ELECTRONICS LG355N1C-N5 / ENPHASE INVERTER  
 1.3.4 PV EQUIPMENT GROUND MOUNT  
 1.3.5 PV SYSTEM WIRING TO A GROUND MOUNT JUNCTION BOX  
 1.3.6 PV LOAD CENTERS (IF INCLUDED)  
 1.3.7 PV METERING/MONITORING (IF INCLUDED)  
 1.3.8 PV DISCONNECTS  
 1.3.9 PV GROUNDING ELECTRODE & BONDING TO (E) GEC  
 1.3.10 PV FINAL COMMISSIONING  
 1.3.11 (E) ELECTRICAL EQUIPMENT RETROFIT FOR PV 1.3.13  
 SIGNAGE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE

#### PROJECT INFORMATION

**OWNER**  
 NAME: STEPHEN TOASO

**PROJECT MANAGER**  
 NAME: MATTHEW WEBB  
 PHONE: 5052180838

**CONTRACTOR NAME**  
 MARC JONES CONSTRUCTION,  
 LLC DBA SUNPRO SOLAR  
 PHONE: 5052180838



Vector Structural Engineering's structural scope of work is for the foundation only.

VSE Project Number: U3573.2777.201



#### SCOPE OF WORK

10/08/2020

SYSTEM SIZE: STC: 24 X 355W = 8.52 kW DC  
 PTC: 24 x 332.8W = 7.99 kW DC  
 (24) LG ELECTRONICS LG355N1C-N5  
 (24) ENPHASE IQ7PLUS-72-2-US

ATTACHMENT TYPE: GROUND MOUNT  
 MSP UPGRADE: NO

#### AUTHORITIES HAVING JURISDICTION

BUILDING: WAKE COUNTY  
 ZONING: WAKE COUNTY  
 UTILITY: DUKE

#### DESIGN SPECIFICATION

OCCUPANCY: I  
 CONSTRUCTION: SINGLE-FAMILY  
 ZONING: RESIDENTIAL  
 GROUND SNOW LOAD: 15 psf  
 WIND EXPOSURE: C  
 WIND SPEED: 105 mph

#### APPLICABLE CODES & STANDARDS

BUILDING: IBC 2015 IRC 2015  
 ELECTRICAL: NEC 2017  
 FIRE: IFC 2018

### VICINITY MAP



### SATELLITE VIEW



### SHEET INDEX

T-001	COVER PAGE
G-001	NOTES
A-101	SITE PLAN
A-102	ELECTRICAL PLAN
A-103	ATTACHMENT PLAN
E-601	LINE DIAGRAM
E-602	ELECTRICAL CALCULATIONS
E-603	PLACARD
R-001	RESOURCE DOCUMENT
R-002	RESOURCE DOCUMENT
R-003	RESOURCE DOCUMENT
R-004	RESOURCE DOCUMENT
R-005	RESOURCE DOCUMENT
R-006	RESOURCE DOCUMENT
R-007	RESOURCE DOCUMENT
R-008	RESOURCE DOCUMENT
R-009	RESOURCE DOCUMENT



22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS

STEPHEN TOASO  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA

Signature with Seal

REVISIONS	DESCRIPTION	REV	DATE	

SHEET TITLE  
 COVER PAGE

DRAWN DATE: 09/26/2020  
 DRAWN BY: YAZ  
 REVIEWED BY: -

SHEET NUMBER  
 T-001

**2.1.1 SITE NOTES:**

2.1.2 A LADDER WILL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS.  
 2.1.3 THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM WITH NO STORAGE BATTERIES.  
 2.1.4 THE SOLAR PV INSTALLATION WILL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS.  
 2.1.5 PROPER ACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PER SECTION NEC 110.26.  
 2.1.6 ROOF COVERINGS SHALL BE DESIGNED, INSTALLED, AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SERVES TO PROTECT THE BUILDING OR STRUCTURE.

**2.2.1 EQUIPMENT LOCATIONS:**

2.2.2 ALL EQUIPMENT SHALL MEET MINIMUM SETBACKS AS REQUIRED BY NEC 110.26.  
 2.2.3 WIRING SYSTEMS INSTALLED IN DIRECT SUNLIGHT MUST BE RATED FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC 690.31 (A),(C) AND NEC TABLES 310.15 (B)(2)(A) AND 310.15 (B)(3)(C).  
 2.2.4 JUNCTION AND PULL BOXES PERMITTED INSTALLED UNDER PV MODULES ACCORDING TO NEC 690.34.  
 2.2.5 ADDITIONAL AC DISCONNECT(S) SHALL BE PROVIDED WHERE THE INVERTER IS NOT WITHIN SIGHT OF THE AC SERVICING DISCONNECT.  
 2.2.6 ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES.  
 2.2.7 ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.

**2.3.1 STRUCTURAL NOTES:**

2.3.2 RACKING SYSTEM & PV ARRAY WILL BE INSTALLED ACCORDING TO CODE-COMPLIANT INSTALLATION MANUAL. TOP CLAMPS REQUIRE A DESIGNATED SPACE BETWEEN MODULES, AND RAILS MUST ALSO EXTEND A MINIMUM DISTANCE BEYOND EITHER EDGE OF THE ARRAY/SUBARRAY, ACCORDING TO RAI MANUFACTURER'S INSTRUCTIONS.  
 2.3.3 JUNCTION BOX WILL BE INSTALLED PER MANUFACTURERS' SPECIFICATIONS. IF ROOF-PENETRATING TYPE, IT SHALL BE FLASHED & SEALED PER LOCAL REQUIREMENTS.  
 2.3.4 ROOFTOP PENETRATIONS FOR PV RACEWAY WILL BE COMPLETED AND SEALED W/ APPROVED CHEMICAL SEALANT PER CODE BY A LICENSED CONTRACTOR.  
 2.3.5 ALL PV RELATED ROOF ATTACHMENTS TO BE SPACED NO GREATER THAN THE SPAN DISTANCE SPECIFIED BY THE RACKING MANUFACTURER.  
 2.3.6 WHEN POSSIBLE, ALL PV RELATED RACKING ATTACHMENTS WILL BE STAGGERED AMONGST THE ROOF FRAMING MEMBERS.

**2.4.1 WIRING & CONDUIT NOTES:**

2.4.2 ALL CONDUIT AND WIRE WILL BE LISTED AND APPROVED FOR THEIR PURPOSE. CONDUIT AND WIRE SPECIFICATIONS ARE BASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT UP-SIZING.  
 2.4.3 CONDUCTORS SIZED ACCORDING TO NEC 690.8, NEC 690.7.  
 2.4.4 VOLTAGE DROP LIMITED TO 1.5%.  
 2.4.5 DC WIRING LIMITED TO MODULE FOOTPRINT. MICROINVERTER WIRING SYSTEMS SHALL BE LOCATED AND SECURED UNDER THE ARRAY W/ SUITABLE WIRING CLIPS.  
 2.4.6 AC CONDUCTORS COLORED OR MARKED AS FOLLOWS: PHASE A OR L1- BLACK PHASE B OR L2- RED, OR OTHER CONVENTION IF THREE PHASE PHASE C OR L3- BLUE, YELLOW, ORANGE\*\*, OR OTHER CONVENTION NEUTRAL- WHITE OR GREY IN 4-WIRE DELTA CONNECTED SYSTEMS THE PHASE WITH HIGHER VOLTAGE TO BE MARKED ORANGE [NEC 110.15].

**2.5.1 GROUNDING NOTES:**

2.5.2 GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR PURPOSE, AND GROUNDING DEVICES EXPOSED TO THE ELEMENTS SHALL BE RATED FOR SUCH USE.  
 2.5.3 PV EQUIPMENT SHALL BE GROUNDED ACCORDING TO NEC 690.43 AND MINIMUM NEC TABLE 250.122.  
 2.5.4 METAL PARTS OF MODULE FRAMES, MODULE RACKING, AND ENCLOSURES CONSIDERED GROUNDED IN ACCORD WITH 250.134 AND 250.136(A).  
 2.5.5 EQUIPMENT GROUNDING CONDUCTORS SHALL BE SIZED ACCORDING TO NEC 690.45 AND MICROINVERTER MANUFACTURERS' INSTRUCTIONS.  
 2.5.6 EACH MODULE WILL BE GROUNDED USING WEEB GROUNDING CLIPS AS SHOWN IN MANUFACTURER DOCUMENTATION AND APPROVED BY THE AHJ. IF WEEBS ARE NOT USED, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE SPECIFIED GROUNDING LUG HOLES PER THE MANUFACTURERS' INSTALLATION REQUIREMENTS.  
 2.5.7 THE GROUNDING CONNECTION TO A MODULE SHALL BE ARRANGED SUCH THAT THE REMOVAL OF A MODULE DOES NOT INTERRUPT A GROUNDING CONDUCTOR TO ANOTHER MODULE.  
 2.5.8 GROUNDING AND BONDING CONDUCTORS, IF INSULATED, SHALL BE COLORED GREEN OR MARKED GREEN IF #4 AWG OR LARGER [NEC 250.119]  
 2.5.9 THE GROUNDING ELECTRODE SYSTEM COMPLIES WITH NEC 690.47 AND NEC 250.50 THROUGH 250.106. IF EXISTING SYSTEM IS INACCESSIBLE, OR INADEQUATE, A GROUNDING ELECTRODE SYSTEM PROVIDED ACCORDING TO NEC 250, NEC 690.47 AND AHJ.  
 2.5.10 GROUND-FAULT DETECTION SHALL COMPLY WITH NEC 690.41(B)(1) AND (2) TO REDUCE FIRE HAZARDS

**2.6.1 DISCONNECTION AND OVER-CURRENT PROTECTION NOTES:**

2.6.2 DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHEN THE SWITCH IS OPENED THE CONDUCTORS REMAINING ENERGIZED ARE RECONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS).  
 2.6.3 DISCONNECTS TO BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH  
 2.6.4 PV SYSTEM CIRCUITS INSTALLED ON OR IN BUILDINGS SHALL INCLUDE A RAPID SHUTDOWN FUNCTION TO REDUCE SHOCK HAZARD FOR EMERGENCY RESPONDERS IN ACCORDANCE WITH 690.12(A) THROUGH (D).  
 2.6.5 ALL OCPD RATINGS AND TYPES SPECIFIED ACCORDING TO NEC 690.8, 690.9, AND 240.  
 2.6.6 MICROINVERTER BRANCHES CONNECTED TO A SINGLE BREAKER OR GROUPED FUSES IN ACCORDANCE WITH NEC 110.3(B).  
 2.6.7 IF REQUIRED BY AHJ, SYSTEM WILL INCLUDE ARC-FAULT CIRCUIT PROTECTION ACCORDING TO NEC 690.11 AND UL 1699B.

**2.7.1 INTERCONNECTION NOTES:**

2.7.2 LOAD-SIDE INTERCONNECTION SHALL BE IN ACCORDANCE WITH [NEC 705.12 (B)]  
 2.7.3 THE SUM OF THE UTILITY OCPD AND INVERTER CONTINUOUS OUTPUT MAY NOT EXCEED 120% OF BUSBAR RATING [NEC 705.12(D)(2)(3)].  
 2.7.4 THE SUM OF 125 PERCENT OF THE POWER SOURCE(S) OUTPUT CIRCUIT CURRENT AND THE RATING OF THE OVERCURRENT DEVICE PROTECTING THE BUSBAR SHALL NOT EXCEED 120 PERCENT OF THE AMPACITY OF THE BUSBAR, PV DEDICATED BACKFEED BREAKERS MUST BE LOCATED OPPOSITE END OF THE BUS FROM THE UTILITY SOURCE OCPD [NEC 705.12(B)(2)(3)].  
 2.7.5 AT MULTIPLE ELECTRIC POWER SOURCES OUTPUT COMBINER PANEL, TOTAL RATING OF ALL OVERCURRENT DEVICES SHALL NOT EXCEED AMPACITY OF BUSBAR. HOWEVER, THE COMBINED OVERCURRENT DEVICE MAY BE EXCLUDED ACCORDING TO NEC 705.12 (B)(2)(3)(C).  
 2.7.6 FEEDER TAP INTERCONNECTION (LOADSIDE) ACCORDING TO NEC 705.12 (B)(2)(1)  
 2.7.7 SUPPLY SIDE TAP INTERCONNECTION ACCORDING TO NEC 705.12 (A) WITH SERVICE ENTRANCE CONDUCTORS IN ACCORDANCE WITH NEC 230.42  
 2.7.8 BACKFEEDING BREAKER FOR ELECTRIC POWER SOURCES OUTPUT IS EXEMPT FROM ADDITIONAL FASTENING [NEC 705.12 (B)(5)].



22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS

**STEPHEN TOASO**  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA

Signature with Seal


REV	DESCRIPTION	DATE		

SHEET TITLE  
**NOTES**

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**G-001**

LENNIE SMITH RD



GEORGE WARREN RD




Vector Structural Engineering's structural scope of work is for the foundation only.

VSE Project Number: U3573.2777.201



**LEGEND**

- FIRE SETBACK
- PROPERTY LINE
- JUNCTION BOX
- SKYLIGHT (ROOF OBSTRUCTION)
- CHIMNEY (ROOF OBSTRUCTION)
- VENT, ATTIC FAN (ROOF OBSTRUCTION)



1 | **SITE PLAN**  
**SCALE: 1/32" = 1'-0"**

**SUNPRO**  
 22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS  
**STEPHEN TOASO**  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA

Signature with Seal

REVISIONS	DESCRIPTION	DATE
REV		

SHEET TITLE  
**SITE PLAN**


DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**A-101**




- ① - MODULE STRING
- ② - MODULE STRING

ARRAY 1 TILT - 30°  
AZIMUTH - 180°  
MODULE - 24



**LEGEND**

- FIRE SETBACK
- PROPERTY LINE
- JUNCTION BOX
- SKYLIGHT (ROOF OBSTRUCTION)
- CHIMNEY (ROOF OBSTRUCTION)
- VENT, ATTIC FAN (ROOF OBSTRUCTION)



**1 | ELECTRICAL PLAN**  
**SCALE: 1/16" = 1'-0"**

**SUNPRO**  
22171 MCH RD  
MANDEVILLE, LA 70471  
PHONE: 9152011490

PROJECT NAME & ADDRESS  
**STEPHEN TOASO**  
285 LENNIE SMITH RD,  
FUQUAY-VARINA, NC  
27526, USA

Signature with Seal






REVISIONS	DESCRIPTION	REV	DATE	
			REV	DATE


SHEET TITLE  
**ELECTRICAL PLAN**

DRAWN DATE 09/26/2020  
DRAWN BY YAZ  
REVIEWED BY -

SHEET NUMBER  
**A-102**

FOOTING DEPTH - 4.5'  
FOOTING DIAMETER - 1.6'

-  - CLAMP
-  - SM HD RAIL
-  - SQUARE BRACE
-  - PIPE 3(2" SCH 40 GAL PIPE)
-  - PIPE 1,2(2" SCH 40 GAL PIPE)



ARRAY 1  
TILT- 30 DEG  
AZIMUTH - 180 DEG



651 W. GALENA PARK BLVD. STE. 101 DRAPER, UTAH 84020 PHONE (801) 990-1775 WWW.VECTORSE.COM

**Vector Structural Engineering's structural scope of work is for the foundation only.**

VSE Project Number: U3573.2777.201



1 | ATTACHMENT PLAN  
SCALE: 1/4" = 1'-0"

**SUNPRO**  
22171 MCH RD  
MANDEVILLE, LA 70471  
PHONE: 9152011490

PROJECT NAME & ADDRESS  
**STEPHEN TOASO**  
285 LENNIE SMITH RD,  
FUQUAY-VARINA, NC  
27526, USA

Signature with Seal

REVISIONS	DESCRIPTION	DATE
REV		

SHEET TITLE  
ATTACHMENT PLAN

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
A-103

**SOLAR MODULE SPECIFICATIONS**

MANUFACTURER / MODEL #	LG ELECTRONICS LG355N1C-N5
VMP	35.7V
IMP	9.95A
VOC	41.4V
ISC	10.65A
TEMP. COEFF. VOC	-0.27%/°C
MODULE DIMENSION	66.4"L x 40"W x 1.57"D (In Inch)

**INVERTER SPECIFICATIONS**

MANUFACTURER / MODEL #	ENPHASE IQ 7 PLUS MICROINVERTER
MIN/MAX DC VOLT RATING	22V MIN/ 60V MAX
MAX INPUT POWER	235W-440W
NOMINAL AC VOLTAGE RATING	240V/ 211-264V
MAX AC CURRENT	1.21A
MAX MODULES PER STRING	13 (SINGLE PHASE)
MAX OUTPUT POWER	290 VA

**WIRE /CONDUIT SCHEDULE**

TAG	DESCRIPTION
1	#12 THWN-2 & (1)#6 THWN-2 GROUND / 1" PVC CONDUIT
2	#6 THWN-2 & (1)#6 THWN-2 GROUND /1" PVC CONDUIT (IN TRENCH, 18" DEEP, 166' APPROX)
3	#6 THWN-2 & (1)#6 THWN-2 GROUND /1" PVC CONDUIT
4	#6 THWN-2 & (1)#6 THWN-2 GROUND /1" PVC CONDUIT
5	(1)#6 BARE GROUND




22171 MCH RD  
MANDEVILLE, LA 70471  
PHONE: 9152011490

PROJECT NAME & ADDRESS

**STEPHEN TOASO**  
285 LENNIE SMITH RD,  
FUQUAY-VARINA, NC  
27526, USA

Signature with Seal



REVISIONS

REV	DESCRIPTION	DATE

SHEET TITLE  
**LINE DIAGRAM**

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**E-601**

AMBIENT TEMPERATURE SPECS	
RECORD LOW TEMP	-10°
AMBIENT TEMP (HIGH TEMP 2%)	36°
CONDUIT HEIGHT	0.5"
CONDUCTOR TEMPERATURE RATE	90°
MODULE TEMPERATURE COEFFICIENT OF Voc	-0.27% /°C

PERCENT OF VALUES	NUMBER OF CURRENT CARRYING CONDUCTORS IN CONDUIT
.80	4-6
.70	7-9
.50	10-20

## CALCULATIONS:

### 1. CURRENT CARRYING CONDUCTOR

#### (A) BEFORE IQ COMBINER PANEL

AMBIENT TEMPERATURE - 36°C ...NEC 310.15(B)(3)(c)  
 TEMPERATURE DERATE FACTOR - 0.91 ...NEC 310.15(B)(2)(a)  
 GROUPING FACTOR - 0.8...NEC 310.15(B)(3)(a)

#### CONDUCTOR AMPACITY

= (INV O/P CURRENT) x 1.25 / A.T.F / G.F ...NEC 690.8(B)  
 = [(12 x 1.21) x 1.25] / [0.91 x 0.8]  
 = 24.93A

SELECTED CONDUCTOR - #12 THWN-2 ...NEC 310.15(B)(16)

#### (B) AFTER SUB PANEL TEMPERATURE DERATE FACTOR - 0.91 GROUPING FACTOR - 1

#### CONDUCTOR AMPACITY

= (TOTAL INV O/P CURRENT) x 1.25 / 0.91 x 1 ...NEC 690.8(B)  
 = [(24 x 1.21) x 1.25] / [0.91 x 1]  
 = 39.89 A

SELECTED CONDUCTOR - #6 THWN-2 ...NEC 310.15(B)(16)

### 2. PV OVER CURRENT PROTECTION ...NEC 690.9(B)

= TOTAL INVERTER O/P CURRENT x 1.25  
 = (24 x 1.21) x 1.25 = 36.3 A

### 3. VOLTAGE DROP CALCULATION

VOLTAGE DROP= (0.2 x LENGTH OF CONDUCTOR x  
 CURRENT x RESISTANCE IN CONDUCTOR) / 240  
 = (0.2 x 166 x 29.04 x .49 ( FOR #6 AWG WIRE) ) / 240  
 = 1.97%

VOLTAGE DROP IS WITHIN PERMISSIBLE LIMIT OF  
 3%.HENCE OK



22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS

STEPHEN TOASO  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA

Signature with Seal

REVISIONS	DESCRIPTION	REV	DATE	
			DATE	

SHEET TITLE  
 ELECTRICAL  
 CALCULATIONS

DRAWN DATE 09/26/2020  
 DRAWN BY YAZ  
 REVIEWED BY -

SHEET NUMBER  
 E-602

**WARNING:  
PHOTOVOLTAIC  
POWER SOURCE**

**LABEL 1**  
ON ALL CONDUITS SPACED AT MAX 10FT

**! WARNING !**  
ELECTRIC SHOCK HAZARD  
DO NOT TOUCH TERMINALS.  
TERMINALS ON BOTH LINE AND LOAD SIDES  
MAY BE ENERGIZED IN THE OPEN POSITION

**LABEL 5**  
AT EACH AC DISCONNECT

**! CAUTION !**  
SOLAR POINT OF  
INTERCONNECTION

**LABEL 9**  
AT UTILITY METER

**! CAUTION !**  
SOLAR ELECTRIC  
SYSTEM CONNECTED  
AND ENERGIZED

**LABEL 2**  
AT INVERTER

**PHOTOVOLTAIC  
AC DISCONNECT**


**LABEL 6**  
AT EACH AC DISCONNECT

**! WARNING !**  
THE SERVICE METER IS ALSO SERVED  
BY A PHOTOVOLTAIC SYSTEM

**LABEL 10**  
AT UTILITY METER

**SOLAR PV SYSTEM EQUIPPED  
WITH RAPID SHUTDOWN**


TURN RAPID SHUTDOWN  
SWITCH TO THE  
"OFF" POSITION TO  
SHUT DOWN PV SYSTEM  
AND REDUCE  
SHOCK HAZARD  
IN THE ARRAY



**LABEL 3**  
AT INVERTER

**! WARNING !**  
DUAL POWER SOURCES  
SECOND SOURCE IS PV SYSTEM

**LABEL 7**  
AT MEP



**PHOTOVOLTAIC  
DC DISCONNECT**

**LABEL 4**  
AT DC DISCONNECT

**! WARNING !**  
SOLAR SYSTEM CONNECTED  
AND ENERGIZED

**LABEL 8**  
AT MEP



22171 MCH RD  
MANDEVILLE, LA 70471  
PHONE: 9152011490

PROJECT NAME & ADDRESS  
**STEPHEN TOASO**  
285 LENNIE SMITH RD,  
FUQUAY-VARINA, NC  
27526, USA

Signature with Seal

REVISIONS	DESCRIPTION	REV	DATE	
			REV	DATE

SHEET TITLE  
**PLACARDS**

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**E-603**





15 YEARS LONGER THAN INDUSTRY STANDARD OF 10 YEARS



# LG NeON<sup>2</sup>

LG350/355N1C-V5

THE HIGH PERFORMER

UP TO 20.7% MODULE EFFICIENCY

## Awards Received By LG Solar™



## THE NeON<sup>2</sup> - 355W - THE PANEL OF THE FUTURE AVAILABLE TODAY

The LG NeON<sup>2</sup> has seen many improvements, from longer warranties to lower degradation. This panel is ideal for homes seeking a visually pleasing solar panel and for roofs where space is tight or where future system expansions are considered e.g. to incorporate battery storage.

The LG NeON<sup>2</sup> panels with their double sided cells and CELLO technology absorb light from the front and the back of the cell. This technology sets a new standard for innovation and was recognised with the 2015 Photovoltaic Innovation Award at the Intersolar Industry Event in Germany. LG also won the 2016 Intersolar award for our new NeON BiFacial range.

### Great Visual Appearance

LG NeON<sup>2</sup> panels have been designed with appearance in mind. Their black cells, black frames and thinner wire busbars give an aesthetically pleasing uniform black appearance. Your home deserves the LG NeON<sup>2</sup>.

### 25 Years Product Warranty (Parts & Labour)

The LG product warranty is 15 years longer than many competitors standard 10 years. The Warranty is provided by LG Electronics Australia and New Zealand. The warranty includes replacement, labour and transport.

### More Power per Square Metre

LG NeON<sup>2</sup>'s 355W are a similar physical size to many competing 300W panels. This means with the LG NeON<sup>2</sup> 355W you get 18% more electricity per square metre than a 300W panel. So you can install more kW of solar on your roof with the LG NeON<sup>2</sup>.

### Improved 25 Year Performance Warranty

The initial degradation of the module has been improved from -3% to -2%, in the 1st year and the annual rate of degradation has fallen from -0.7%/year to -0.33%/ year thereafter. This brings an 90.08% warranted output after 25 years, compared to 80.2% for many competing panels.

Made in Korea

Call LG Solar on 1300 152 179

www.lgenergy.com.au

# LG NeON<sup>2</sup>

## Mechanical Properties

Cells	6 x 10
Cell Vendor	LG
Cell Type	Monocrystalline / N-type
Cell Dimensions	161.7 x 161.7 mm
# of Busbar	12 (Multi Wire Busbar)
Dimensions (L x W x H)	1686 x 1016 x 40 mm
Front Load (test)	5400 Pa
Rear Load (test)	4000 Pa
Weight	17.1 kg
Connector Type	Genuine MC4, IP68 (Male: PV-KST4) (Female: PV-KBT4)
Junction Box	IP68 with 3 bypass diodes
Length of Cables	2 x 1000 mm
Front cover	High transmission tempered glass
Frame	Anodised aluminum with protective matt black coating

## Certifications and Warranty


Certifications	ISO 9001, ISO 14001, ISO 50001 IEC 61215-1/-1-1/2:2016, IEC 61730-1/2:2016, UL1703 OHSAS 18001
Module Fire Performance	Type 1 (UL 1703), Class C (UL 790, ULC/ORD C 1703)
Product Warranty	25 Years
Output Warranty of Pmax (Measurement Tolerance ± 3%)	Linear Warranty <sup>1</sup>

<sup>1</sup> 1) 1st year: 98%; 2) After 1st year: 0.33% annual degradation; 3) 90.08% for 25 years.


## Temperature Characteristics

NMOT	42 ± 3 °C
Pmax	-0.36 %/°C
Voc	-0.27 %/°C
Isc	0.03 %/°C

## Current - Voltage characteristics at various irradiance levels



## Current - Voltage characteristics at various cell temperatures



## Electrical Properties (STC<sup>2</sup>)

Module Type	350 W	355 W
Maximum Power Pmax (W)	350	355
MPP Voltage Vmpp (V)	35.3	35.7
MPP Current Imp (A)	9.92	9.95
Open Circuit Voltage Voc (V)	41.3	41.4
Short Circuit Current Isc (A)	10.61	10.65
Module Efficiency (%)	20.4	20.7
Operating Temperature (°C)	-40 ~ +90	
Maximum System Voltage (V)	1000	
Maximum Series Fuse Rating (A)	20	
Power Tolerance (%)	0 ~ +3	


<sup>2</sup> STC (Standard Test Condition): Irradiance 1000 W/m<sup>2</sup>, Module Temperature 25 °C, AM 1.5. The nameplate power output is measured and determined by LG Electronics at its sole and absolute discretion.

## Electrical Properties (NMOT<sup>3</sup>)

Module Type	350 W	355 W
Maximum Power Pmax (W)	262	266
MPP Voltage Vmpp (V)	33.2	33.5
MPP Current Imp (A)	7.91	7.93
Open Circuit Voltage Voc (V)	38.9	39.0
Short Circuit Current Isc (A)	8.52	8.56

<sup>3</sup> NMOT (Nominal Module Operating Temperature): Irradiance 800 W/m<sup>2</sup>, ambient temperature 20 °C, wind speed 1 m/s, Spectrum AM 1.5.

## Dimensions (mm)



LG Electronics Australia Pty Ltd  
Solar Business Group  
2 Wonderland Drive, Eastern Creek, NSW 2766  
Ph: 1300 152 179  
E-Mail: solarsales@lge.com.au  
Web: lgenergy.com.au

LG Electronics Inc.  
Solar Business Division  
Twin Building, Western Tower, 11F,  
128, Yeouido-daero, Yeongdeungpo-gu,  
Seoul, 07336, Korea  
www.lg.com/global/business

Product specifications are subject to change without prior notice.  
Date: 08/2019.

Copyright © 2019 LG Electronics.  
All rights reserved.



22171 MCH RD  
MANDEVILLE, LA 70471  
PHONE: 9152011490

PROJECT NAME & ADDRESS

STEPHEN TOASO  
285 LENNIE SMITH RD,  
FUQUAY-VARINA, NC  
27526, USA

Signature with Seal

REVISIONS	DATE			
	DESCRIPTION			
REV				

## SHEET TITLE RESOURCE DOCUMENT

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
R-001



## Enphase IQ 7 and IQ 7+ Microinverters

The high-powered smart grid-ready **Enphase IQ 7 Micro™** and **Enphase IQ 7+ Micro™** dramatically simplify the installation process while achieving the highest system efficiency.

Part of the Enphase IQ System, the IQ 7 and IQ 7+ Microinverters integrate with the Enphase IQ Envoy™, Enphase IQ Battery™, and the Enphase Enlighten™ monitoring and analysis software.

IQ Series Microinverters extend the reliability standards set forth by previous generations and undergo over a million hours of power-on testing, enabling Enphase to provide an industry-leading warranty of up to 25 years.



### Easy to Install

- Lightweight and simple
- Faster installation with improved, lighter two-wire cabling
- Built-in rapid shutdown compliant (NEC 2014 & 2017)

### Productive and Reliable

- Optimized for high powered 60-cell and 72-cell\* modules
- More than a million hours of testing
- Class II double-insulated enclosure
- UL listed

### Smart Grid Ready

- Complies with advanced grid support, voltage and frequency ride-through requirements
- Remotely updates to respond to changing grid requirements
- Configurable for varying grid profiles
- Meets CA Rule 21 (UL 1741-SA)

\* The IQ 7+ Micro is required to support 72-cell modules.



To learn more about Enphase offerings, visit [enphase.com](http://enphase.com)



## Enphase IQ 7 and IQ 7+ Microinverters

INPUT DATA (DC)	IQ7-60-2-US		IQ7PLUS-72-2-US	
Commonly used module pairings <sup>1</sup>	235 W - 350 W +		235 W - 440 W +	
Module compatibility	60-cell PV modules only		60-cell and 72-cell PV modules	
Maximum input DC voltage	48 V		60 V	
Peak power tracking voltage	27 V - 37 V		27 V - 45 V	
Operating range	16 V - 48 V		16 V - 60 V	
Min/Max start voltage	22 V / 48 V		22 V / 60 V	
Max DC short circuit current (module Isc)	15 A		15 A	
Overvoltage class DC port	II		II	
DC port backfeed current	0 A		0 A	
PV array configuration	1 x 1 ungrounded array; No additional DC side protection required; AC side protection requires max 20A per branch circuit			
OUTPUT DATA (AC)	IQ 7 Microinverter		IQ 7+ Microinverter	
Peak output power	250 VA		295 VA	
Maximum continuous output power	240 VA		290 VA	
Nominal (L-L) voltage/range <sup>2</sup>	240 V / 211-264 V	208 V / 183-229 V	240 V / 211-264 V	208 V / 183-229 V
Maximum continuous output current	1.0 A (240 V)	1.15 A (208 V)	1.21 A (240 V)	1.39 A (208 V)
Nominal frequency	60 Hz		60 Hz	
Extended frequency range	47 - 68 Hz		47 - 68 Hz	
AC short circuit fault current over 3 cycles	5.8 Arms		5.8 Arms	
Maximum units per 20 A (L-L) branch circuit <sup>3</sup>	16 (240 VAC)	13 (208 VAC)	13 (240 VAC)	11 (208 VAC)
Overvoltage class AC port	III		III	
AC port backfeed current	0 A		0 A	
Power factor setting	1.0		1.0	
Power factor (adjustable)	0.85 leading ... 0.85 lagging		0.85 leading ... 0.85 lagging	
EFFICIENCY	@240 V	@208 V	@240 V	@208 V
Peak efficiency	97.6 %	97.6 %	97.5 %	97.3 %
CEC weighted efficiency	97.0 %	97.0 %	97.0 %	97.0 %
MECHANICAL DATA				
Ambient temperature range	-40°C to +65°C			
Relative humidity range	4% to 100% (condensing)			
Connector type (IQ7-60-2-US & IQ7PLUS-72-2-US)	MC4 (or Amphenol H4 UTX with additional Q-DCC-5 adapter)			
Dimensions (WxHxD)	212 mm x 175 mm x 30.2 mm (without bracket)			
Weight	1.08 kg (2.38 lbs)			
Cooling	Natural convection - No fans			
Approved for wet locations	Yes			
Pollution degree	PD3			
Enclosure	Class II double-insulated, corrosion resistant polymeric enclosure			
Environmental category / UV exposure rating	NEMA Type 6 / outdoor			
FEATURES				
Communication	Power Line Communication (PLC)			
Monitoring	Enlighten Manager and MyEnlighten monitoring options. Both options require installation of an Enphase IQ Envoy.			
Disconnecting means	The AC and DC connectors have been evaluated and approved by UL for use as the load-break disconnect required by NEC 690.			
Compliance	CA Rule 21 (UL 1741-SA) UL 62109-1, UL1741/IEEE1547, FCC Part 15 Class B, ICES-0003 Class B, CAN/CSA-C22.2 NO. 107.1-01 This product is UL Listed as PV Rapid Shut Down Equipment and conforms with NEC-2014 and NEC-2017 section 690.12 and C22.1-2015 Rule 64-218 Rapid Shutdown of PV Systems, for AC and DC conductors, when installed according manufacturer's instructions.			

1. No enforced DC/AC ratio. See the compatibility calculator at <https://enphase.com/en-us/support/module-compatibility>  
2. Nominal voltage range can be extended beyond nominal if required by the utility.  
3. Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.

To learn more about Enphase offerings, visit [enphase.com](http://enphase.com)

© 2019 Enphase Energy. All rights reserved. All trademarks or brands used are the property of Enphase Energy, Inc. 2019-3-26



22171 MCH RD  
MANDEVILLE, LA 70471  
PHONE: 9152011490

PROJECT NAME & ADDRESS

STEPHEN TOASO  
285 LENNIE SMITH RD,  
FUQUAY-VARINA, NC  
27526, USA

Signature with Seal

REVISIONS	REV	DESCRIPTION	DATE

SHEET TITLE  
**RESOURCE DOCUMENT**

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**R-002**

## Enphase IQ Combiner 3 (X-IQ-AM1-240-3)

The **Enphase IQ Combiner 3™** with Enphase IQ Envoy™ consolidates interconnection equipment into a single enclosure and streamlines PV and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.



### Smart

- Includes IQ Envoy for communication and control
- Flexible networking supports Wi-Fi, Ethernet, or cellular
- Optional AC receptacle available for PLC bridge
- Provides production metering and optional consumption monitoring

### Simple

- Reduced size from previous combiner
- Centered mounting brackets support single stud mounting
- Supports back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- 80 A total PV or storage branch circuits

### Reliable

- Durable NRTL-certified NEMA type 3R enclosure
- Five-year warranty
- UL listed



To learn more about Enphase offerings, visit [enphase.com](http://enphase.com)



## Enphase IQ Combiner 3

### MODEL NUMBER

IQ Combiner 3 X-IQ-AM1-240-3	IQ Combiner 3 with Enphase IQ Envoy™ printed circuit board for integrated revenue grade PV production metering (ANSI C12.20 +/- 0.5%) and optional* consumption monitoring (+/- 2.5%).
------------------------------	--

### ACCESSORIES and REPLACEMENT PARTS (not included, order separately)

Enphase Mobile Connect™ CELLMODEM-03 (4G / 12-year data plan) CELLMODEM-01 (3G / 5-year data plan) CELLMODEM-M1 (4G based LTE-M / 5-year data plan)	Plug and play industrial grade cellular modem with data plan for systems up to 60 microinverters. (Available in the US, Canada, Mexico, Puerto Rico, and the US Virgin Islands, where there is adequate cellular service in the installation area.)
Consumption Monitoring* CT CT-200-SPLIT	Split core current transformers enable whole home consumption metering (+/- 2.5%).
Circuit Breakers BRK-10A-2-240 BRK-15A-2-240 BRK-20A-2P-240	Supports Eaton BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers. Circuit breaker, 2 pole, 10A, Eaton BR210 Circuit breaker, 2 pole, 15A, Eaton BR215 Circuit breaker, 2 pole, 20A, Eaton BR220
EPLC-01	Power line carrier (communication bridge pair), quantity 2.
XA-PLUG-120-3	Accessory receptacle for Power Line Carrier in IQ Combiner 3 (required for EPLC-01)
XA-ENV-PCBA-3	Replacement IQ Envoy printed circuit board (PCB) for Combiner 3

### ELECTRICAL SPECIFICATIONS

Rating	Continuous duty
System voltage	120/240 VAC, 60 Hz
Eaton BR series busbar rating	125 A
Max. continuous current rating (output to grid)	65 A
Max. fuse/circuit rating (output)	90 A
Branch circuits (solar and/or storage)	Up to four 2-pole Eaton BR series Distributed Generation (DG) breakers only (not included)
Max. continuous current rating (input from PV)	64 A
Max. total branch circuit breaker rating (input)	80A of distributed generation / 90A with IQ Envoy breaker included
Production Metering CT	200 A solid core pre-installed and wired to IQ Envoy.

### MECHANICAL DATA

Dimensions (WxHxD)	49.5 x 37.5 x 16.8 cm (19.5" x 14.75" x 6.63"). Height is 21.06" (53.5 cm with mounting brackets).
Weight	7.5 kg (16.5 lbs)
Ambient temperature range	-40° C to +46° C (-40° to 115° F)
Cooling	Natural convection, plus heat shield
Enclosure environmental rating	Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction
Wire sizes	<ul style="list-style-type: none"> <li>• 20 A to 50 A breaker inputs: 14 to 4 AWG copper conductors</li> <li>• 60 A breaker branch input: 4 to 1/0 AWG copper conductors</li> <li>• Main lug combined output: 10 to 2/0 AWG copper conductors</li> <li>• Neutral and ground: 14 to 1/0 copper conductors</li> </ul> Always follow local code requirements for conductor sizing.
Altitude	To 2000 meters (6,560 feet)

### INTERNET CONNECTION OPTIONS

Integrated Wi-Fi	802.11b/g/n
Ethernet	Optional, 802.3, Cat5E (or Cat 6) UTP Ethernet cable (not included)
Cellular	Optional, CELLMODEM-01 (3G) or CELLMODEM-03 (4G) or CELLMODEM-M1 (4G based LTE-M) (not included)

### COMPLIANCE

Compliance, Combiner	UL 1741 CAN/CSA C22.2 No. 107.1 47 CFR, Part 15, Class B, ICES 003 Production metering: ANSI C12.20 accuracy class 0.5 (PV production)
Compliance, IQ Envoy	UL 60601-1/CANCSA 22.2 No. 61010-1

\* Consumption monitoring is required for Enphase Storage Systems.

To learn more about Enphase offerings, visit [enphase.com](http://enphase.com)

© 2018 Enphase Energy. All rights reserved. All trademarks or brands in this document are registered by their respective owner.  
2018-09-13



22171 MCH RD  
MANDEVILLE, LA 70471  
PHONE: 9152011490

PROJECT NAME & ADDRESS

STEPHEN TOASO  
285 LENNIE SMITH RD,  
FUQUAY-VARINA, NC  
27526, USA

Signature with Seal



REV	DESCRIPTION	DATE	REVISIONS	

SHEET TITLE  
**RESOURCE DOCUMENT**

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**R-003**





**UNIRAC**  
 1411 BROADWAY BLVD NE  
 ALBUQUERQUE, NM 87102 USA  
 WWW.UNIRAC.COM



<b>PRODUCT LINE:</b>	ULA
<b>DRAWING TYPE:</b>	ASSEMBLY
<b>DESCRIPTION:</b>	ASSEMBLY EXAMPLE
<b>REVISION DATE:</b>	APRIL 2016

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE  
 OR MORE US PATENTS

**LEGAL NOTICE**

**ULA-A01**  
 SHEET



**UNIRAC**  
 1411 BROADWAY BLVD NE  
 ALBUQUERQUE, NM 87102 USA  
 WWW.UNIRAC.COM

<b>PRODUCT LINE:</b>	ULA
<b>DRAWING TYPE:</b>	ASSEMBLY
<b>DESCRIPTION:</b>	ASSEMBLY EXAMPLE
<b>REVISION DATE:</b>	APRIL 2016

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE  
 OR MORE US PATENTS

**LEGAL NOTICE**

**ULA-A02**  
 SHEET

**SUNPRO**

22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS  
**STEPHEN TOASO**  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA

Signature with Seal


REV	DESCRIPTION	DATE

SHEET TITLE  
**RESOURCE DOCUMENT**

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**R-004**





**UNIRAC**  
 1411 BROADWAY BLVD NE  
 ALBUQUERQUE, NM 87102 USA  
 WWW.UNIRAC.COM


<b>PRODUCT LINE:</b>	ULA
<b>DRAWING TYPE:</b>	ASSEMBLY
<b>DESCRIPTION:</b>	ULA FOUNDATION
<b>REVISION DATE:</b>	APRIL 2016

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE  
 OR MORE US PATENTS

**LEGAL NOTICE**

**ULA-A03**  
 SHEET



**UNIRAC**  
 1411 BROADWAY BLVD NE  
 ALBUQUERQUE, NM 87102 USA  
 WWW.UNIRAC.COM

<b>PRODUCT LINE:</b>	ULA
<b>DRAWING TYPE:</b>	PART
<b>DESCRIPTION:</b>	ALUM FRONT CAP
<b>REVISION DATE:</b>	APRIL 2016

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE  
 OR MORE US PATENTS

**LEGAL NOTICE**

**ULA-A04**  
 SHEET

**SUNPRO**  
 22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS  
**STEPHEN TOASO**  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA


Signature with Seal

REV	DESCRIPTION	DATE

SHEET TITLE  
**RESOURCE DOCUMENT**

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**R-005**



**UNIRAC**  
 1411 BROADWAY BLVD NE  
 ALBUQUERQUE, NM 87102 USA  
 WWW.UNIRAC.COM


<b>PRODUCT LINE:</b>	ULA
<b>DRAWING TYPE:</b>	PART
<b>DESCRIPTION:</b>	ALUMINUM REAR CAP
<b>REVISION DATE:</b>	APRIL 2016

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE  
 OR MORE US PATENTS

**LEGAL NOTICE**

**ULA-A05**  
 SHEET



**UNIRAC**  
 1411 BROADWAY BLVD NE  
 ALBUQUERQUE, NM 87102 USA  
 WWW.UNIRAC.COM

<b>PRODUCT LINE:</b>	ULA
<b>DRAWING TYPE:</b>	PART
<b>DESCRIPTION:</b>	ALUM SLIDER
<b>REVISION DATE:</b>	APRIL 2016

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE  
 OR MORE US PATENTS

**LEGAL NOTICE**

**ULA-A06**  
 SHEET



22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS  
**STEPHEN TOASO**  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA


Signature with Seal

REV	DESCRIPTION	DATE

SHEET TITLE  
**RESOURCE DOCUMENT**

DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**R-006**



**UNIRAC**  
 1411 BROADWAY BLVD NE  
 ALBUQUERQUE, NM 87102 USA  
 WWW.UNIRAC.COM


<b>PRODUCT LINE:</b>	ULA
<b>DRAWING TYPE:</b>	PART
<b>DESCRIPTION:</b>	UNIVERSAL RAIL BRACKET
<b>REVISION DATE:</b>	APRIL 2016

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE  
 OR MORE US PATENTS

**LEGAL NOTICE**

**ULA-A07**  
 SHEET



**UNIRAC**  
 1411 BROADWAY BLVD NE  
 ALBUQUERQUE, NM 87102 USA  
 WWW.UNIRAC.COM

<b>PRODUCT LINE:</b>	ULA
<b>DRAWING TYPE:</b>	ASSEMBLY
<b>DESCRIPTION:</b>	PORTRAIT ORIENTATION
<b>REVISION DATE:</b>	APRIL 2016

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE  
 OR MORE US PATENTS

**LEGAL NOTICE**

**ULA-A08**  
 SHEET

**SUNPRO**

22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS


**STEPHEN TOASO**  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA

Signature with Seal

REV	DESCRIPTION	DATE

SHEET TITLE	
<b>RESOURCE DOCUMENT</b>	
DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**R-007**



**UNIRAC**  
 1411 BROADWAY BLVD NE  
 ALBUQUERQUE, NM 87102 USA  
 WWW.UNIRAC.COM

<b>PRODUCT LINE:</b>	ULA
<b>DRAWING TYPE:</b>	PART
<b>DESCRIPTION:</b>	STEEL THREADED FOOT
<b>REVISION DATE:</b>	APRIL 2016

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE NOMINAL

PRODUCT PROTECTED BY ONE  
 OR MORE US PATENTS

**LEGAL NOTICE**

**ULA-P01**  
 SHEET



22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS

**STEPHEN TOASO**  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA


Signature with Seal

REVISIONS		DATE
REV	DESCRIPTION	

SHEET TITLE	
<b>RESOURCE DOCUMENT</b>	
DRAWN DATE	09/26/2020
DRAWN BY	YAZ
REVIEWED BY	-

SHEET NUMBER  
**R-008**





PART # TABLE		
P/N	DESCRIPTION	LENGTH
410144M	SMHD, RAIL 144" MILL	144"
410168M	SMHD, RAIL 168" MILL	168"
410204M	SMHD, RAIL 204" MILL	204"
410240M	SMHD, RAIL 240" MILL	240"

**UNIRAC**  
 1411 BROADWAY BLVD. NE  
 ALBUQUERQUE, NM 87102 USA  
 PHONE: 505.242.6411  
 WWW.UNIRAC.COM

PRODUCT LINE: SOLARMOUNT  
 DRAWING TYPE: PART DETAIL  
 DESCRIPTION: HD RAIL  
 REVISION DATE: 9/11/2017

DRAWING NOT TO SCALE  
 ALL DIMENSIONS ARE  
 NOMINAL  
 PRODUCT PROTECTED BY  
 ONE OR MORE US PATENTS  
 LEGAL NOTICE

**SM-P03**  
 SHEET



22171 MCH RD  
 MANDEVILLE, LA 70471  
 PHONE: 9152011490

PROJECT NAME & ADDRESS  
**STEPHEN TOASO**  
 285 LENNIE SMITH RD,  
 FUQUAY-VARINA, NC  
 27526, USA

Signature with Seal

REVISIONS	REV	DESCRIPTION	DATE

SHEET TITLE  
**RESOURCE DOCUMENT**

DRAWN DATE: 09/26/2020  
 DRAWN BY: YAZ  
 REVIEWED BY: -

SHEET NUMBER  
**R-009**