



**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

5/20/2021

**SUBJECT: ERES2102-0059**  
**ELECTRICAL RESIDENTIAL**

To: CMC ELECTRIC LLC

Here are the results of all Inspections located at **144 BROWER RD:**

Inspection Type: RE-CONNECT  
Scheduled Date/Time: 3/10/2021  
Completed Date/Time: 3/10/2021  
Inspector: Steven Gazlay  
Result: CANCELLED  
Remarks:  
Notes:

Inspection Type: RE-CONNECT  
Scheduled Date/Time: 3/22/2021  
Completed Date/Time: 3/22/2021  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 3/26/2021  
Completed Date/Time: 3/26/2021  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Gas piping never scheduled. Label breakers in panel.

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 4/14/2021  
Completed Date/Time: 4/14/2021  
Inspector: Steven Gazlay  
Result: FAIL W/ PENALTY  
Remarks:  
Notes: Label panel per previous inspection.



**Harnett County**  
108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: GAS PIPING  
Scheduled Date/Time: 4/14/2021  
Completed Date/Time: 4/14/2021  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 5/19/2021  
Completed Date/Time: 5/19/2021  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes: Previous items