

March 16, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Powerhome Solar
919 N Main Street
Mooresville, NC 28115

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Tank Application # BRES2102-0066

Mr. Denicola:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out


3. Replace Sanitary T

4. **Other – Proposed solar array not marked onsite and outlet end of septic tank not uncovered and lid not accessible. Additionally, proposed power access site must be marked onsite and on site plan. Existing septic field marked onsite.**

Existing septic field marked onsite. Mark solar array onsite and proposed power access route. Ensure both are off flagged septic area. Revise paperwork accordingly with power route and revised array location if required. Lastly, uncover outlet end of septic tank, break outlet end lid free, and leave exposed for inspection. If not completed recently, Tank is routinely pumped and outlet lid left exposed by pumper or exposed by homeowner.

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting