HTE #: ERES2102-0066RR

HARNETT COUNTY HEALTH DEPARTMENT ENVIRONMENTAL HEALTH 307 CORNELIUS HARNETT BOULEVARD LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: POWER HOME SOLAR LLC Phone #: (919) 300-7976

Address: 919 N. MAIN STREET MOORESVILLE, NC 28115

Name of Mobile Home Park or S/D: NOT APPLICABLE

Name of Owner (if different): LORENZA CREEKMUR JR

Address of Owner (if different): <u>562 HARVELL RD COATS, NC 27521</u>

Property Location (State Road name and #): 562 HARVELL RD (SR 2008)

Purpose of Inspection: <u>22 GROUND MOUNTED SOLAR PANELS - DRAINLINES</u>
<u>MARKED ONSITE VIA GPR - REVISED TO MEET SEPTIC SETBACKS - SITE PLAN</u>
<u>SHOWS TRENCHING GOING AROUND SEPTIC AREA - DO NOT CROSS SEPTIC AREA</u>
WITH POWER SUPPLY

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- 1. the intended use of the septic system should change, and/or
- 2. the system should fail or malfunction, and/or
- 3. the owner or tenant of the property change, and/or
- 4. after six months

BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM DO NOT DRIVE OR PARK ON SEPTIC SYSTEM

AUTHORIZATION OF EXISTING SYSTEM

Signature of Environmental Health Specialist

Date