



LEADING THE WAY  
Structural Engineering Firm  
NC License No. C-2499

168 Quade Drive  
Cary, North Carolina 27513  
www.rbengineering.com

Phone: 919-677-9662 / Cell: 919-280-2695 / Fax: 919-677-9663

E-mail: [rbittler@rbengineering.com](mailto:rbittler@rbengineering.com)

Mr. Max Middleton

March 23, 2021

**Yes! Solar Solutions of the Triangle**

E-mail: [mmiddleton@yessolarsolutions.com](mailto:mmiddleton@yessolarsolutions.com)

Subject: Roof mounted solar panels – Butler Residence  
111 Dees Street  
Lillington, North Carolina 27546

File No.: RB-216884

Dear Max:

RB Engineering, Inc. is pleased to provide the following summary engineering letter concerning the subject project. The existing roof system is constructed with 2-inch by 6-inch timber framing at 16 inches on center, a plywood roof deck and a corrugated metal roof. Some attic bracing exists. We have reviewed the proposed solar layout and have structurally evaluated the additional proposed roof loading with the following conclusions:

- The total surface area of the new proposed solar array (48 PV modules) is approximately 870 SF. The solar panel installation has been evaluated for an ultimate design wind speed of 120 mph.
- The subject roof mounted PV system attachment method is structurally adequate to transfer the design uplift loads in accordance with the current North Carolina residential building code.
- The existing roof system is structurally adequate to transfer the applicable design loads - including the additional or modified design loading (dead, wind and snow loads) due to the proposed solar panel installation - in accordance with the current North Carolina residential building code.

Our services were provided in accordance with the standard of practice for structural engineering and within the limits imposed by scope, schedule, and budget. If you have any questions or if I can be of further assistance to you on this project, please contact me at (919) 677-9662.

Respectfully submitted,

Ron Bittler, PE  
President / Structural Engineer  
RB Engineering, Inc.

Ron  
Bittler,  
PE

Digitally signed by  
Ron Bittler, PE  
DN: cn=Ron Bittler,  
PE, o=RB  
Engineering, Inc., ou,  
email=rbittler@rben  
gineering.com, c=US  
Date: 2021.03.23  
08:42:27 -04'00'



03.23.2021

**GENERAL NOTES**

- 1.1.1 **PROJECT NOTES:**
- 1.1.2 THIS PHOTOVOLTAIC (PV) SYSTEM SHALL COMPLY WITH THE NATIONAL ELECTRIC CODE (NEC) ARTICLE 690, ALL MANUFACTURER'S LISTING AND INSTALLATION INSTRUCTIONS, AND THE RELEVANT CODES AS SPECIFIED BY THE AUTHORITY HAVING JURISDICTION'S (AHJ) APPLICABLE CODES.
- 1.1.3 THE UTILITY INTERCONNECTION APPLICATION MUST BE APPROVED AND PV SYSTEM INSPECTED PRIOR TO PARALLEL OPERATION
- 1.1.4 ALL PV SYSTEM COMPONENTS; MODULES, UTILITY-INTERACTIVE INVERTERS, AND SOURCE CIRCUIT COMBINER BOXES ARE IDENTIFIED AND LISTED FOR USE IN PHOTOVOLTAIC SYSTEMS AS REQUIRED BY NEC 690.4: **PV MODULES:** UL1703, IEC61730, AND IEC61215, AND NFPA 70 CLASS C FIRE **INVERTERS:** UL 1741 CERTIFIED, IEEE 1547, 929, 519 **COMBINER BOX(ES):** UL 1703 OR UL 1741 ACCESSORY.
- 1.1.8 MAX DC VOLTAGE CALCULATED USING MANUFACTURER PROVIDED TEMP COEFFICIENT FOR VOC. IF UNAVAILABLE, MAX DC VOLTAGE CALCULATED ACCORDING TO NEC 690.7.
- 1.1.9 ALL INVERTERS, PHOTOVOLTAIC MODULES, PHOTOVOLTAIC PANELS, AND SOURCE CIRCUIT COMBINERS INTENDED FOR USE IN A PHOTOVOLTAIC POWER SYSTEM WILL BE IDENTIFIED AND LISTED FOR THE APPLICATION PER 690.4 (D). SHALL BE INSTALLED ACCORDING TO ANY INSTRUCTIONS FROM LISTING OR LABELING [NEC 110.3].
- 1.1.10 ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE. IF EXPOSED TO SUNLIGHT, IT SHALL BE UV RESISTANT. ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS REQUIRED BY THE NEC AND AHJ.
- 1.2.1 **SCOPE OF WORK:**
- 1.2.2 PRIME CONTRACTOR IS RESPONSIBLE FOR THE DESIGN AND SPECIFICATIONS OF THE GRID-TIED PHOTOVOLTAIC SYSTEM RETROFIT. PRIME CONTRACTOR WILL BE RESPONSIBLE FOR COLLECTING EXISTING ONSITE REQUIREMENTS TO DESIGN, SPECIFY, AND INSTALL THE EXTERIOR ROOF-MOUNTED PORTION OF THE PHOTOVOLTAIC SYSTEMS DETAILED IN THIS DOCUMENT.
- 1.3.1 **WORK INCLUDES:**
- 1.3.2 PV ROOF ATTACHMENTS - S15 PROTEA BRACKET
- 1.3.3 PV RACKING SYSTEM INSTALLATION - SNAPRACK UR-40
- 1.3.4 PV MODULE AND INVERTER INSTALLATION - REC REC330TP3M BLACK / SOLAR EDGE SE7600H-US (240V) / SOLAR EDGE SE6000H-US (240V)
- 1.3.5 PV EQUIPMENT GROUNDING
- 1.3.6 PV SYSTEM WIRING TO A ROOF-MOUNTED JUNCTION BOX
- 1.3.7 PV LOAD CENTERS (IF INCLUDED)
- 1.3.8 PV METERING/MONITORING (IF INCLUDED)
- 1.3.9 PV DISCONNECTS
- 1.3.10 PV FINAL COMMISSIONING
- 1.3.11 (E) ELECTRICAL EQUIPMENT RETROFIT FOR PV
- 1.3.12 SIGNAGE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE

**SCOPE OF WORK**

**SYSTEM SIZE:** STC: 48 x 330W = 15.840kW  
 PTC: 48 x 308.8W = 14.822kW DC  
 (48) REC REC330TP3M BLACK  
 (1) SOLAR EDGE SE7600H-US (240V)  
 (1) SOLAR EDGE SE6000H-US (240V)


**ATTACHMENT TYPE:** S15 PROTEA BRACKET

**MSP UPGRADE:** NO


# NEW PV SYSTEM: 15.840 kWp

## BUTLER RESIDENCE

111 DEES ST  
 LILLINGTON, NC 27546  
 ASSESSOR'S #: 1306400004



**01** AERIAL PHOTO  
 NOT TO SCALE



**02** PLAT MAP  
 NOT TO SCALE



**SHEET LIST TABLE**

SHEET NUMBER	SHEET TITLE
T-001	COVER PAGE
G-001	NOTES
A-101	SITE PLAN
A-102	ELECTRICAL PLAN
A-103	SOLAR ATTACHMENT PLAN
E-601	LINE DIAGRAM
E-602	DESIGN TABLES
E-603	PLACARDS
S-501	ASSEMBLY DETAILS
R-001	RESOURCE DOCUMENT
R-002	RESOURCE DOCUMENT
R-003	RESOURCE DOCUMENT
R-004	RESOURCE DOCUMENT
R-005	RESOURCE DOCUMENT
R-006	RESOURCE DOCUMENT
R-007	RESOURCE DOCUMENT

**PROJECT INFORMATION**

**OWNER**  
 NAME: PATRICK BUTLER  
 PHONE: 913-948-1933  
 E-MAIL: PATRICKBUTLER1@GMAIL.COM

**PROJECT MANAGER**  
 NAME: DUSTIN SMITH  
 PHONE:

**CONTRACTOR**  
 NAME: YES SOLAR SOLUTIONS  
 PHONE: 919-459-2846

**AUTHORITIES HAVING JURISDICTION**  
 BUILDING: CHAPEL HILL  
 ZONING: CHAPEL HILL  
 UTILITY: DUKE ELECTRIC

**DESIGN SPECIFICATIONS**  
 OCCUPANCY: II  
 CONSTRUCTION: SINGLE-FAMILY  
 ZONING: RESIDENTIAL  
 GROUND SNOW LOAD: 15 PSF  
 WIND EXPOSURE: B  
 WIND SPEED: 117 MPH

**APPLICABLE CODES & STANDARDS**  
 BUILDING: NCSBC 2018 NCSRC 2018  
 ELECTRICAL: NEC 2017  
 FIRE: NCSFC 2018



**CONTRACTOR**

YES SOLAR SOLUTIONS

**PHONE:** (919) 459-2846  
**ADDRESS:** 202 NORTH DIXON AVENUE  
 CARY, NC 27513

**LIC. NO.:** 67356  
**HIC. NO.:**  
**ELE. NO.:** 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

## BUTLER RESIDENCE

111 DEES ST  
 LILLINGTON, NC 27546  
 APN: 1306400004

**ENGINEER OF RECORD**

PAPER SIZE: 11" x 17" (ANSI B)

**COVER PAGE**

**DATE:** 03.20.2021

**DESIGN BY:** P.A.

**CHECKED BY:** M.M.

REVISIONS

**T-001.00**

(SHEET 1)

	A	B	C	D	E	F	G	H
2.1.1	<b>SITE NOTES:</b>			2.4.9	THE GROUNDING ELECTRODE SYSTEM COMPLIES WITH NEC 690.47 AND NEC 250.50 THROUGH 250.106. IF EXISTING SYSTEM IS INACCESSIBLE, OR INADEQUATE, A	2.7.5	PV WIRE BLACK WIRE MAY BE FIELD-MARKED WHITE [NEC 200.6 (A)(6)].	
2.1.2	A LADDER WILL BE IN PLACE FOR INSPECTION IN COMPLIANCE WITH OSHA REGULATIONS.				GROUNDING ELECTRODE SYSTEM PROVIDED ACCORDING TO NEC 250, NEC 690.47 AND AHJ.	2.7.6	MODULE WIRING SHALL BE LOCATED AND SECURED UNDER THE ARRAY.	
2.1.3	THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE AND THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM WITH STORAGE BATTERIES.			2.4.10	DC PV ARRAYS SHALL BE PROVIDED WITH DC GROUND-FAULT PROTECTION MEETING THE REQUIREMENTS OF 690.41(B)(1) AND (2) TO REDUCE FIRE HAZARDS	2.7.7	ACCORDING TO NEC 200.7, UNGROUNDED SYSTEMS DC CONDUCTORS COLORED OR MARKED AS FOLLOWS: DC POSITIVE- RED, OR OTHER COLOR EXCLUDING WHITE, GREY AND GREEN DC NEGATIVE- BLACK, OR OTHER COLOR EXCLUDING WHITE, GREY AND GREEN	
2.1.4	THE SOLAR PV INSTALLATION WILL NOT OBSTRUCT ANY PLUMBING, MECHANICAL, OR BUILDING ROOF VENTS.						AC CONDUCTORS COLORED OR MARKED AS FOLLOWS: PHASE A OR L1- BLACK PHASE B OR L2- RED, OR OTHER CONVENTION IF THREE PHASE PHASE C OR L3- BLUE, YELLOW, ORANGE*, OR OTHER CONVENTION NEUTRAL- WHITE OR GREY	
2.1.5	PROPER ACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL BE PROVIDED AS PER SECTION NEC 110.26.			2.5.1	<b>INTERCONNECTION NOTES:</b>	2.7.8		
2.1.6	ROOF COVERINGS SHALL BE DESIGNED, INSTALLED, AND MAINTAINED IN ACCORDANCE WITH THIS CODE AND THE APPROVED MANUFACTURER'S INSTRUCTIONS SUCH THAT THE ROOF COVERING SERVES TO PROTECT THE BUILDING OR STRUCTURE.			2.5.2	LOAD-SIDE INTERCONNECTION SHALL BE IN ACCORDANCE WITH [NEC 705.12 (B)]			
2.2.1	<b>EQUIPMENT LOCATIONS</b>			2.5.3	THE SUM OF THE UTILITY OCPD AND INVERTER CONTINUOUS OUTPUT MAY NOT EXCEED 120% OF BUSBAR RATING [NEC 705.12(B)(2)(3)].			
2.2.2	ALL EQUIPMENT SHALL MEET MINIMUM SETBACKS AS REQUIRED BY NEC 110.26.			2.5.4	THE SUM OF 125 PERCENT OF THE POWER SOURCE(S) OUTPUT CIRCUIT CURRENT AND THE RATING OF THE OVERCURRENT DEVICE PROTECTING THE BUSBAR SHALL NOT EXCEED 120 PERCENT OF THE AMPACITY OF THE BUSBAR, PV DEDICATED BACKFEED BREAKERS MUST BE LOCATED OPPOSITE END OF THE BUS FROM THE UTILITY SOURCE OCPD [NEC 705.12(B)(2)(3)].			
2.2.3	WIRING SYSTEMS INSTALLED IN DIRECT SUNLIGHT MUST BE RATED FOR EXPECTED OPERATING TEMPERATURE AS SPECIFIED BY NEC 690.31 (A),(C) AND NEC TABLES 310.15 (B)(2)(A) AND 310.15 (B)(3)(C).			2.5.5	AT MULTIPLE ELECTRIC POWER SOURCES OUTPUT COMBINER PANEL, TOTAL RATING OF ALL OVERCURRENT DEVICES SHALL NOT EXCEED AMPACITY OF BUSBAR. HOWEVER, THE COMBINED OVERCURRENT DEVICE MAY BE EXCLUDED ACCORDING TO NEC 705.12 (B)(2)(3)(C).			
2.2.3	JUNCTION AND PULL BOXES PERMITTED INSTALLED UNDER PV MODULES ACCORDING TO NEC 690.34.			2.5.6	FEEDER TAP INTERCONNECTION (LOAD SIDE) ACCORDING TO NEC 705.12 (B)(2)(1)			
2.2.4	ADDITIONAL AC DISCONNECT(S) SHALL BE PROVIDED WHERE THE INVERTER IS NOT WITHIN SIGHT OF THE AC SERVICING DISCONNECT.			2.5.7	SUPPLY SIDE TAP INTERCONNECTION ACCORDING TO NEC 705.12 (A) WITH SERVICE ENTRANCE CONDUCTORS IN ACCORDANCE WITH NEC 230.42			
2.2.5	ALL EQUIPMENT SHALL BE INSTALLED ACCESSIBLE TO QUALIFIED PERSONNEL ACCORDING TO NEC APPLICABLE CODES.			2.5.8	BACKFEEDING BREAKER FOR ELECTRIC POWER SOURCES OUTPUT IS EXEMPT FROM ADDITIONAL FASTENING [NEC 705.12 (B)(5)].			
2.2.6	ALL COMPONENTS ARE LISTED FOR THEIR PURPOSE AND RATED FOR OUTDOOR USAGE WHEN APPROPRIATE.							
2.3.1	<b>STRUCTURAL NOTES:</b>			2.6.1	<b>DISCONNECTION AND OVER-CURRENT PROTECTION NOTES:</b>			
2.3.2	RACKING SYSTEM & PV ARRAY WILL BE INSTALLED ACCORDING TO CODE-COMPLIANT INSTALLATION MANUAL. TOP CLAMPS REQUIRE A DESIGNATED SPACE BETWEEN MODULES, AND RAILS MUST ALSO EXTEND A MINIMUM DISTANCE BEYOND EITHER EDGE OF THE ARRAY/SUBARRAY, ACCORDING TO RAIL MANUFACTURER'S INSTRUCTIONS.			2.6.2	DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHEN THE SWITCH IS OPENED THE CONDUCTORS REMAINING ENERGIZED ARE CONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS).			
2.3.3	JUNCTION BOX WILL BE INSTALLED PER MANUFACTURERS' SPECIFICATIONS. IF ROOF-PENETRATING TYPE, IT SHALL BE FLASHED & SEALED PER LOCAL REQUIREMENTS.			2.6.3	DISCONNECTS TO BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH.			
2.3.4	ROOFTOP PENETRATIONS FOR PV RACEWAY WILL BE COMPLETED AND SEALED W/ APPROVED CHEMICAL SEALANT PER CODE BY A LICENSED CONTRACTOR.			2.6.4	BOTH POSITIVE AND NEGATIVE PV CONDUCTORS ARE UNGROUNDED. THEREFORE BOTH MUST OPEN WHERE A DISCONNECT IS REQUIRED, ACCORDING TO NEC 690.13.			
2.3.5	ALL PV RELATED ROOF ATTACHMENTS TO BE SPACED NO GREATER THAN THE SPAN DISTANCE SPECIFIED BY THE RACKING MANUFACTURER.			2.6.5	ISOLATING DEVICES OR EQUIPMENT DISCONNECTING MEANS SHALL BE INSTALLED IN CIRCUITS CONNECTED TO EQUIPMENT AT A LOCATION WITHIN THE EQUIPMENT, OR WITHIN SIGHT AND WITHIN 10 FT OF THE EQUIPMENT. AN EQUIPMENT DISCONNECTING MEANS SHALL BE PERMITTED TO BE REMOTE FROM THE EQUIPMENT WHERE THE EQUIPMENT DISCONNECTING MEANS CAN BE REMOTELY OPERATED FROM WITHIN 10 FT OF THE EQUIPMENT, ACCORDING TO NEC 690.15 (A).			
2.3.6	WHEN POSSIBLE, ALL PV RELATED RACKING ATTACHMENTS WILL BE STAGGERED AMONGST THE ROOF FRAMING MEMBERS.			2.6.6	PV SYSTEM CIRCUITS INSTALLED ON OR IN BUILDINGS SHALL INCLUDE A RAPID SHUTDOWN FUNCTION TO REDUCE SHOCK HAZARD FOR EMERGENCY RESPONDERS IN ACCORDANCE WITH 690.12(A) THROUGH (D)			
2.4.1	<b>GROUNDING NOTES:</b>			2.6.7	ALL OCPD RATINGS AND TYPES SPECIFIED ACCORDING TO NEC 690.8, 690.9, AND 240.			
2.4.2	GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR PURPOSE, AND GROUNDING DEVICES EXPOSED TO THE ELEMENTS SHALL BE RATED FOR SUCH USE.			2.6.8	BOTH POSITIVE AND NEGATIVE PV CONDUCTORS ARE UNGROUNDED, THEREFORE BOTH REQUIRE OVER-CURRENT PROTECTION, ACCORDING TO NEC 240.21. (SEE EXCEPTION IN NEC 690.9)			
2.4.3	PV SYSTEMS REQUIRE AN EQUIPMENT GROUNDING CONDUCTOR. ALL METAL ELECTRICAL EQUIPMENT AND STRUCTURAL COMPONENTS BONDED TO GROUND, IN ACCORDANCE WITH 250.134 OR 250.136(A). ONLY THE DC CONDUCTORS ARE UNGROUNDED.			2.6.9	IF REQUIRED BY AHJ, SYSTEM WILL INCLUDE ARC-FAULT CIRCUIT PROTECTION ACCORDING TO NEC 690.11 AND UL1699B.			
2.4.4	PV EQUIPMENT SHALL BE GROUNDED ACCORDING TO NEC 690.43 AND MINIMUM NEC TABLE 250.122.			2.7.1	<b>WIRING &amp; CONDUIT NOTES:</b>			
2.4.5	METAL PARTS OF MODULE FRAMES, MODULE RACKING, AND ENCLOSURE CONSIDERED GROUNDED IN ACCORD WITH 250.134 AND 250.136(A).			2.7.2	ALL CONDUIT AND WIRE WILL BE LISTED AND APPROVED FOR THEIR PURPOSE. CONDUIT AND WIRE SPECIFICATIONS ARE BASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT UP-SIZING.			
2.4.6	EACH MODULE WILL BE GROUNDED USING WEEB GROUNDING CLIPS AS SHOWN IN MANUFACTURER DOCUMENTATION AND APPROVED BY THE AHJ. IF WEEBS ARE NOT USED, MODULE GROUNDING LUGS MUST BE INSTALLED AT THE SPECIFIED GROUNDING LUG HOLES PER THE MANUFACTURERS' INSTALLATION REQUIREMENTS.			2.7.3	ALL CONDUCTORS SIZED ACCORDING TO NEC 690.8, NEC 690.7.			
2.4.7	THE GROUNDING CONNECTION TO A MODULE SHALL BE ARRANGED SUCH THAT THE REMOVAL OF A MODULE DOES NOT INTERRUPT A GROUNDING CONDUCTOR TO ANOTHER MODULE.			2.7.4	EXPOSED PV SOURCE CIRCUITS AND OUTPUT CIRCUITS SHALL USE WIRE LISTED AND IDENTIFIED AS PHOTOVOLTAIC (PV) WIRE [690.31 (C)]. PV MODULES WIRE LEADS SHALL BE LISTED FOR USE ON PV ARRAYS, ACCORDING TO NEC 690.31 (A).			
2.4.8	GROUNDING AND BONDING CONDUCTORS, IF INSULATED, SHALL BE COLORED GREEN OR MARKED GREEN IF #4 AWG OR LARGER [NEC 250.119]							



**CONTRACTOR**

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846  
ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356  
HIC. NO.:  
ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

**BUTLER RESIDENCE**

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

**ENGINEER OF RECORD**


PAPER SIZE: 11" x 17" (ANSI B)

**NOTES**

DATE: 03.20.2021  
DESIGN BY: P.A.  
CHECKED BY: M.M.

REVISIONS

**G-001.00**  
(SHEET 2)



**GENERAL NOTES**

- 1. FIELD VERIFY ALL MEASUREMENTS
  - 2. ITEMS BELOW MAY NOT BE ON THIS PAGE
- PROPERTY LINE



**CONTRACTOR**

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846  
 ADDRESS: 202 NORTH DIXON AVENUE  
 CARY, NC 27513

LIC. NO.: 67356  
 HIC. NO.:  
 ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

**BUTLER RESIDENCE**

111 DEES ST  
 LILLINGTON, NC 27546  
 APN: 1306400004

**ENGINEER OF RECORD**

PAPER SIZE: 11" x 17" (ANSI B)

**SITE PLAN**

DATE: 03.20.2021

DESIGN BY: P.A.

CHECKED BY: M.M.


REVISIONS

**A-101.00**

(SHEET 3)

01 SITE PLAN  
 1/32" = 1'-0"





**CONTRACTOR**

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846  
ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356  
HIC. NO.:  
ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

**BUTLER RESIDENCE**

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

**ENGINEER OF RECORD**

PAPER SIZE: 11" x 17" (ANSI B)

**ELECTRICAL PLAN**

DATE: 03.20.2021


DESIGN BY: P.A.

CHECKED BY: M.M.

REVISIONS

**A-102.00**

(SHEET 4)



**GENERAL NOTES**

1. FIELD VERIFY ALL MEASUREMENTS
2. ITEMS BELOW MAY NOT BE ON THIS PAGE

--- METAL RIBS



SOLAR (PV) MODULE  
ATTACHMENTS  
RAILS





SOLAR (PV) MODULE  
ATTACHMENTS  
RAILS

ROOF MATERIAL IS CORRUGATED METAL

FLUSH MOUNT SOLAR MODULES ATTACHED TO ROOF SURFACE (SEE SHEET S-501 FOR MOUNTING DETAILS)

**01 SOLAR ATTACHMENT PLAN**  
1/8" = 1'



MODULE:  
REC  
REC330TP3M BLACK  
330 WATTS



**CONTRACTOR**

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846  
ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356  
HIC. NO.:  
ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

**BUTLER RESIDENCE**

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

**ENGINEER OF RECORD**

PAPER SIZE: 11" x 17" (ANSI B)

**SOLAR ATTACHMENT PLAN**

DATE: 03.20.2021


DESIGN BY: P.A.

CHECKED BY: M.M.

REVISIONS

**A-103.00**

(SHEET 5)



**CONTRACTOR**

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846  
ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356  
HIC. NO.:  
ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

**BUTLER RESIDENCE**

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

**ENGINEER OF RECORD**

PAPER SIZE: 11" x 17" (ANSI B)

**LINE DIAGRAM**

DATE: 03.20.2021

DESIGN BY: P.A.

CHECKED BY: M.M.

REVISIONS

**E-601.00**

(SHEET 6)



**CONTRACTOR**

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846  
 ADDRESS: 202 NORTH DIXON AVENUE  
 CARY, NC 27513

LIC. NO.: 67356  
 HIC. NO.:  
 ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

**BUTLER RESIDENCE**

111 DEES ST  
 LILLINGTON, NC 27546  
 APN: 1306400004

**ENGINEER OF RECORD**

PAPER SIZE: 11" x 17" (ANSI B)

**DESIGN TABLES**

DATE: 03.20.2021  
 DESIGN BY: P.A.  
 CHECKED BY: M.M.

REVISIONS

**E-602.00**  
 (SHEET 7)

**SYSTEM SUMMARY**

	INVERTER #1		INVERTER #2	
	STRING #1	STRING #2	STRING #1	STRING #2
POWERBOX MAX OUTPUT CURRENT	15A	15A	15A	15A
OPTIMIZERS IN SERIES	14	14	10	10
NOMINAL STRING VOLTAGE	400V	400V	380V	380V
ARRAY OPERATING CURRENT	11.55A	11.55A	8.68A	8.68A
ARRAY STC POWER	9,240W		6,600W	
ARRAY PTC POWER	8,646W		6,176W	
MAX AC CURRENT	32A		25A	
MAX AC POWER	7,600W		6,000W	
DERATED (CEC) AC POWER	7,600W		6,000W	
TOTAL STC POWER	15,840W			
TOTAL PTC POWER	14,822W			
MAX AC CURRENT	57A			
MAX AC POWER	13,600W			
DERATED (CEC) AC POWER	13,600W			

**MODULES**

REF.	QTY.	MAKE AND MODEL	PMAX	PTC	ISC	IMP	VOC	VMP	TEMP. COEFF. OF VOC	FUSE RATING
PM1-48	48	REC REC330TP3M BLACK	330W	308.8W	10.39A	9.62A	39.9V	33.6V	-0.112V/°C (-0.28%/°C)	20A

**POWER OPTIMIZERS**

REF.	QTY.	MODEL	RATED INPUT POWER	MAX OUTPUT CURRENT	MAX INPUT ISC	MAX DC VOLTAGE	WEIGHTED EFFICIENCY
PO1-48	48	SOLAR EDGE P340	340W	15A	11A	48V	98.8%

**INVERTERS**

REF.	QTY.	MAKE AND MODEL	AC VOLTAGE	GROUND	OCPP RATING	RATED POWER	MAX OUTPUT CURRENT	MAX INPUT CURRENT	MAX INPUT VOLTAGE	CEC WEIGHTED EFFICIENCY
I1	1	SOLAR EDGE SE7600H-US (240V)	240V	FLOATING	40A	7600W	32A	20A	480V	99.0%
I2	1	SOLAR EDGE SE6000H-US (240V)	240V	FLOATING	35A	6000W	25A	16.5A	480V	99.0%

**DISCONNECTS**

REF.	QTY.	MAKE AND MODEL	RATED CURRENT	MAX RATED VOLTAGE
SW1	1	EATON DG224NRK OR EQUIV.	200A	240VAC

**OCPPDS**

REF.	QTY.	RATED CURRENT	MAX VOLTAGE
CB1-2	2	40A	240VAC
F1-2	2	80A	240VAC

ASHRAE EXTREME LOW	-11.1°C (12.0°F), SOURCE: HARTNETT COUNTY (35.38°; -78.73°)
ASHRAE 2% HIGH	37.1°C (98.8°F), SOURCE: HARTNETT COUNTY (35.38°; -78.73°)

**CONDUCTOR AND CONDUIT SCHEDULE W/ELECTRICAL CALCULATIONS**

ID	TYPICAL	CONDUCTOR	CONDUIT	CURRENT-CARRYING CONDUCTORS IN CONDUIT	OCPPD	EGC	TEMP. CORR. FACTOR	CONDUIT FILL FACTOR	CONT. CURRENT	MAX. CURRENT (125%)	BASE AMP.	DERATED AMP.	TERM. TEMP. RATING	AMP. @ TERMINAL
1	4	10 AWG PV WIRE, COPPER	FREE AIR	2	N/A	6 AWG BARE, COPPER	0.91 (37.1 °C)	1	15A	18.75A	55A	50.05A	75°C	50A
2	2	10 AWG THWN-2, COPPER	0.75" DIA EMT	4	N/A	10 AWG THWN-2, COPPER	0.91 (37.1 °C)	0.8	15A	18.75A	40A	29.12A	75°C	35A
3	2	8 AWG THWN-2, COPPER	0.75" DIA EMT	2	40A	10 AWG THWN-2, COPPER	0.91 (37.1 °C)	1	32A	40A	55A	50.05A	75°C	50A
4	2	4 AWG THWN-2, COPPER	1" DIA EMT	2	80A	8 AWG THWN-2, COPPER	0.91 (37.1 °C)	1	57A	71.25A	125A	154.7A	75°C	125A
5	1	3/O AWG THWN-2, COPPER	2" DIA EMT	2	N/A	3/O AWG THWN-2, COPPER	0.91 (37.1 °C)	1	57A	71.25A	225A	204.75A	75°C	200A



**LABELING NOTES**  
 1.1 LABELING REQUIREMENTS BASED ON THE 2017 NATIONAL ELECTRICAL CODE, INTERNATIONAL FIRE CODE 605.11, OSHA STANDARD 1910.145, ANSI Z535  
 1.2 MATERIAL BASED ON THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.  
 1.3 LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED.  
 1.4 LABELS TO BE A MINIMUM LETTER HEIGHT OF 3/8" AND PERMANENTLY AFFIXED.  
 1.5 ALERTING WORDS TO BE COLOR CODED. "DANGER" WILL HAVE RED BACKGROUND; "WARNING" WILL HAVE ORANGE BACKGROUND; "CAUTION" WILL HAVE YELLOW BACKGROUND. [ANSI Z535]  
 1.6 ALL SIGNAGE MUST BE PERMANENTLY ATTACHED AND BE WEATHER RESISTANT/SUNLIGHT RESISTANT AND CANNOT BE HAND-WRITTEN PER NEC 110.21(B)


**WARNING**  
 ELECTRICAL SHOCK HAZARD  
 TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

**LABEL 1**  
 AT EACH DISCONNECTING MEANS FOR PHOTOVOLTAIC EQUIPMENT (2" X 4"). [NEC 690.13].

**WARNING**  
 POWER SOURCE OUTPUT CONNECTION DO NOT RELOCATE THIS OVERCURRENT DEVICE

**LABEL 2**  
 AT POINT OF INTERCONNECTION OVERCURRENT DEVICE (2" X 4"). [NEC 705.12(B)(2)(3)(B)].

**SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN**



TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN ARRAY

**LABEL 3**  
 AT RAPID SHUTDOWN SYSTEM (3 3/4" X 5 1/4"). [NEC 690.56(C)(1)(A)].

**WARNING: PHOTOVOLTAIC POWER SOURCE**

**LABEL 4**  
 AT EXPOSED RACEWAYS, CABLE TRAYS, AND OTHER WIRING METHODS; SPACED AT MAXIMUM 10 FT SECTION OR WHERE SEPARATED BY ENCLOSURES, WALLS, PARTITIONS, CEILINGS, OR FLOORS (5 3/4" X 1 1/8"). [NEC 690.31(G)]  
 LETTERS AT LEAST 3/8 INCH; WHITE ON RED BACKGROUND; REFLECTIVE [IFC 605.11.1.1]

**RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM**

**LABEL 5**  
 AT RAPID SHUTDOWN DISCONNECT SWITCH (5 1/4" X 2"). [NEC 690.56(C)(3)].

**CAUTION**  
 SOLAR ELECTRIC SYSTEM CONNECTED

**LABEL 6**  
 AT UTILITY METER (5 3/4" X 1 1/8") [NEC 690.56(B)]

**WARNING**  
 TRIPLE POWER SUPPLY SOURCES: UTILITY GRID, BATTERY AND PV SOLAR ELECTRIC SYSTEM

**LABEL 7**  
 AT POINT OF INTERCONNECTION (2 3/4" X 1 5/8"). [NEC 705.12(B)(3)]

**WARNING**  
 SOLAR ELECTRIC CIRCUIT BREAKER IS BACKFED

**LABEL 8**  
 AT POINT OF INTERCONNECTION (2" X 1"). [NEC 705.12(B)(3)]

INTERACTIVE PHOTOVOLTAIC SYSTEM CONNECTED PHOTOVOLTAIC SYSTEM DISCONNECT LOCATED NW SIDE OF THE HOUSE

**DIRECTORY**  
 PERMANENT PLAQUE OR DIRECTORY PROVIDING THE LOCATION OF THE SERVICE DISCONNECTING MEANS AND THE PHOTOVOLTAIC SYSTEM DISCONNECTING MEANS IF NOT IN THE SAME LOCATION (5 3/4" X 1 1/8"). [NEC 690.56(B)]  
 WHERE THE PV SYSTEMS ARE REMOTELY LOCATED FROM EACH OTHER, A DIRECTORY IN ACCORDANCE WITH 705.10 SHALL BE PROVIDED AT EACH PV SYSTEM DISCONNECTING MEANS. PV SYSTEM EQUIPMENT AND DISCONNECTING MEANS SHALL NOT BE INSTALLED IN BATHROOMS [NEC 690.4(D),(E)]

PHOTOVOLTAIC SOLAR AC DISCONNECT

**LABEL 9**  
 AT EACH AC DISCONNECTING MEANS (4" X 1"). [NEC 690.13(B)].

PHOTOVOLTAIC SOLAR DC DISCONNECT

**LABEL 10**  
 AT EACH DC DISCONNECTING MEANS (4" X 1"). [NEC 690.13(B)].

**PHOTOVOLTAIC SYSTEM AC DISCONNECT**

RATED AC OUTPUT CURRENT  A  
 NOMINAL OPERATING AC VOLTAGE  V

**LABEL 11**  
 AT POINT OF INTERCONNECTION, MARKED AT DISCONNECTING MEANS (4" X 2"). [NEC 690.54]

**DIRECT CURRENT PHOTOVOLTAIC POWER SOURCE**

MAXIMUM VOLTAGE:  V DC  
 MAXIMUM CIRCUIT CURRENT:  A DC

MAX RATED OUTPUT CURRENT OF THE CHARGE CONTROLLER OR DC-TO-DC CONVERTER  A DC


**LABEL 12**  
 AT EACH DC DISCONNECTING MEANS (3" X 4"). [NEC 690.53].

**DIRECT CURRENT PHOTOVOLTAIC POWER SOURCE**

MAXIMUM VOLTAGE:  V DC  
 MAXIMUM CIRCUIT CURRENT:  A DC

MAX RATED OUTPUT CURRENT OF THE CHARGE CONTROLLER OR DC-TO-DC CONVERTER  A DC

**LABEL 13**  
 AT EACH DC DISCONNECTING MEANS (3" X 4"). [NEC 690.53].



**CONTRACTOR**  
 YES SOLAR SOLUTIONS  
 PHONE: (919) 459-2846  
 ADDRESS: 202 NORTH DIXON AVENUE CARY, NC 27513  
 LIC. NO.: 67356  
 HIC. NO.:  
 ELE. NO.: 31227-U  
 UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp  
**BUTLER RESIDENCE**  
 111 DEES ST  
 LILLINGTON, NC 27546  
 APN: 1306400004

**ENGINEER OF RECORD**


PAPER SIZE: 11" x 17" (ANSI B)

PLACARDS


DATE: 03.20.2021  
 DESIGN BY: P.A.  
 CHECKED BY: M.M.  
 REVISIONS

**E-603.00**  
 (SHEET 8)


A B C D E F G H




**D1** RACKING DETAIL (TRANSVERSE)  
NOT TO SCALE




**D2** RACKING DETAIL (LONGITUDINAL)  
NOT TO SCALE



**D3** RACKING DETAIL (TOP)  
NOT TO SCALE



**D4** DETAIL (TRANSVERSE)  
NOT TO SCALE



**D5** DETAIL (LONGITUDINAL)  
NOT TO SCALE

**GENERAL NOTES**

1. FIELD VERIFY ALL MEASUREMENTS

**SHEET KEYNOTES**

1. ROOF MATERIAL: CORRUGATED METAL
2. ROOF STRUCTURE: SINGLE SPAN RAFTER
3. ATTACHMENT TYPE: S15 PROTEA BRACKET
4. MODULE MANUFACTURER: REC
5. MODULE MODEL: REC330TP3M BLACK
6. MODULE LENGTH: 66.3"
7. MODULE WIDTH: 39.25"
8. MODULE WEIGHT: 41.7 LBS.
9. SEE SHEET A-103 FOR DIMENSION(S)
10. MIN. FIRE OFFSET: NO FIRE CODE ENFORCED
11. TRUSS SPACING: 16 IN. O.C.
12. TRUSS SIZE: 2X6 IN. NOMINAL
13. LAG BOLT DIAMETER: 5/16 IN.
14. LAG BOLT EMBEDMENT: 2-1/2 IN.
15. TOTAL # OF ATTACHMENTS: 100
16. TOTAL AREA: 867.43 SQ. FT.
17. TOTAL WEIGHT: 2212.04 LBS.
18. WEIGHT PER ATTACHMENT: 22.12 LBS.
19. DISTRIBUTED LOAD: 2.56 PSF
20. MAX. HORIZONTAL STANDOFF: 48 IN.
21. MAX. VERTICAL STANDOFF: LANDSCAPE: 26 IN., PORTRAIT: 33 IN.
22. STANDOFF STAGGERING: YES
23. RAIL MANUFACTURER (OR EQUIV.): SNAP N RACK
24. RAIL MODEL (OR EQUIVALENT): UR-40 RAIL
25. RAIL WEIGHT: 0.42 PLF.
26. MAX. TRUSS SPAN: N/A
27. MODULE CLEARANCE: 3 IN. MIN., 6 IN. MAX.

**Ron Bittler**  
PE

Digitally signed by  
Ron Bittler, PE  
DN: cn=Ron Bittler, PE,  
ou=RB Engineering,  
Inc., ou,  
email=rbittler@rbeng  
neering.com, c=US  
Date: 2021.03.23  
08:41:08 -04'00'



**CONTRACTOR**

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846  
ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356  
HIC. NO.:  
ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS  
DRAWING SET WITHOUT WRITTEN  
PERMISSION FROM CONTRACTOR IS IN  
VIOLATION OF U.S. COPYRIGHT LAWS  
AND WILL BE SUBJECT TO CIVIL  
DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

**BUTLER  
RESIDENCE**

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

**ENGINEER OF RECORD**



03.20.2021

PAPER SIZE: 11" x 17" (ANSI B)

**ASSEMBLY DETAILS**

DATE: 03.20.2021

DESIGN BY: P.A.

CHECKED BY: M.M.

REVISIONS

STRUCTURAL REVIEW PROVIDED BY:  
RONALD P. BITTLER, PE  
RB ENGINEERING, INC. (C-2499)  
168 QUADE DRIVE  
CARY, NC 27513  
919-677-9662  
PROJECT #RB-216884

**S-501.00**

(SHEET 9)

A B C D E F G H

SOLAR'S MOST TRUSTED 

# REC TWINPEAK 3 MONO BLACK SERIES

**PREMIUM SOLAR PANELS WITH SUPERIOR PERFORMANCE**

REC TwinPeak 3 Mono Black Series solar panels feature an innovative design with high panel efficiency and power output, enabling customers to get the most out of the space used for the installation.

Combined with industry-leading product quality and the reliability of a strong and established European brand, REC TwinPeak 3 Mono Black panels are ideal for residential and commercial rooftops worldwide.



**MORE POWER OUTPUT PER M<sup>2</sup>**



**IMPROVED PERFORMANCE IN SHADED CONDITIONS**



**100% PID FREE**




**REDUCES BALANCE OF SYSTEM COSTS**



**ELIGIBLE FOR**

## REC TWINPEAK 3 MONO BLACK SERIES



Measurements in mm [in]

ELECTRICAL DATA @ STC		Product code*: RECxxxTP3M Black				
Power Output - P <sub>max</sub> (Wp)	315	320	325	330	335	
Watt Class Sorting - (W)	-0/+5	-0/+5	-0/+5	-0/+5	-0/+5	
Nominal Power Voltage - V <sub>mp</sub> (V)	33.6	33.8	34.1	34.3	34.6	
Nominal Power Current - I <sub>mp</sub> (A)	9.40	9.50	9.54	9.62	9.69	
Open Circuit Voltage - V <sub>oc</sub> (V)	38.7	39.1	39.5	39.9	40.2	
Short Circuit Current - I <sub>sc</sub> (A)	10.30	10.30	10.36	10.39	10.42	
Panel Efficiency (%)	18.8	19.1	19.4	19.7	20.0	

Values at standard test conditions (STC: air mass AM1.5, irradiance 1000 W/m<sup>2</sup>, temperature 25°C), based on a production spread with a tolerance of P<sub>max</sub>, V<sub>oc</sub> & I<sub>sc</sub> ±3% within one watt class. At a low irradiance of 200 W/m<sup>2</sup> at least 95% of the STC module efficiency will be achieved.  
\*Where xxx indicates the nominal power class (P<sub>max</sub>) at STC indicated above.

ELECTRICAL DATA @ NMOT		Product code*: RECxxxTP3M Black				
Power Output - P <sub>max</sub> (Wp)	235	238	242	246	250	
Nominal Power Voltage - V <sub>mp</sub> (V)	31.3	31.5	31.7	31.9	32.2	
Nominal Power Current - I <sub>mp</sub> (A)	7.51	7.57	7.63	7.70	7.75	
Open Circuit Voltage - V <sub>oc</sub> (V)	36.1	36.4	36.8	37.1	37.5	
Short Circuit Current - I <sub>sc</sub> (A)	8.23	8.26	8.29	8.31	8.34	

Nominal module operating temperature (NMOT: air mass AM1.5, irradiance 800 W/m<sup>2</sup>, temperature 20°C, windspeed 1 m/s).  
\*Where xxx indicates the nominal power class (P<sub>max</sub>) at STC indicated above.

### CERTIFICATIONS



### WARRANTY

	Standard	REC ProTrust
Installed by an REC Certified Solar Professional	No	Yes Yes
System Size	Any	<25 kW 25-500 kW
Product Warranty (yrs)	20	25 25
Power Warranty (yrs)	25	25 25
Labor Warranty (yrs)	3	25 10
Power in Year 1	97.5%	97.5% 97.5%
Annual Degradation	0.7%	0.7% 0.7%
Power in Year 25	80.7%	80.7% 80.7%

See warranty documents for details. Some conditions apply.

**20.0% EFFICIENCY**

**20 YEAR PRODUCT WARRANTY**

**25 YEAR LINEAR POWER OUTPUT WARRANTY**

TEMPERATURE RATINGS	
Nominal Module Operating Temperature	44.6°C (±2°C)
Temperature coefficient of P <sub>max</sub>	-0.37 %/°C
Temperature coefficient of V <sub>oc</sub>	-0.28 %/°C
Temperature coefficient of I <sub>sc</sub>	0.04 %/°C

### GENERAL DATA

**Cells:** 120 half-cut mono-Si p-type PERC cells  
6 strings of 20 cells in series

**Glass:** 0.13" (3.2 mm) solar glass with anti-reflective surface treatment

**Back sheet:** Highly resistant polyester polyolefin construction (black)

**Frame:** Anodized aluminum (black)

**Junction box:** 3-part with 3 bypass diodes, IP67 rated  
12 AWG (4 mm<sup>2</sup>) PV wire: 35" x 47" (1.0 m x 1.2 m)

**Connectors:** Staubi MC4 PV-KBT4/PV-KST4  
12 AWG (4 mm<sup>2</sup>)

### MAXIMUM RATINGS

Operational temperature:	-40 ... +185°F (-40 ... +85°C)
Maximum system voltage:	1000 V
Design load (+) snow:	3600 Pa (75.2 lbs/ft <sup>2</sup> )
Maximum test load (+):	5400 Pa (112.8 lbs/ft <sup>2</sup> )
Design load (-) wind:	1600 Pa (33.4 lbs/ft <sup>2</sup> )
Maximum test load (-):	2400 Pa (50 lbs/ft <sup>2</sup> )
Max series fuse rating:	20 A
Max reverse current:	20 A

\* Calculated using a safety factor of 1.5  
See installation manual for mounting instructions

### MECHANICAL DATA

Dimensions:	66.3 x 39.25 x 1.5 (1683 x 997 x 38 mm)
Area:	17.98 ft <sup>2</sup> (1.68 m <sup>2</sup> )
Weight:	41.7 lbs (18.9 kg)

**Note!** Specifications subject to change without notice.



### CONTRACTOR

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846  
ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356  
HIC. NO.:  
ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

## BUTLER RESIDENCE

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

### ENGINEER OF RECORD

PAPER SIZE: 11" x 17" (ANSI B)

### RESOURCE DOCUMENT

DATE: 03.20.2021

DESIGN BY: P.A.

CHECKED BY: M.M.

REVISIONS

**R-001.00**

(SHEET 10)

REC Group is an international pioneering solar energy company dedicated to empowering consumers with clean, affordable solar power in order to facilitate global energy transitions. Committed to quality and innovation, REC offers photovoltaic modules with leading high quality, backed by an exceptional low warranty claims rate of less than 10/10pm. Founded in Norway in 1996, REC employs 2,000 people and has an annual solar panel capacity of 1.8 GW. With over 10 GW installed worldwide, REC is empowering more than 16 million people with clean solar energy. REC Group is a Bluestar Elexem company with headquarters in Norway, operational headquarters in Singapore, and regional bases in North America, Europe, and Asia-Pacific.



www.recgroup.com

# Single Phase Inverter with HD-Wave Technology

for North America

SE3000H-US / SE3800H-US / SE5000H-US / **SE6000H-US** / **SE7600H-US** / SE10000H-US / SE11400H-US

INVERTERS

12-25  
YEAR  
WARRANTY



## Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Extremely small
- Record-breaking efficiency
- Built-in module-level monitoring
- Fixed voltage inverter for longer strings
- Outdoor and indoor installation
- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12
- Optional: Revenue grade data, ANSI C12.20 Class 0.5 (0.5% accuracy)
- UL1741 SA certified, for CPUC Rule 21 grid compliance

solaredge.com



## Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / **SE6000H-US** / **SE7600H-US** / SE10000H-US / SE11400H-US

	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US		
<b>OUTPUT</b>									
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA	
Maximum AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA	
AC Output Voltage Min.-Norm.-Max. (211 - 240 - 264)	✓	✓	✓	✓	✓	✓	✓	Vac	
AC Output Voltage Min.-Norm.-Max. (183 - 208 - 229)	-	✓	-	✓	-	-	✓	Vdc	
AC Frequency (Nominal)				59.3 - 60 - 60.5 <sup>1)</sup>				Hz	
Maximum Continuous Output Current @240V	12.5	16	21	25	32	42	47.5	A	
Maximum Continuous Output Current @208V	-	16	-	24	-	-	48.5	A	
GFDI Threshold				1				A	
Utility Monitoring, Islanding Protection, Country Configurable Thresholds				Yes					
<b>INPUT</b>									
Maximum DC Power @240V	4650	5900	7750	9300	11800	15500	17650	W	
Maximum DC Power @208V	-	5100	-	7750	-	-	15500	W	
Transformer-less, Ungrounded				Yes					
Maximum Input Voltage				480				Vdc	
Nominal DC Input Voltage	380					400		Vdc	
Maximum Input Current @240V <sup>2)</sup>	8.5	10.5	13.5	16.5	20	27	30.5	Adc	
Maximum Input Current @208V <sup>2)</sup>	-	9	-	13.5	-	-	27	Adc	
Max. Input Short Circuit Current				45				Adc	
Reverse-Polarity Protection				Yes					
Ground-Fault Isolation Detection				600ka Sensitivity					
Maximum Inverter Efficiency	99			99.2				%	
CEC Weighted Efficiency				99		99 @ 240V 98.5 @ 208V		%	
Nighttime Power Consumption				< 2.5				W	
<b>ADDITIONAL FEATURES</b>									
Supported Communication Interfaces				RS485, Ethernet, ZigBee (optional), Cellular (optional)					
Revenue Grade Data, ANSI C12.20				Optional <sup>3)</sup>					
Rapid Shutdown - NEC 2014 and 2017 690.12				Automatic Rapid Shutdown upon AC Grid Disconnect					
<b>STANDARD COMPLIANCE</b>									
Safety				UL1741, UL1741 SA, UL1699B, CSA C22.2, Canadian AFCI according to T.I.L. M-07					
Grid Connection Standards				IEEE1547, Rule 21, Rule 14 (H)					
Emissions				FCC Part 15 Class B					
<b>INSTALLATION SPECIFICATIONS</b>									
AC Output Conduit Size / AWG Range				3/4" minimum / 14-6 AWG		3/4" minimum / 14-4 AWG			
DC Input Conduit Size / # of Strings / AWG Range				3/4" minimum / 1-2 strings / 14-6 AWG		3/4" minimum / 1-3 strings / 14-6 AWG			
Dimensions with Safety Switch (HxWxD)				17.7 x 14.6 x 6.8 / 450 x 370 x 174		21.3 x 14.6 x 7.3 / 540 x 370 x 185		in / mm	
Weight with Safety Switch	22 / 10		25.1 / 11.4		26.2 / 11.9		38.8 / 17.6		lb / kg
Noise				< 25		< 50		dBA	
Cooling				Natural Convection					
Operating Temperature Range				-40 to +140 / -25 to +60 <sup>4)</sup> (-40F / -40C option) <sup>5)</sup>				°F / °C	
Protection Rating				NEMA 4X (Inverter with Safety Switch)					

<sup>1)</sup> For other regional settings please contact SolarEdge support  
<sup>2)</sup> A higher current source may be used; the inverter will limit its input current to the values stated  
<sup>3)</sup> Revenue grade inverter P/N: SExxxxH-US000NCC2  
<sup>4)</sup> For power derating information refer to <https://www.solaredge.com/sites/default/files/temperature-derating-note-na.pdf>  
<sup>5)</sup> -40 version P/N: SExxxxH-US000NNU4

© SolarEdge Technologies, Inc. All rights reserved. SOLAREGE, the SolarEdge logo, OPTIMIZED BY SOLAREGE are trademarks or registered trademarks of SolarEdge Technologies, Inc. All other trademarks mentioned herein are trademarks of their respective owners. Date: 12/2018/V01/ENG-NAM. Subject to change without notice.

RoHS



### CONTRACTOR

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846

ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356

HIC. NO.:

ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

## BUTLER RESIDENCE

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

### ENGINEER OF RECORD

PAPER SIZE: 11" x 17" (ANSI B)

### RESOURCE DOCUMENT

DATE: 03.20.2021

DESIGN BY: P.A.

CHECKED BY: M.M.

REVISIONS

R-002.00


(SHEET 11)

# Power Optimizer

For North America

P320 / **P340** / P370 / P400 / P405 / P505

POWER OPTIMIZER



## PV power optimization at the module-level

- Specifically designed to work with SolarEdge inverters
- Up to 25% more energy
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch losses, from manufacturing tolerance to partial shading
- Flexible system design for maximum space utilization
- Fast installation with a single bolt
- Next generation maintenance with module-level monitoring
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System (PVRSS)
- Module-level voltage shutdown for installer and firefighter safety

solaredge.com



## / Power Optimizer

For North America

P320 / **P340** / P370 / P400 / P405 / P505

Optimizer model (typical module compatibility)	P320 (for 60-cell modules)	P340 (for high-power 60-cell modules)	P370 (for higher-power 60 and 72-cell modules)	P400 (for 72 & 96-cell modules)	P405 (for thin film modules)	P505 (for higher current modules)	
<b>INPUT</b>							
Rated Input DC Power <sup>(1)</sup>	320	340	370	400	405	505	W
Absolute Maximum Input Voltage (Voc at lowest temperature)	48	60	80	125 <sup>(2)</sup>	83 <sup>(3)</sup>		Vdc
MPPT Operating Range	8 - 48	8 - 60	8 - 80	12.5 - 105	12.5 - 83		Vdc
Maximum Short Circuit Current (IsC)	11		10.1	14			Adc
Maximum DC Input Current	13.75		99.5	17.5			Adc
Maximum Efficiency			99.5				%
Weighted Efficiency			98.8			98.6	%
Overvoltage Category	II						
<b>OUTPUT DURING OPERATION (POWER OPTIMIZER CONNECTED TO OPERATING SOLAREEDGE INVERTER)</b>							
Maximum Output Current		15					Adc
Maximum Output Voltage		60		85			Vdc
<b>OUTPUT DURING STANDBY (POWER OPTIMIZER DISCONNECTED FROM SOLAREEDGE INVERTER OR SOLAREEDGE INVERTER OFF)</b>							
Safety Output Voltage per Power Optimizer		1 ± 0.1					Vdc
<b>STANDARD COMPLIANCE</b>							
EMC	FCC Part15 Class B, IEC61000-6-2, IEC61000-6-3						
Safety	IEC62109-1 (class II safety), UL1741						
RoHS	Yes						
<b>INSTALLATION SPECIFICATIONS</b>							
Maximum Allowed System Voltage	1000						
Compatible inverters	All SolarEdge Single Phase and Three Phase inverters						
Dimensions (W x L x H)	128 x 152 x 28 / 5 x 5.97 x 1.1	128 x 152 x 36 / 5 x 5.97 x 1.42	128 x 152 x 50 / 5 x 5.97 x 1.96	128 x 152 x 59 / 5 x 5.97 x 2.32	mm / in		
Weight (including cables)	630 / 1.4	750 / 1.7	845 / 1.9	1064 / 2.3	gr / lb		
Input Connector	MC4 <sup>(4)</sup>						
Output Wire Type / Connector	Double Insulated; MC4						
Output Wire Length	0.95 / 3.0		1.2 / 3.9	m / ft			
Input Wire Length			0.16 / 0.52	m / ft			
Operating Temperature Range	-40 - +85 / -40 - +185						
Protection Rating	IP68 / NEMA6P						
Relative Humidity	0 - 100						

<sup>(1)</sup> Rated STC power of the module. Module of up to +5% power tolerance allowed  
<sup>(2)</sup> NEC 2017 requires max input voltage be not more than 80V  
<sup>(3)</sup> For other connector types please contact SolarEdge

PV System Design Using a SolarEdge Inverter <sup>(4)(5)</sup>	Single Phase HD-Wave	Single phase	Three Phase 208V	Three Phase 480V	
Minimum String Length (Power Optimizers)	P320, P340, P370, P400 P405 / P505	8	10	18	
Maximum String Length (Power Optimizers)		6	8	14	
Maximum Power per String	5700 (6000 with SE7600-US - SE11400-US)	5250	6000 <sup>(6)</sup>	12750 <sup>(6)</sup>	W
Parallel Strings of Different Lengths or Orientations	Yes				

<sup>(4)</sup> For detailed string sizing information refer to: [http://www.solaredge.com/sites/default/files/string\\_sizing\\_na.pdf](http://www.solaredge.com/sites/default/files/string_sizing_na.pdf)  
<sup>(5)</sup> It is not allowed to mix P405/P505 with P320/P340/P370/P400 in one string  
<sup>(6)</sup> A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement  
<sup>(7)</sup> For SE14.4KUS/SE43.2KUS: It is allowed to install up to 6,500W per string when 3 strings are connected to the inverter (3 strings per unit for SE43.2KUS) and when the maximum power difference between the strings is up to 1,000W  
<sup>(8)</sup> For SE30KUS/SE33.3KUS/SE66.6KUS/SE100KUS: It is allowed to install up to 15,000W per string when 3 strings are connected to the inverter (3 strings per unit for SE66.6KUS/SE100KUS) and when the maximum power difference between the strings is up to 2,000W



### CONTRACTOR

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846

ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356

HIC. NO.:

ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

## BUTLER RESIDENCE

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

### ENGINEER OF RECORD

PAPER SIZE: 11" x 17" (ANSI B)

### RESOURCE DOCUMENT

DATE: 03.20.2021

DESIGN BY: P.A.

CHECKED BY: M.M.

REVISIONS

R-003.00

(SHEET 12)

DESCRIPTION:  
SNAPRACK, UR-40 RAIL



PART NUMBER(S):  
232-02449, 232-02450, 232-02451

DRAWN BY:  
mwatkins

REVISION:  
**A**



595 MARKET STREET, 29TH FLOOR • SAN FRANCISCO, CA 94105 USA  
PHONE: (415) 560-6900 • FAX: (415) 560-6902  
THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF SUNRUN SOUTH LLC.



UR-40 RAIL PROPERTIES	
SKU	FINISH
232-02449	MILL
232-02450	CLEAR
232-02451	BLACK

ALL DIMENSIONS IN INCHES

MATERIALS:	6000 SERIES ALUMINUM	OPTIONS:
DESIGN LOAD (LBS):	N/A	CLEAR / BLACK ANODIZED
ULTIMATE LOAD (LBS):	N/A	MILL FINISH
TORQUE SPECIFICATION:	N/A LB-FT	BUNDLES OF 144
CERTIFICATION:	UL 2703, FILE E359313	
WEIGHT (LBS):	5.85	



**CONTRACTOR**

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846  
ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356  
HIC. NO.:  
ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

**BUTLER RESIDENCE**

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

**ENGINEER OF RECORD**

PAPER SIZE: 11" x 17" (ANSI B)

**RESOURCE DOCUMENT**

DATE: 03.20.2021

DESIGN BY: P.A.

CHECKED BY: M.M.

REVISIONS

**R-006.00**

SHEET 15

The right way to attach almost anything to metal roofs!

# S-5!®

## The Right Way!

### ProteaBracket™

ProteaBracket™ is the most versatile standing seam metal roof attachment solution on the market, fitting most trapezoidal sheet profiles with and without intermediate insulation. It features an adjustable attachment base and multiple solar module attachment options (illustrated on back) to accommodate varying widths and heights. There are no messy sealants to apply and no chance for leaks; the ProteaBracket comes with factory-applied, adhesive rubber sealant to ensure quick installation and a weather-proof fit.


Installation is simple! The ProteaBracket is mounted directly onto the crown of the panel, straddling the profile. No surface preparation is necessary; simply wipe away excess oil and debris, align, and apply. Secure ProteaBracket through its pre-punched holes, using the hardened drill point S-5!® screws.

ProteaBracket is the perfect match for our S-5-PV Kit and spares you the hassle of cold-bridging! For a solar attachment solution that is both economical and easy to use, choose ProteaBracket.\*

\*When ProteaBracket is used in conjunction with the S-5-PV Kit, an additional nut is required during installation.



S-5!® ProteaBracket™ is a versatile bracket that adjusts easily to most trapezoidal roof profiles.



ProteaBracket™

888-825-3432 | www.S-5.com

## S-5!®

### The Right Way!

ProteaBracket™ is the perfect solar attachment solution for most trapezoidal exposed-fastened metal roof profiles! No messy sealants to apply. The factory-applied adhesive rubber sealant weather-proofs and makes installation easy!

Each ProteaBracket™ comes with a factory-applied, adhesive rubber sealant on the base. A structural A2 stainless steel bimetal attachment bracket, ProteaBracket is compatible with most common metal roofing materials. All four pre-punched holes must be used to achieve tested strength. Mounting hardware is furnished with the ProteaBracket. For design assistance, ask your distributor, or visit [www.S-5.com](http://www.S-5.com) for the independent lab test data that can be used for load-critical designs and applications. Also, please visit our website for more information including metallurgical compatibilities and specifications. S-5!® holding strength is unmatched in the industry.

### Multiple Attachment Options:

Side Rail Option




Top Rail Option



S-5-PV Kit Option



### ProteaBracket™



Please note: All measurements are rounded to the second decimal place.

### Example Applications



S-5-PV Kit demonstrated with a ProteaBracket on a trapezoidal profile.

### Example Profile



### S-5!® Warning! Please use this product responsibly!

Products are protected by multiple U.S. and foreign patents. For published data regarding holding strength, bolt torque, patents, and trademarks, visit the S-5! website at [www.S-5.com](http://www.S-5.com). Copyright 2013, Metal Roof Innovators, Ltd. S-5!® products are patent protected. S-5! aggressively protects its patents, trademarks, and copyrights. Version 112513.

Distributed by



### CONTRACTOR

YES SOLAR SOLUTIONS

PHONE: (919) 459-2846

ADDRESS: 202 NORTH DIXON AVENUE  
CARY, NC 27513

LIC. NO.: 67356

HIC. NO.:

ELE. NO.: 31227-U

UNAUTHORIZED USE OF THIS DRAWING SET WITHOUT WRITTEN PERMISSION FROM CONTRACTOR IS IN VIOLATION OF U.S. COPYRIGHT LAWS AND WILL BE SUBJECT TO CIVIL DAMAGES AND PROSECUTIONS.

NEW PV SYSTEM: 15.840 kWp

## BUTLER RESIDENCE

111 DEES ST  
LILLINGTON, NC 27546  
APN: 1306400004

### ENGINEER OF RECORD

PAPER SIZE: 11" x 17" (ANSI B)

### RESOURCE DOCUMENT

DATE: 03.20.2021

DESIGN BY: P.A.

CHECKED BY: M.M.

REVISIONS

R-007.00

SHEET 16