

Richard Robinson

load Calculations

55 Fisher Rd

Lillington NC 27546


$$\text{Sq}' 2400 \times 3 = 7200$$

$$\text{Small App} \quad 4500$$

Appliance

DW	1000	44,882
Micro	1450	-10,000
Washer	1200	34,882
Dryer	4000	x .40
Range	8000	13,952.8
Sewer pump	1080	+10,000
Hot water	4500	23,95.8
Disp	1152	+ 14,000
Heat	14,000	37952.8
		÷ 240
		158.14

location of lockouts



any questions please call  
Frank @ 919-498-4321