
PROJECT DETAILS			
PV Modules	27 x REC 365AA BLACK		
Optimizers	27 x P370		
Inverter	1 x SE10000H-US(RGM)		
Roof Type	Asphalt Shingles		
Racking	IronRidge XR10		
Mounting Type	Flashfoot 2		
DC SIZE	9.855 kW		
AC SIZE	10.0 kVA		

DRAWING INDEX			
Item	Drawing #	Rev	Description
1	2178SS00-0	А	Drawing Index
2	2178SS00-1	А	Sit e Layout
3	2178SS00-2	А	String Mapping
4	2178SS00-3	А	Electrical One Line Diagram
5	2178SS00-4	А	Detailed Electrical Wiring Schematic
6	2178SS00-5	А	PV Labels
7	2178SS00-6	А	Bill of Materials



### **TOP VIEW OF BUILDING**



### **FRONT VIEW OF BUILDING**







1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474

E: info@8msolar.com

Salcia Slack-Perry

44 Scotland Dr., Spring Lake NC 28390



Ali Buttar PVIP #031310-32


1_	05/04/2021	Α
JOB NUMB	ER	
	21-78-SS00	
DATE ISSU		
	05/04/2021	
PROJECT S		
	PERMITTING	
SHEET		
DRAWIN	NG INDEX	

### PV System Dead Load (Panel + Racking weight) / PV System Area

(27 modules x 43 lbs./panel + 237 ft. of racking x 1.15 lb.ft) / (27 panels x 67.8" x 40") = 2.82 psf

The roof is located in 119mph wind zone

There is one layer of shingles Roofing material is a sphalt shingles




Module Dimension	1,016mm	
Roofs	Pitch	Azimuth
А	40°	142°
В	30°	142°

1,721mm /

### **SYSTEM DETAILS**

NUMBER OF PANELS : 27 PANELS MODEL : REC 365AA BLK

DC SIZE: 9.855 KW AC SIZE: 10.0 KVA



6" clearance from each side of the roof





1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474 E: info@8msolar.com

Salcia Slack-Perry

44 Scotland Dr., Spring Lake NC 28390




Ali Buttar PVIP #031310-32

1_	05/04/2021	Α		
	<del></del>			
JOB NUMBER				
21-78-SS00				
DATE ISSUED				
05/04/2021				
PRO JECT	STATUS PERMITTING			

SITE LAYOUT

SHEET

	String Layout				
Inverter: SE10000H-US(RGM)					
Strings #	No. of Modules	Color Code	Strings #	No. of Modules	Color Code
String 1	16				
String 2	11				




Dimension	1,016mm	
Roofs	Pitch	Azimuth
Α	40°	142°
В	30°	142°

1,721mm

### **SYSTEM DETAILS**

NUMBER OF PANELS : 27 PANELS MODEL : REC 365AA BLK

DC SIZE: 9.855 KW AC SIZE: 10.0 KVA



6" clearance from each side of the roof





1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474

E: info@8msolar.com

Salcia Slack-Perry


44 Scotland Dr., Spring Lake NC 28390



Ali Buttar PVIP #031310-32

1_	05/04/2021	_ A			
OB NUMI	BER				
	21-78-SS00				
ATE ISSUED					
	05/04/2021				
ROJECT S	TATUS PERMITTING				

STRING MAPPING



1600 Heritage Commerce Ct, Ste 104 Wake Forest NC 27587 O: 919.948.6474

E: info@8msolar.com

44 Scotland Dr., Spring Lake NC 28390 Salcia Slack-Perry



Ali Buttar PVIP #031310-32

_1_	05/04/2021	Α		
JOB NUMBER				
	21-78-SS00			

DATE ISSUED

PROJECT STATUS

PERMITTING

SHEET

Rapid Shutdown is included in the Inverter, refer to

The load center / disconnect will be visible, lockable

accessible to utility linesmen and will be properly

labelled as per NEC requirements. It will be located

on the exterior wall of the building, next to the utility

inverter & optimizer attached datasheets.


**ELECTRICAL ONE LINE** DIAGRAM

> SS 2178SS00-3

### Grounding will be done via IronRidge grounding mid-**ELECTRICAL NOTES** clamps and WEEB bonding jumpers to ensure the rail and panels are continuously grounded.

- System Size: 9,855 W DC
- (27) REC 365 AA BLACK (27) SOLAREDGE P370 OPTIMIZERS
- (01) SOLAREDGE SE10000H-US 10.0 kVA AC output max
- Inverter Output: 42A max @ 240 VAC
- STRING 1: 16 x 365W = 5,840W ea I mpp = 14.6 Adc I max = 23.4 Adc V mpp = 400 VdcV o c = 16 V dc

STRING 2: 11 x 365W = 4,015W ea I mpp = 10.03 Adc I max = 23.4 Adc V m pp = 400 V dcVoc=11 Vdc





1600 Heritage Commerce Ct, Ste 104 Wake Forest NC 27587 O: 919.948.6474

E: info@8msolar.com


44 Scotland Dr., Spring Lake NC 28390 Salcia Slack-Perry



Ali Buttar PVIP #031310-32

1_	05/04/2021	_ A			
JOB NUMBER					
	21-78-SS00				
DATE ISS					
05/04/2021					
PROJECT STATUS PERMITTING					
SHEET					

**DETAILED ELECTRICAL WIRING** 



### LABELING AND WARNING SIGNS

### A PLIR POSE

PROVIDE EMERGENCY RESPONDERS WITH APPROPRIATE WARNING AND GUIDANCE WITH RESPECT TO ISOLATING THE SOLAR ELECTRIC SYSTEM. THIS CAN FACILITATE IDENTIFYING ENERGIZED ELECTRICAL LINES THAT CONNECT THE SOLAR PANELS TO THE INVERTER, AS SHOULD NOT BE CUT WHEN VENTING FOR SMOKE REMOVAL.

### B. MAIN SERVICE DISCONNECT:

- 1. RESIDENTIAL BUILDINGS-THE MARKING MAY BE PLACED WITHIN THE MAIN SERVICE DISCONNECT. THE MARKING SHALL BE PLACED ON THE OUTSIDE COVER IF THE MAIN SERVICE DISCONNECT IS OPERABLE WITH THE SERVICE PANEL CLOSED.
- 2. COMMERCIAL BUILDINGS-THE MARKINGS SHALL BE PLACED ADJACENT TO THE MAIN SERVICE DISCONNECTCLEARLY VISIBLE FROM THE LOCATION WHERE THE LEVER IS OPERATED
- 3. MARKINGS, VERBIAGE, FORMAT AND TYPE OF MATERIAL
  - a. VERBIAGE: CAUTION; SOLAR ELECTRIC SYSTEM CONNECTED b. FORMAT:
    - (1) WHITE LETTERING ON A RED BACKGROUND
    - (2) MINIMUM 3/8 INCH LETTER HEIGHT
    - (3) ALL LETTERS SHALL BE CAPITALIZED
    - (4) ARIAL OR SIMILAR FONT, NON-BOLD

### c. MATERIAL:

- (1) REFLECTIVE, WEATHER RESISTANT MATERIAL SUITABLE FOR THE ENVIRONMENT (USE UL-969) AS STANDARD FOR WEATHER RATING): DURABLE ADHESIVE MATERIALS MEET THIS REQUIREMENT.
- C. MARKING REQUIREMENTS ON DC CONDUIT, RACEWAYS, ENCLOSURES, CABLE ASSEMBLIES, DC COMBINERS AND JUNCTION BOXES;
  - 1. MARKING: PLACEMENT, VERBIAGE, FORMAT AND TYPE OF MATERIAL.
    - a. PLACEMENT: MARKINGS SHALL BE PLACED EVERY 10 (TEN) FEET ON ALL INTERIOR AND EXTERIOR DC CONDUITS, RACEWAYS, ENCLOSURES AND CABLE ASSEMBLIES, ATTURNS ABOVE AND/OR BELOW PENETRATIONS, ALL DC COMBINERS AND JUNCTION BOXES. b. VERBIAGE: CAUTION SOLAR CIRCUIT
    - c. THE FORMAT AND TYPE OF MATERIAL SHALL ADHERE TO SECTION B-3.B & C ABOVE
- D. INVERTERS ARE NOT REQUIRED TO HAVE CAUTION MARKINGS

### WARNING: PHOTOVOLTAIC POWER SOURCE

### DC DISCONNECT

#4 RAPID SHUTDOWN **SWITCH FOR** SOLAR PV SYSTEM

#5 MAXIMUM VOLTAGE MAXIMUM CIRCUIT CURRENT MAX. RATED OUTPUT CURRENT E CHARGE CONTROLLER OR -DC CONVERTER (IF INSTALLED)

PHOTOVOLTAIC POWER SOURCE

AC DISCONNECT

PHOTOVOLTAIC SYSTEM

**POWER SOURCE** 

VOLTS

RATED AC

**OUTPUT CURRENT** 

NOMINAL OPERATING

AC VOLTAGE

OPERATING AC VOLTAGE

MAXIMUM OPERATING

**AC OUTPUT CURRENT** 

#6

#7

#11

TURN OFF PHOTOVOLTAIC AC DISCONNECT PRIOR TO WORKING INSIDE PANEL

#12 **↑** WARNING BIPOLAR PHOTOVOLTAIC ARRAY

ELECTRIC SHOCK HAZARD TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION ...

**↑** WARNING

**DUAL POWER SUPPLY** SOURCES: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM

#10 **↑WARNING** 

> THIS SERVICE METER IS ALSO SERVED BY A PHOTOVOLTAIC SYSTEM

SOLAR AC DISCONNECT LOCATED AT NORTH-EAST SIDE WALL OF THE HOUSE BESIDE THE UTILITY METER

SERVICE DISCONNECT LOCATED IN MAIN LOAD PANEL BEHIND THE UTILITY **METER** 

1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 0:919.948.6474

E: info@8ms olar.com

Salcia Slack-Perry

44 Scotland Dr., Spring Lake NC 28390



Ali Buttar PVIP #031310-32

_1_	05/04/2021	Α		
IOB NUM	BER			
DATE ISSUED				
05/04/2021				
DPO IFCT	STATUS			

SS

2178SS00-5

PERMITTING

SHEET

**PV LABELS** 

DISCONNECTION OF NEUTRAL GROUNDED CONDUCTORS MAY RESULT IN OVERVOLTAGE ON ARRAY OR INVERTER

SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN THE ARRAY

**#14** SOLAR PV SYSTEM EQUIPPED

TURN RAPID SHUTDOWN

SWITCH TO THE 'OFF" POSITION TO

**↑** WARNING

THIS EQUIPMENT FED BY MULTIPLE

SOURCES. TOTAL RATING OF ALL

OVERCURRENT DEVICES. EXCLUDING

MAIN SUPPLY OVERCURRENT DEVICE, SHALL NOT EXCEED

AMPACITY OF BUSBAR.

WITH RAPID SHUTDOWN


#13

**↑** WARNING

#16

Rails and Splices: XR10	Roof Attachment : Flashfoot2	
Rafter Spacing: 24 in	There is one layer of shingles Roofing material is a sphalt shingles	
Attachment Span: 4ft	The roof is located in 119 mph wind zone	

Roof B 16 Modules



**Roof A** 

11 Modules

Module Dimension	1,721mm		
Roofs	Pitch	Azimuth	
Α	40°	142°	
В	30°	142°	



1600 Heritage Commerce Ct Ste 104, Wake Forest NC 27587 O: 919.948.6474

E: info@8msolar.com

Salcia Slack-Perry

44 Scotland Dr., Spring Lake NC 28390

### RAILS AND SPLICES

- 07 x XR-10-204B: XR10, Rail 204" (17 Feet) Black
- 10 x XR-10-168B: XR10, Rail 168" (14 Feet) Black
- 08 x XR-10-BO SS-01-M1: XR10 Bonded Splice (Incl. Selftapping Screws)

### CLAMPS & GROUNDING

- 40 x UFO-CL-01-B1: Universal Module Clamp, Black
- 28 x CAMO-01-M1: Hidden End Cam (universal clamp)
- 09 x XR-LUG-03-A1: Grounding Lug, Low Profile

### ATTACHMENTS

- 66 x FF2-01-M2: Flash Fo ot2, Mill
- 66 x B HW-SQ-02-A1: Square-Bolt Bonding Hardware

### ACCESSO RIES

- 02 x XR-10-CAP: Kit, End Cap XR10 (10 sets per bag)
- 27 x B HW-MI-01-A1: Microinverter Bonding Hardware, T-Bolt

### SOLAR MODULES

27 x REC365AA BLACK

### INVERTER & SUPPORTING ITEMS


- 01 x SolarEdge SE10000H-US (with Cons. Meter SE10000H-US000BNI4)
- 27 x SolarEdge Po wer Optimizer P370
- 01 x SE-WFGW-B-S1-NA with Antenna kit
  - 02 x 200A SolarEdge CTs
- 01 x PV Labels kit

### WIRE & DISCONNECTS

500 ft x PV WIRE BLK (Cu)

Ro w: 5'10" (1 x 7') = 7'	
Mounts = 02 (Cantilever 11")	
Cut one 14' rail into half and use	-
Row: 17'2" (1 x 14' + 1 x 7') = 21'	
Mounts = 5 (Cantilever 7")	
Row: 22'10" (1 x 17' + 1 x 7') = 24'	
Mounts = 6 (Cantilever 1'5")	

6" clearance from each side of the roof







Ali Buttar PVIP #031310-32

_1_	05/04/2021	_A				
JOB NUME	JOB NUMBER					
	21-78-SS00					
DATE ISSU						
	05/04/2021					
PROJECT STATUS						
	PERMITTING					
SHEET						


SS 2178SS00-2

STRING MAPPING









# REC ALPHX BLACK SERIES


375 W<sub>P</sub> POWER

20 YEAR PRODUCT WARRANTY

25 YEAR POWER OUTPUT WARRANTY



### C ALPHO BLACK SERIES



### **GENERAL DATA**

Cell type:	120 half-cut cells with REC heterojunction cell technology 6 strings of 20 cells in series
Glass:	0.13 in (3.2 mm) solar glass with anti-reflection surface treatment
Backsheet:	Highly resistant polymeric construction
Frame:	Anodized aluminum (black)

Junction box:	3-part, 3 bypass diodes, IP67 rated in accordance with IEC 62790
Cable:	12 AWG (4 mm²) PV wire, 39 + 47 in (1 + 1.2 m) in accordance with EN 50618
Connectors:	Stäubli MC4PV-KBT4/KST4,12AWG (4mm²) in accordance with IEC 62852 IP68 only when connected
Origin:	Made in Singapore

Product Code\*: RECxxxAA Black

### **ELECTRICAL DATA @ STC**

Nominal Power - P <sub>MPP</sub> (Wp)	355	360	365	370	375
Watt Class Sorting - (W)	-0/+5	-0/+5	-0/+5	-0/+5	-0/+5
Nominal Power Voltage - V <sub>MPP</sub> (V)	37.4	37.7	38.0	38.3	38.7
Nominal Power Current - I <sub>MPP</sub> (A)	9.50	9.55	9.60	9.66	9.72
Open Circuit Voltage - V <sub>oc</sub> (V)	44.0	44.1	44.3	44.5	44.6
Short Circuit Current - I <sub>SC</sub> (A)	10.19	10.23	10.26	10.30	10.40
Panel Efficiency (%)	20.3	20.6	20.9	21.2	21.4
VI	AAA1 E : 10 7 E IAA	5 (1000) 11/ 2)		n= (n=ne)	

Values at standard test conditions (STC: air mass AM1.5, irradiance 10.75 W/sq ft (1000 W/m²), temperature 77°F (25°C), based on a production spread with a tolerance of  $V_{oc}$  &  $I_{sc}$  ±3% within one watt class. \*Where xxx indicates the nominal power class ( $P_{MPP}$ ) at STC above.

ELECTRICAL DATA @ NM	10T
----------------------	-----

ELECTRICAL DATA @ NMOT	P	roduct Code*	:RECxxxAA	Black	
Nominal Power - P <sub>MPP</sub> (Wp)	270	274	278	282	286
Nominal Power Voltage - V <sub>MPP</sub> (V)	35.2	35.5	35.8	36.1	36.4
Nominal Power Current - I <sub>MPP</sub> (A)	7.67	7.71	7.76	7.80	7.85
Open Circuit Voltage - V <sub>oc</sub> (V)	41.4	41.6	41.7	41.9	42.0
Short Circuit Current-I <sub>SC</sub> (A)	8.23	8.26	8.29	8.32	8.40
Naminal and January in the second of AIMOT air and	ANALE :	00141/3 1	COSE (200C)		/. /1 /.\ *

Nominal module operating temperature (NMOT: air mass AM 1.5, irradiance  $800 \, \text{W/m}^2$ , temperature  $68^\circ\text{F}$  ( $20^\circ\text{C}$ ), windspeed  $3.3 \, \text{ft/s}$  ( $1 \, \text{m/s}$ ). Where xxx indicates the nominal power class  $(P_{MPP})$  at STC above.

### CERTIFICATIONS

IEC 61215:2016, IEC 61730:2016, UL 1703, UL 61730			
IEC 62804	PID		
IEC 61701	Salt Mist		
IEC 62716	Ammonia Resistance		
UL 1703	Fire Type Class 2		
IEC 62782	Dynamic Mechanical Load		
IEC 61215-2:2016	Hailstone (35mm)		
AS4040.2 NCC 2016	Cyclic Wind Load		
100110012001100120120120120120120012007			

ISO 14001:2004, ISO 9001:2015, OHSAS 18001:2007









### WARRANTY

20 year product warranty 25 year linear power output warranty Maximum annual power degression of 0.25% p.a. Guarantees 92% of power after 25 years See warranty conditions for further details.

### MECHANICAL DATA

Dimensions:	67.8 x 40 x 1.2 in (1721 x 1016 x 30 mm)
Area:	18.8 sq ft (1.75 m²)
Weight:	43 lbs (19.5 kg)

### MAXIMUM RATINGS

Operational temperature:	-40+85°C
Maximum system voltage:	1000 V
Design load (+): snow Maximum test load (+):	4666 Pa (97.5 lbs/sq ft)⁺ 7000 Pa (146 lbs/sq ft)*
Design load (-): wind Maximum test load (-):	2666 Pa (55.6 lbs/sq ft)⁺ 4000 Pa (83.5 lbs/sq ft)*
Max series fuse rating:	25 A
Max reverse current:	25 A

\*Calculated using a safety factor of 1.5
\*See installation manual for mounting instructions


### TEMPERATURE RATINGS\*

Nominal Module Operating Temperature:	44°C (±2°C)
Temperature coefficient of $P_{\text{MPP}}$ :	-0.26 %/°C
Temperature coefficient of $V_{\rm oc}$ :	-0.24 %/°C
Temperature coefficient of I <sub>sc</sub> :	0.04 %/°C

\*The temperature coefficients stated are linear values

### LOW LIGHT BEHAVIOUR

Typical low irradiance performance of module at STC:





Founded in Norway in 1996, REC is a leading vertically integrated solar energy company. Through integrated manufacturing from silicon to wafers, cells, high-quality panels and extending to solar solutions, REC provides the world with a reliable source of clean energy. REC's renowned product quality is supported by the lowest warranty claims rate in the industry. REC is a Bluestar Elkem company with headquarters in Norway and operational headquarters in Singapore. REC employs around 2,000 people worldwide, producing 1.5 GW of solar panels annually.





## Single Phase Inverter with HD-Wave Technology

### for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US





### Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Record-breaking 99% weighted efficiency
- Quick and easy inverter commissioning directly from a smartphone using the SolarEdge SetApp
- Fixed voltage inverter for longer strings
- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12

UL1741 SA certified, for CPUC Rule 21 grid compliance

NVERTE

- Small, lightweight, and easy to install both outdoors or indoors
- Built-in module-level monitoring
- Optional: Faster installations with built-in consumption metering (1% accuracy) and production revenue grade metering (0.5% accuracy, ANSI C12.20)



### Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US

MODEL NUMBER	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
APPLICABLE TO INVERTERS WITH PART NUMBER		SEXXXXH-XXXXXBXX4						
OUTPUT	•							
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
Maximum AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
AC Output Voltage MinNomMax. (211 - 240 - 264)	✓	✓	✓	✓	✓	✓	<b>√</b>	Vac
AC Output Voltage MinNomMax. (183 - 208 - 229)	-	<b>√</b>	-	✓	-	-	<b>✓</b>	Vac
AC Frequency (Nominal)				59.3 - 60 - 60.5 <sup>(1)</sup>		,		Hz
Maximum Continuous Output Current @240V	12.5	16	21	25	32	42	47.5	А
Maximum Continuous Output Current @208V	-	16	-	24	-	-	48.5	А
Power Factor			1,	, Adjustable - 0.85 to	0.85			
GFDI Threshold				1				А
Utility Monitoring, Islanding Protection, Country Configurable Thresholds				Yes				
INPUT								
Maximum DC Power @240V	4650	5900	7750	9300	11800	15500	17650	W
Maximum DC Power @208V	-	5100	-	7750	-	-	15500	W
Transformer-less, Ungrounded				Yes				
Maximum Input Voltage				480				Vdc
Nominal DC Input Voltage		3	380			400		Vdc
Maximum Input Current @240V <sup>(2)</sup>	8.5	10.5	13.5	16.5	20	27	30.5	Adc
Maximum Input Current @208V <sup>(2)</sup>	-	9	-	13.5	-	-	27	Adc
Max. Input Short Circuit Current				45				Adc
Reverse-Polarity Protection				Yes				
Ground-Fault Isolation Detection				600kΩ Sensitivity				
Maximum Inverter Efficiency	99			9	9.2			%
CEC Weighted Efficiency		99 99 240V 98.5 @ 208V						%
Nighttime Power Consumption				< 2.5				W

 $<sup>^{\</sup>mbox{\tiny (1)}}$  For other regional settings please contact SolarEdge support

<sup>&</sup>lt;sup>(2)</sup> A higher current source may be used; the inverter will limit its input current to the values stated

### Single Phase Inverter with HD-Wave Technology for North America


SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/ SE7600H-US / SE10000H-US / SE11400H-US

MODEL NUMBER	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US			
ADDITIONAL FEATURES	1		•	•						
Supported Communication Interfaces		RS485, Ethernet, ZigBee (optional), Cellular (optional)								
Revenue Grade Metering, ANSI C12.20				Optional <sup>(3)</sup>						
Consumption metering										
Inverter Commissioning		With the Set	App mobile applicat	ion using Built-in Wi-	Fi Access Point for Lo	ocal Connection				
Rapid Shutdown - NEC 2014 and 2017 690.12			Automatic Rap	id Shutdown upon A	C Grid Disconnect					
STANDARD COMPLIANCE										
Safety		UL1741,	UL1741 SA, UL1699B	, CSA C22.2, Canadia	an AFCI according to	T.I.L. M-07				
Grid Connection Standards			IEE	E1547, Rule 21, Rule	14 (HI)					
Emissions				FCC Part 15 Class I	3					
INSTALLATION SPECIFICAT	TIONS									
AC Output Conduit Size / AWG Range		1'	' Maximum / 14-6 A\	WG		1" Maximum /	14-4 AWG			
DC Input Conduit Size / # of Strings / AWG Range		1" Maximum / 1-2 strings / 14-6 AWG 1" Maximum / 1-3 strings / 14-6 AWG					ings / 14-6 AWG			
Dimensions with Safety Switch (HxWxD)		17.7 x 14.6 x 6.8 / 450 x 370 x 174 21.3 x 14.6 x 7.3 / 540 x 370 x 185						in / mm		
Weight with Safety Switch	22 /	10	25.1 / 11.4	26.2	/ 11.9	38.8 / 1	7.6	lb / kg		
Noise		<	25			<50		dBA		
Cooling				Natural Convectio	n					
Operating Temperature Range		-40 to +140 / -40 to +60 <sup>(4)</sup>						°F/°C		
Protection Rating		NEMA 4X (Inverter with Safety Switch)								

<sup>(3)</sup> Inverter with Revenue Grade Meter P/N: SExxxxH-US000BNC4; Inverter with Revenue Grade Production and Consumption Meter P/N: SExxxxH-US000BNI4 . For consumption metering, current transformers should be ordered separately. SEACT0750-200NA-20 or SEACT0750-400NA-20. 20 units per box

### **How to Enable Consumption Monitoring**

By simply wiring current transformers through the inverter's existing AC conduits and connecting them to the service panel, homeowners will gain full insight into their household energy usage helping them to avoid high electricity bills





<sup>(4)</sup> Full power up to at least 50°C / 122°F; for power de-rating information refer to: https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf

### **Power Optimizer**

### **For North America**

P320 / P340 / P370 / P400 / P401 / P405 / P485 / P505





# POWER OPTIMIZER

### PV power optimization at the module-level

- Specifically designed to work with SolarEdge inverters
- Up to 25% more energy
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch losses, from manufacturing tolerance to partial shading
- Flexible system design for maximum space utilization

- Fast installation with a single bolt
- Next generation maintenance with modulelevel monitoring
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System (PVRSS)
- Module-level voltage shutdown for installer and firefighter safety



### / Power Optimizer **For North America**

### P320 / P340 / P370 / P400 / P401 / P405 / P485 / P505

Optimizer model (typical module compatibility)	P320 (for 60-cell modules)	P340 (for high- power 60-cell modules)	P370 (for higher- power 60 and 72- cell modules)	P400 (for 72 & 96-cell modules)	P401 (for high power 60 and 72 cell modules)	P405 (for high- voltage modules)	P485 (for high- voltage modules)	P505 (for higher current modules)	
INPUT		•	•				•		
Rated Input DC Power <sup>(1)</sup>	320	340	370	4	00	405	485	505	W
Absolute Maximum Input Voltage (Voc at lowest temperature)	4	8	60	80	60	12	5 <sup>(2)</sup>	83 <sup>(2)</sup>	Vdc
MPPT Operating Range	8 -	48	8 - 60	8 - 80	8-60	12.5	- 105	12.5 - 83	Vdc
Maximum Short Circuit Current (Isc)		11		10.1	11.75	1	1	14	Adc
Maximum DC Input Current		13.75		12.5	14.65	12	2.5	17.5	Adc
Maximum Efficiency				99.	5				%
Weighted Efficiency				98.8				98.6	%
Overvoltage Category				II					
<b>OUTPUT DURING OPER</b>	ATION (POV	VER OPTIMI	ZER CONNEC	TED TO OPE	RATING SOL	AREDGE IN	VERTER)		
Maximum Output Current				15	i				Adc
Maximum Output Voltage			60				85		Vdc
<b>OUTPUT DURING STANI</b>	DBY (POWER	OPTIMIZER	DISCONNECT	ED FROM SC	LAREDGE IN	IVERTER OR	SOLAREDGI	E INVERTER O	OFF)
Safety Output Voltage per Power Optimizer				1 ±	0.1				Vdc
STANDARD COMPLIAN	CE								
EMC			FCC Pa	rt15 Class B, IEC6	1000-6-2, IEC6100	D-6-3			
Safety			,	IEC62109-1 (class	II safety), UL1741				
Material		UL94 V-0 , UV Resistant							
RoHS				Ye	S				
INSTALLATION SPECIFI	CATIONS								
Maximum Allowed System Voltage				100	00				Vdc
Compatible inverters			All SolarE	dge Single Phase	and Three Phase i	nverters			
Dimensions (W x L x H)	129 :	× 153 × 27.5 / 5.1 >	( 6 x 1.1	129 x 153 x 33.5 / 5.1 x 6 x 1.3	129 x 153 x 29.5 /5.1 x 6 x 1.16	129 x 159 x 49.5	5 / 5.1 x 6.3 x 1.9	129 x 162 x 59 / 5.1 x 6.4 x 2.3	mm / in
Weight (including cables)		630 / 1.4		750 / 1.7	655 / 1.5	845	/ 1.9	1064 / 2.3	gr/lb
Input Connector			МС	4 <sup>(3)</sup>			Single or dual MC4 <sup>(3)(4)</sup>	MC4 <sup>(3)</sup>	
Input Wire Length				0.16 /	0.52				m/ft
Output Wire Type / Connector				Double Insul	ated / MC4				
Output Wire Length	0.9 /	2.95			1.2 /	3.9			m/ft
Operating Temperature Range <sup>(5)</sup>		-40 - +85 / -40 - +185						°C / °F	
Protection Rating		IP68 / NEMA6P							
Relative Humidity				0 - 1	00				%

<sup>(1)</sup> Rated power of the module at STC will not exceed the optimizer "Rated Input DC Power". Modules with up to +5% power tolerance are allowed

PV System Design Using a SolarEdge Inverter <sup>(6)(7)</sup>		Single Phase HD-Wave	Single phase	Three Phase for 208V grid	Three Phase for 277/480V grid	
Minimum String Length	P320, P340, P370, P400, P401	8		10	18	
(Power Optimizers)	P405, P485, P505	6	5	8	14	
Maximum String Length (Power Op	Maximum String Length (Power Optimizers)		25		50(8)	
Maximum Power per String		5700 (6000 with SE7600-US - SE11400- US) 5250		6000 <sup>(9)</sup>	12750 <sup>(10)</sup>	W
Parallel Strings of Different Lengths	or Orientations		Ye	es		



<sup>(2)</sup> NEC 2017 requires max input voltage be not more than 80V

<sup>(3)</sup> For other connector types please contact SolarEdge
(4) For dual version for parallel connection of two modules use P485-4NMDMRM. In the case of an odd number of PV modules in one string, installing one P485 dual version power optimizer connected to one PV module. When connecting a single module seal the unused input connectors with the supplied pair of seals.

(5) For ambient temperature above +85°C / +185°F power de-rating is applied. Refer to Power Optimizers Temperature De-Rating Technical Note for more details.

<sup>(6)</sup> For detailed string sizing information refer to: http://www.solaredge.com/sites/default/files/string\_sizing\_na.pdf
(7) It is not allowed to mix P405/P485/P505 with P320/P340/P370/P400/P401 in one string
(8) A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement

<sup>(9)</sup> For 208V grid: it is allowed to install up to 6,500W per string when the maximum power difference between each string is 1,000W

<sup>(10)</sup> For 277/480V grid: it is allowed to install up to 15,000W per string when the maximum power difference between each string is 2,000W



Intertek 3933 US Route 11 Cortland, NY 13045 Telephone: 607-753-7311 www.intertek.com

Subject: ETL Evaluation of SolarEdge Products to NEC 2017 Rapid Shutdown Requirements

To, whom it may concern

This letter represents the testing results of the below listed products to the requirements contained in the following standards:

The evaluation was done on the PV Rapid Shutdown System (PVRSS), and covers installations consisting of optimizers and inverters with part numbers listed below.

The testing done has verified that controlled conductors are limited to:

- Not more than 30 volts and 240 voltamperes within 30 seconds of rapid shutdown initiation outside the array.
- Not more than 80 volts and 240 voltamperes within 30 seconds of rapid shutdown initiation inside the array.

The rapid shutdown initiation is performed by either disconnecting the AC feed to the inverter, or – if the inverter DC Safety switch is readily accessible – by turning off the DC Safety switch.

### **Applicable products:**

(1) Power optimizers:

PB followed by 001 to 350; followed by -AOB or -TFI. OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV. P followed by 001 to 860.

SP followed by 001 to 350.

When optimizers are connected to 2 or more modules in series, the max input voltage may exceed 80V. Following the implementation of the NEC 2017 rapid shutdown value of 80V max inside of the array at the beginning of 2019, modules exceeding this combined input max voltage will be required to use optimizers with parallel inputs.

(2) 1 -PH Inverters

 $SE3000A-US\ /\ SE3800A-US\ /\ SE5000A-US\ /\ SE6000A-US\ /\ SE7600A-US\ /\ SE10000A-US\ /\ SE11400A-US\ /\ SE3000H-US\ /\ SE5000H-US\ /\ SE5000H-US\ /\ SE5000H-US\ /\ SE11400H-US\ when the following label is labeled on the side of the inverter:$ 

Inverter part number may be followed by a suffix.

(3) 3 -PH Inverters

SE9KUS / SE10KUS / SE14.4KUS / SE20KUS / SE30KUS / SE33.3KUS / SE43.2KUS / SE66.6KUS / SE100KUS; when the following label is labeled on the side of the inverter:

Please note, this Letter Report does not represent authorization for the use of any Intertek certification marks.



Intertek 3933 US Route 11 Cortland, NY 13045 Telephone: 607-753-7311 www.intertek.com

Brand Name(s) SolarEdge

Relevant Standard(s) UL 1741, UL 1741 CRD for rapid shutdown

National Electric Code, 2017, Section 690.12 requirement for

rapid shutdown

**Verification Issuing Office** 3933 US Route 11, Cortland, NY 13045

NRTL Disclaimer, Different for each NRTL – Example: "This Verification is for the exclusive use of NRTL's Client and is provided pursuant to the agreement between NRTL and its Client. NRTL's responsibility and liability are limited to the terms and conditions of the agreement. NRTL assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the NRTL name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by NRTL. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an NRTL certification program."

Signature:

Name: Mukund Rana

Position: Engineering Team Leader

Date: 2/11/2020




### **XR** Rail Family

### **Solar Is Not Always Sunny**

Over their lifetime, solar panels experience countless extreme weather events. Not just the worst storms in years, but the worst storms in 40 years. High winds capable of ripping panels from a roof, and snowfalls weighing enough to buckle a panel frame.

XR Rails are the structural backbone preventing these results. They resist uplift, protect against buckling and safely and efficiently transfer loads into the building structure. Their superior spanning capability requires fewer roof attachments, reducing the number of roof penetrations and the amount of installation time.



### Force-Stabilizing Curve

Sloped roofs generate both vertical and lateral forces on mounting rails which can cause them to bend and twist. The curved shape of XR Rails is specially designed to increase strength in both directions while resisting the twisting. This unique feature ensures greater security during extreme weather and a longer system lifetime.

### Compatible with Flat & Pitched Roofs



XR Rails are compatible with FlashFoot and other pitched roof attachments.



IronRidge offers a range of tilt leg options for flat roof mounting applications.

### **Corrosion-Resistant Materials**

All XR Rails are made of 6000-series aluminum alloy, then protected with an anodized finish. Anodizing prevents surface and structural corrosion, while also providing a more attractive appearance.



### **XR Rail Family**

The XR Rail Family offers the strength of a curved rail in three targeted sizes. Each size supports specific design loads, while minimizing material costs. Depending on your location, there is an XR Rail to match.



### **XR10**

XR10 is a sleek, low-profile mounting rail, designed for regions with light or no snow. It achieves spans up to 6 feet, while remaining light and economical.

- · 6' spanning capability
- · Moderate load capability
- · Clear & black anodized finish
- · Internal splices available



### XR100

XR100 is the ultimate residential mounting rail. It supports a range of wind and snow conditions, while also maximizing spans up to 10 feet.

- · 10' spanning capability
- · Heavy load capability
- · Clear & black anodized finish
- · Internal splices available



### XR1000

XR1000 is a heavyweight among solar mounting rails. It's built to handle extreme climates and spans up to 12 feet for commercial applications.

- · 12' spanning capability
- · Extreme load capability
- Clear anodized finish
- · Internal splices available

### **Rail Selection**

The table below was prepared in compliance with applicable engineering codes and standards.\* Values are based on the following criteria: ASCE 7-16, Gable Roof Flush Mount, Roof Zones 1 & 2e, Exposure B, Roof Slope of 8 to 20 degrees and Mean Building Height of 30 ft. Visit IronRidge.com for detailed certification letters.

Load		Rail Span					
Snow (PSF)	Wind (MPH)	4'	5' 4"	6'	8'	10'	12'
	90						
None	120						
None	140	XR10		XR100		XR1000	
	160						
	90						
20	120						
20	140						
	160						
30	90						
30	160						
40	90						
40	160						
80	160						
120	160	11.1					

<sup>\*</sup>Table is meant to be a simplified span chart for conveying general rail capabilities. Use approved certification letters for actual design guidance.



### FlashFoot2

### **The Strongest Attachment in Solar**

IronRidge FlashFoot2 raises the bar in solar roof protection. The unique water seal design is both elevated and encapsulated, delivering redundant layers of protection against water intrusion. In addition, the twist-on Cap perfectly aligns the rail attachment with the lag bolt to maximize mechanical strength.

# Three-Tier Water Seal

### Twist-On Cap


FlashFoot2's unique Cap design encapsulates the lag bolt and locks into place with a simple twist. The Cap helps FlashFoot2 deliver superior structural strength, by aligning the rail and lag bolt in a concentric load path.



FlashFoot2's seal architecture utilizes three layers of protection. An elevated platform diverts water away, while a stack of rugged components raises the seal an entire inch. The seal is then fully-encapuslated by the Cap. FlashFoot2 is the first solar attachment to pass the TAS-100 Wind-Driven Rain Test.

### Single Socket Size


A custom-design lag bolt allows you to install FlashFoot2 with the same 7/16" socket size used on other Flush Mount System components.



### Water-Shedding Design

An elevated platform diverts water away from the water seal.

### **Installation Features**



### (A) Alignment Markers

Quickly align the flashing with chalk lines to find pilot holes.

### (B) Rounded Corners

Makes it easier to handle and insert under the roof shingles.


### C Reinforcement Ribs

Help to stiffen the flashing and prevent any bending or crinkling during installation.

### **Benefits of Concentric Loading**

Traditional solar attachments have a horizontal offset between the rail and lag bolt, which introduces leverage on the lag bolt and decreases uplift capacity.

FlashFoot2 is the only product to align the rail and lag bolt. This concentric loading design results in a stronger attachment for the system.



### **Testing & Certification**

### **Structural Certification**

Designed and Certified for Compliance with the International Building Code & ASCE/SEI-7.

### **Water Seal Ratings**

Water Sealing Tested to UL 441 Section 27 "Rain Test" and TAS 100-95 "Wind Driven Rain Test" by Intertek. Ratings applicable for composition shingle roofs having slopes between 2:12 and 12:12.

### **UL 2703**

Conforms to UL 2703 Mechanical and Bonding Requirements. See Flush Mount Install Manual for full ratings.

### PRE-INSTALLATION

□ Verify module compatibility. See Page 13 for info.

### **TOOLS REQUIRED**

- ☐ Cordless Drill (non-impact)
- ☐ Impact Driver (for lag bolts)
- ☐ Torque Wrench (0-250 in-lbs)
- □ 5/16" Socket
- □ 7/16" Socket
- ☐ 1/2" Socket
- ☐ String Line

### **TORQUE VALUES**

- ☐ FlashFoot2 Lag Bolts (7/16" Socket): Fully Seat
- ☐ Bonded Splice Screws (5/16" Socket): 20 in-lbs
- ☐ Grounding Lug Nuts (7/16" Socket): 80 in-lbs
- ☐ Grounding Lug Terminal Screws (7/16" Socket): 20 in-lbs
- ☐ Universal Fastening Object (7/16" Socket): 80 in-lbs
- □ Expansion Joint Nuts (7/16" Socket): 80 in-lbs
- ☐ Flush Standoffs (1/2" Socket): 132 in-lbs
- ☐ Microinverter Kit Nuts (7/16" Socket): 80 in-lbs
- ☐ Frameless Module Kit Nuts (7/16" Socket): 80 in-lbs
- □ 3/8" Bonding Hardware Nuts (7/16" Socket): 250 in-lbs
- ☐ All Tile Hook Lags (7/16" Socket): Fully Seat
- ☐ All Tile Hook Carriage Bolts (7/16" Socket): 132 in-lbs
- ☐ Knockout Tile Lags (1/2" Socket): Fully Seat
- ☐ Knockout Tile Nuts (1/2" Socket): 132 in-lbs
- ☐ Flat Roof Attachment Nuts (9/16" Socket): 250 in-lbs


### IRONRIDGE COMPONENTS



XR Rail



**Bonded Splice** 



L-Foot



FlashFoot2



UFO and Stopper Sleeve



**CAMO** 



8" Bonding Jumper



Grounding Lug



**Expansion Joint** 



**End Cap** 




Wire Clip



Flush Standoff



Microinverter Kit



3/8" Bonding Hardware



Frameless Module Kit




Frameless End/Mid Clamp



All Tile Hook




All Tile Hook Flashing



Knockout Tile



Flat Roof Attachment



Membrane Flashing

If using FlashVue or previous version of: FlashFoot, Integrated Grounding Mid Clamps, Grounding Lug, End Clamps, and Expansion Joints please refer to Alternate Components Addendum (Version 1.3).

### **D222NRB**

Safety Switch , 60A, Fusible, Cartridge (Class H, K or R), 2-Pole





List Price \$326.00 USD

by Schneider Electric

Availability Stock Item: This item is normally stocked in our distribution facility.

### **Technical Characteristics**

Terminal Type	Lugs
Type of Duty	General Duty
Maximum Voltage Rating	240VAC
Wire Size	#10 to #2 AWG(AI) - #14 to #2 AWG(Cu)
Depth	4.83 Inches
Height	14.88 Inches
Width	6.63 Inches
Action	Single Throw
Ampere Rating	60A
Approvals	UL Listed File: E2875
Enclosure Rating	NEMA 3R
Enclosure Type	Rainproof and Sleet/Ice proof (Indoor/Outdoor)
Enclosure Material	Galvannealed Steel
Factory Installed Neutral	Yes
Fuse Type	Cartridge (Class H, K or R)
Disconnect Type	Fusible
Short Circuit Current Rating	100kA (max. depending on fuse type)
Mounting Type	Surface
Number of Poles	2-Pole

### **Shipping and Ordering**

Category	00106 - Safety Switch, General Duty, 30 - 200 Amp, NEMA3R
Discount Schedule	DE1A
GTIN	00785901460640
Package Quantity	1
Weight	8.35 lbs.
Availability Code	Stock Item: This item is normally stocked in our distribution facility.
Returnability	Υ
Country of Origin	US

As standards, specifications, and designs change from time to time, please ask for confirmation of the information given in this document.

Generated: 06/30/2010 15:53:57





### UL

PROJECT INFORMATION:	_
JOB:	_
APPROVALS:	

### **POLARIS**<sup>TM</sup>

Pre-Insulated Connectors

To enable users to achieve desired ampacity with a UL listed pre-insulated connector through paralleling, NSi Industries' Polaris™ line of connectors have been fully tested and meet the specifications for UL 486 A/B for 90°C conductor (copper and aluminum) in accordance with the National Electrical Code (NEC).

See the chart to the right that shows the maximum ampacity for connectors utilized in parallel applications.

Although these connectors have been tested in the worst case condition (Line conductor(s) on one end of the connector and load conductor(s) on opposite end of connector), laboratory tests have shown that the connector will run cooler if the load is distributed evenly. The recommendation is to stagger the line and load conductors (line-load-line-load-line-load) throughout the wire connector. If that is not possible, another practice that would run cooler is to place the main/line conductors in the center of the connector and the load/tap conductors on the outer ports of the connector.







### **Max Ampacity**

SIZE OF CONNECTOR	# OF PARALLEL CONDUCTORS	# OF CONNECTOR WIRE PORTS	COPPER CONDUCTOR (AMPS)	ALUMINUM CONDUCTOR (AMPS)
250	2	4	527	410
250	3	6	790	615
250	4	8	1053	820
350	2	4	657	514
350	3	6	985	770
350	4	8	1314	1028
500	2	4	806	631
500	3	6	1209	946
500	4	8	1612	1262
600	2	4	1035	810
600	3	6	1554	1215
600	4	8	2070	1620
750	2	4	1178	930
750	3	6	1767	1395
750	4	8	2356	1860





UL50 Type 3R Enclosure • Stamped 18 gauge gal. steel • Powder coated finish • Weather tight

### **Enclosure Includes:**

- Dual ground lug
- · Universal DIN rail
- 1/2". 3/4" & 1" knockouts
- · Wire strain relief clip
- Complete hardware package



### INTRODUCED AT SOLAR POWER 2007





### **PV Roof-Mount Combiner/Enclosure**

### **Benefits**

- •The ability to prep the building is now possible
- Replaces several parts used today
- Provides professional looking install
- · Saves time on install
- Allows for easy access
- Guaranteed seal to roof
- Low profile design

For product information contact us at [866] 367-7782

www.commdeck.com



RSTC Enterprises, Inc 2219 Heimstead Road Eau Claire, WI 54703 1 (866) 367 - 7782





### SolaDeck Part # 780

### **Specifications:**

18 Gauge Steel Base (1) and Cover (2)
Pre Punched 7 holes in base (1) for roof deck
Pre Punched 4 holes in base (1) and cover (2) for match
Draw Process both parts
Powder Coated to withstand 1000 hours Salt Spray (Primer Gray)
High UV resistance
15" x 15" flashing dimension
Cavity dimension 8"W x 9" L x 2.5"D
Approx. 162 Cubic inch equipment cavity
Norloked steel base plate (3) to drawn base (2)
Three knockout locations .5", .75" and 1"
3" DIN rail installed
Grounding Lug- Installed (In Equipment Cavity)
Wire Strain Relief Clip –Installed (In Equipment Cavity)
Hardware pack withstands 500 hours Salt Spray

- 7 2" Trusshead Screws
- 4 .5" 8-32 thread cutting screws
- 4 #10 Bonded Seal washers
- 1 Foam closed Cell Seal

ETL Listed UL50 Type 3R

**Total Weight 6.9 pounds each** 

### Packaging:

Individually bagged and boxed
Box dimension 15.5"w x 16" L x 3" D
White Carton labeled with Cut out template
Print One Color - Black

Master Cartons of 6 Units each
Master Carton dimension 18.75"x16"x16.375"
Master Carton Weight – 42 pounds
18 Master Cartons per skid Approx 800 pounds with skid