


© 2019 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.

NOTICE TO CONTRACTOR:
All construction must comply with current NC Building Codes and is subject to field inspection and verification.

APPROVED
Contract building only -
Harnett County responsible for
full compliance with the code.


06/17/2021

PV MATERIAL SUMMARY: DISTRIBUTOR

Q.PEAK DUO BLK-G8+340	35
P401	35
SE10000H-US000BNU4	1
SE-ZBCW-B-S1-NA	1
XR-10-168B	18
XR-10-204B	1
XR10-BOSS-01-M1	4
UFO-CL-01-4H	86
UFO-STP-32MM-B1	32
XR-LUG-03-A1	8
4 IN QB1	85
GC66803 Geocel Sealant	6
SOLADECK 0799-5B	5

NC SOLAR NOW



6/17/21






CLIENT INFO
AMANDA SOTO
407 CORKSBURY PARK LANE
LUQUAY-VARINA, NC 27526

PROJECT INFO
DC INPUT: 11.90 kW
AC EXPORT: 10.00 kW
DOINSPT METHOD: OPTION 2

CODE REFERENCES
NATION ELECTRICAL CODE v. 2017
NC FIRE PROTECTION CODE v. 2018
NC BUILDING CODE v. 2018
NC RESIDENTIAL CODE v. 2018
ACSE v. 7-10

SITE CONDITIONS
WIND SPEED: 115 MPH
RISK CATEGORY: B
EXPOSURE: B
SNOW: 15 PSF


SHEET INDEX
PV-1 COVER SHEET
PV-2 PV STRUCTURAL
PV-3 PV ELECTRICAL
PV-4 PV EQUIPMENT LABELS
PV-5 PV INSTALL GUIDE

DESIGNER INFO
DESIGNER: CRM
ENGINEER: AAK
DATE: 6/10/2021
VERSION: P1

PV SYSTEM COVER PAGE

PV-1.1






© 2019 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.




STATEMENT OF STRUCTURAL COMPLIANCE

THE EXISTING ROOF STRUCTURE HAS BEEN DESIGNED TO SUPPORT THE ADDITIONAL LOADS OF THE PROPOSED PV SYSTEM. IN ADDITION, THE RACKING AND FASTENING SYSTEM SHALL BE CAPABLE OF SECURING THE SYSTEM TO THE STRUCTURE UNDER DESIGN CONDITIONS WHEN INSTALLED PROPERLY AND IN ACCORDANCE WITH THE RACKING AND FASTENING ARRANGEMENT DETAILED WITHIN THESE DRAWINGS.

NAME: ANDREW W. KING, PE
 SIGNED: *Andrew W. King*



1 ROOF FASTENER DETAIL
 NOT TO SCALE



2 ROOF ARRAY LAYOUT
 1/8" = 1'-0"

PV MODULES	
MAKE	HANWHA
MODEL	Q.PEAK DUO BLK-G-34-340
WIDTH	40.60 IN
LENGTH	68.50 IN
THICKNESS	32 MM
WEIGHT	4.90 LBS
ARRAY AREA	290 SQFT
ARRAY WEIGHT	724 LBS



ROOF SUMMARY	
STRUCTURE TYPE	RAFTERS
MATERIAL	SOUTHERN PINE #2
SIZE	2 X 8
SPACING	16 IN O.C.
EFFECTIVE SPAN	202 IN
PITCH	7/12
DENSITY	30 LBS./CU.FT.
DECKING TYPE	OSB
MATERIAL THICKNESS	7/16 IN
WEIGHT	1.60 LBS./SQ.FT.
ROOFING TYPE	ASPHALT SHINGLE
MATERIAL WEIGHT	ASPHALT 2.30 LBS./SQ.FT.

ROOF MOUNT SUMMARY		
MAXIMUM (IN)	MOUNT SPACING	RAIL OVERHANG
WIND ZONE 1	64 IN	26 IN
WIND ZONE 2	48 IN	26 IN
WIND ZONE 3	48 IN	23 IN

ROOF LOADING	
GROUND SNOW LOAD:	15 LBS./SQ.FT.
DEAD LOAD:	20 LBS./SQ.FT.
ROOFING:	1.9 LBS./SQ.FT.
PV ARRAY:	2.5 LBS./SQ.FT.
TOTAL:	6.4 LBS./SQ.FT.
WIND LOAD:	
UPLIFT ZONE 1	-24.6 LBS./SQ.FT.
UPLIFT ZONE 2	-29.0 LBS./SQ.FT.
UPLIFT ZONE 3	-29.0 LBS./SQ.FT.
DOWNWARD:	23.0 LBS./SQ.FT.
FASTENER LOAD:	
UPLIFT ZONE 1	-371 LBS.
UPLIFT ZONE 2	-328 LBS.
UPLIFT ZONE 3	-328 LBS.
DOWNWARD	347 LBS.

ROOF MOUNT & FASTENER	
ROOF MOUNT MAKE	QUICKBOLT
MODEL	4 IN CQB
MATERIAL	STAINLESS / EPDM
FASTENER MAKE	SOLAR ROOF HOOK
MODEL	HANGER BOLT
MATERIAL	304 SS
SIZE	5/16-18 X 5-1/4"
GENERAL WEIGHT	0.56 LBS.
FASTENERS PER MOUNT	1
MAX. PULL-OUT FORCE	960.0 LBS.
SAFETY FACTOR	2
DESIGN PULL-OUT FORCE	480.0 LBS.

MOUNTING RAILS	
MAKE	IRONRIDGE
MODEL	SR10
MATERIAL	ALUMINUM
WEIGHT	0.425 LBS/IN
SPACING	34 IN



CLIENT INFO
 AMANDA SOTO
 407 CORNSBURY PARK LANE
 FUQUAY-VARINA, NC 27526

PROJECT INFO
 DC INPUT: 11.90 kW
 AC EXPORT: 10.00 kW
 DC/INSP. METHOD: OPTION 2

CODE REFERENCES
 NATION ELECTRICAL CODE v. 2017
 NC FIRE PROTECTION CODE v. 2018
 NC BUILDING CODE v. 2018
 NC RESIDENTIAL CODE v. 2018
 ACSE v. 7-10

SITE CONDITIONS
 WIND SPEED: 115 MPH
 RISK CATEGORY: II
 EXPOSURE: B
 SNOW: 15 PSI


SHEET INDEX
 PV-1 COVER SHEET
 PV-2 PV STRUCTURAL
 PV-3 PV ELECTRICAL
 PV-4 PV EQUIPMENT LABELS
 PV-5 PV INSTALL GUIDE

DESIGNER INFO
 DESIGNER: CRBA
 ENGINEER: AWWK
 DATE: 6/10/2021
 VERSION: P1

PV SYSTEM STRUCTURAL

PV-2.1






© 2018 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.




STATEMENT OF STRUCTURAL COMPLIANCE

THE EXISTING ROOF STRUCTURE HAS BEEN DESIGNED TO SUPPORT THE ADDITIONAL LOADS OF THE PROPOSED PV SYSTEM. IN ADDITION, THE RACKING AND FASTENING SYSTEM SHALL BE CAPABLE OF SECURING THE SYSTEM TO THE STRUCTURE UNDER DESIGN CONDITIONS WHEN INSTALLED PROPERLY AND IN ACCORDANCE WITH THE RACKING AND FASTENING ARRANGEMENT DETAILED WITHIN THESE DRAWINGS.

NAME: ANDREW W. KING, PE
 SIGNED: *Andrew W. King*



1 ROOF FASTENER DETAIL
NOT TO SCALE



2 ROOF B ARRAY LAYOUT
1/8" = 1'-0"

PV MODULES	
MAKE	18ANWHV
MODEL	Q PEAK L100 REC-8+340
WIDTH	40.60 IN
LENGTH	68.50 IN
THICKNESS	12 MM
WEIGHT	43.90 LBS
ARRAY AREA	77.52 SQ FT
ARRAY WEIGHT	1911 LBS

ROOF SUMMARY	
STRUCTURE	RAFTERS
TYPE	SOUTHERN PINE #2
MATERIAL	2 X 8
SIZE	16 IN O.C.
SPACING	167 IN
EFFECTIVE SPAN	7/12
PITCH	30 LBS./CU FT
DENSITY	OSB
DECKING	COMPOSITE
TYPE	2 1/4 IN
MATERIAL	1.60 LBS./SQ FT
THICKNESS	ASPHALT SHINGLE
ROOFING	ASPHALT
TYPE	2.30 LBS./SQ FT
MATERIAL	
WEIGHT	


ROOF MOUNT SUMMARY		
MAXIMUM (IN)	MOUNT SPACING	RAIL OVERHANG
WIND ZONE 1	64 IN	26 IN
WIND ZONE 2	48 IN	25 IN
WIND ZONE 3	48 IN	23 IN

ROOF LOADING	
GROUND SNOW LOAD:	15 LBS./SQ FT
UP E LOAD:	20 LBS./SQ FT
DEAD LOAD:	1.9 LBS./SQ FT
ROOFING:	2.5 LBS./SQ FT
PV ARRAY:	6.4 LBS./SQ FT
TOTAL:	
WIND LOAD:	
UPLIFT ZONE 1	-24.6 LBS./SQ FT
UPLIFT ZONE 2	-29.0 LBS./SQ FT
UPLIFT ZONE 3	-29.0 LBS./SQ FT
DOWNWARD:	23.0 LBS./SQ FT
FASTENER LOAD:	
UPLIFT ZONE 1	-372 LBS
UPLIFT ZONE 2	-329 LBS
UPLIFT ZONE 3	-329 LBS
DOWNWARD	348 LBS

ROOF MOUNT & FASTENER	
ROOF MOUNT	QUICKBOLT
MAKE	4 IN QBT
MODEL	STAINLESS / EPDM
MATERIAL	
FASTENER:	
MAKE	SOLAR ROOF HOOK
MODEL	HANGER BOLT
MATERIAL	304 SS
SIZE	5/16-18 X 5-1/4"
GENERAL:	
WEIGHT	0.56 LBS
FASTENERS PER MOUNT	1
MAX. PULL-OUT FORCE	960.0 LBS
SAFETY FACTOR	2
DESIGN PULL-OUT FORCE	480.0 LBS

MOUNTING RAILS	
MAKE	IRONRIDGE
MODEL	XRT0
MATERIAL	ALUMINUM
WEIGHT	0.425 LBS/IN
SPACING	34 IN

NC SOLAR NOW



CLIENT INFO
 AMANDA SOTO
 407 COMBSBURY PARK LANE
 FUQUAY-VARRA, NC 27726

PROJECT INFO
 DC INPUT: 11.90 kW
 AC EXPORT: 10.00 kW
 DC/INSP. METHOD: OPTION 2

CODE REFERENCES
 NATION ELECTRICAL CODE v. 2017
 NC FIRE PROTECTION CODE v. 2018
 NC BUILDING CODE v. 2018
 NC RESIDENTIAL CODE v. 2018
 ACSE v. 7.10

SITE CONDITIONS
 WIND SPEED: 115 MPH
 RISK CATEGORY: II
 EXPOSURE: B
 SNOW: 15 PSF


SHEET INDEX
 PV-1 COVER SHEET
 PV-2 PV STRUCTURAL
 PV-3 PV ELECTRICAL
 PV-4 PV EQUIPMENT LABELS
 PV-5 PV INSTALL GUIDE

DESIGNER INFO
 DESIGNER: CRM
 ENGINEER: AVK
 DATE: 4/18/2021
 VERSION: P1

PV SYSTEM STRUCTURAL

PV-2.2






© 2019 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.




STATEMENT OF STRUCTURAL COMPLIANCE

THE EXISTING ROOF STRUCTURE HAS BEEN DESIGNED TO SUPPORT THE ADDITIONAL LOADS OF THE PROPOSED PV SYSTEM. IN ADDITION, THE RACKING AND FASTENING SYSTEM SHALL BE CAPABLE OF SECURING THE SYSTEM TO THE STRUCTURE UNDER DESIGN CONDITIONS WHEN INSTALLED PROPERLY AND IN ACCORDANCE WITH THE RACKING AND FASTENING ARRANGEMENT DETAILED WITHIN THESE DRAWINGS.

NAME: ANDREW W. KING, PE
SIGNED: *Andrew W. King*



1 ROOF FASTENER DETAIL
NOT TO SCALE



2 ROOF C ARRAY LAYOUT
1/8" = 1'-0"

PV MODULES	
MAKE	HANWHA
MODEL	Q PEAK DUO REC-G+340
WIDTH	40.60 IN
LENGTH	65.50 IN
THICKNESS	32 MM
WEIGHT	43.90 LBS
ARRAY AREA	155 SQFT
ARRAY WEIGHT	386 LBS

ROOF SUMMARY	
STRUCTURE	RAFTERS
TYPE	SOUTHERN PINE #2
MATERIAL	2 X 8
SIZE	16 IN O.C.
SPACING	163 IN
EFFECTIVE SPAN	7/12
PITCH	30 LBS./CU.FT
DENSITY	OSB
DECKING	COMPOSITE
TYPE	7/16 IN
MATERIAL	1.60 LBS./SQ.FT
THICKNESS	ASPHALT SHINGLE
WEIGHT	ASPHALT
ROOFING	2.30 LBS./SQ.FT
TYPE	
MATERIAL	
WEIGHT	


ROOF MOUNT SUMMARY		
MAXIMUM (IN)	MOUNT SPACING	RAIL OVERHANG
WIND ZONE 1	64 IN	26 IN
WIND ZONE 2	48 IN	25 IN
WIND ZONE 3	48 IN	23 IN

ROOF LOADING	
GROUND SNOW LOAD:	15 LBS./SQ.FT
LIVE LOAD:	20 LBS./SQ.FT
DEAD LOAD:	
ROOFING:	1.9 LBS./SQ.FT
PV ARRAY:	2.5 LBS./SQ.FT
TOTAL:	6.4 LBS./SQ.FT
WIND LOAD:	
UPLIFT ZONE 1	-24.6 LBS./SQ.FT
UPLIFT ZONE 2	-29.0 LBS./SQ.FT
UPLIFT ZONE 3	-29.0 LBS./SQ.FT
DOWNWARD:	23.0 LBS./SQ.FT
FASTENER LOAD:	
UPLIFT ZONE 1	-372 LBS
UPLIFT ZONE 2	-329 LBS
UPLIFT ZONE 3	-329 LBS
DOWNWARD	348 LBS

ROOF MOUNT & FASTENER	
ROOF MOUNT:	QUICKBOLT
MAKE	4 IN QRB
MODEL	STAINLESS / EPDM
MATERIAL	
FASTENER:	SOLAR ROOF HOOK
MAKE	HANGER BOLT
MODEL	304 SS
MATERIAL	5/16-18 X 5-1/4"
SIZE	
GENERAL:	
WEIGHT	0.56 LBS.
FASTENERS PER MOUNT	1
MAX. PULL-OUT FORCE	960.0 LBS.
SAFETY FACTOR	2
DESIGN PULL-OUT FORCE	480.0 LBS.

MOUNTING RAILS	
MAKE	IRONRIDGE
MODEL	AR10
MATERIAL	ALUMINUM
WEIGHT	0.425 LBS/IN
SPACING	34 IN

NC SOLAR NOW



CLIENT INFO
AMANDA SOTO
407 COKESBURY PARK LANE
FUQUAY-VARINA, NC 27526

PROJECT INFO
DC INPUT: 11.90 kW
AC EXPORT: 10.00 kW
DC INSP. METHOD: OPTION 2

CODE REFERENCES
NATION ELECTRICAL CODE v. 2017
NC FIRE PROTECTION CODE v. 2018
NC BUILDING CODE v. 2018
NC RESIDENTIAL CODE v. 2018
ACSE v. 7-10

SITE CONDITIONS
WIND SPEED: 115 MPH
RISK CATEGORY: B
EXPOSURE: B
SNOW: 15 PSF


SHEET INDEX
PV-1 COVER SHEET
PV-2 PV STRUCTURAL
PV-3 PV ELECTRICAL
PV-4 PV EQUIPMENT LABELS
PV-5 PV INSTALL GUIDE

DESIGNER INFO
DESIGNER: CRM
ENGINEER: AIVK
DATE: 6/10/2021
VERSION: P1

PV SYSTEM STRUCTURAL

PV-2.3






© 2019 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.




STATEMENT OF STRUCTURAL COMPLIANCE

THE EXISTING ROOF STRUCTURE HAS BEEN DESIGNED TO SUPPORT THE ADDITIONAL LOADS OF THE PROPOSED PV SYSTEM. IN ADDITION, THE RACKING AND FASTENING SYSTEM SHALL BE CAPABLE OF SECURING THE SYSTEM TO THE STRUCTURE UNDER DESIGN CONDITIONS WHEN INSTALLED PROPERLY AND IN ACCORDANCE WITH THE RACKING AND FASTENING ARRANGEMENT DETAILED WITHIN THESE DRAWINGS.

NAME: ANDREW W. KING, PE
 SIGNED: *Andrew W. King*



1 ROOF FASTENER DETAIL
NOT TO SCALE



2 ROOF D ARRAY LAYOUT
1/8" = 1'-0"

PV MODULES	
MAKE	HANWHA
MODEL	Q.PEAK DUO BLK-G64-340
WIDTH	40.60 IN
LENGTH	68.50 IN
THICKNESS	32.3MM
WEIGHT	43.90 LBS
ARRAY AREA	97 SQFT
ARRAY WEIGHT	241 LBS

ROOF SUMMARY	
STRUCTURE	RAFTERS
TYPE	SOUTHERN PINE #2
MATERIAL	2 X 8
SIZE	16 IN O.C.
SPACING	1.50 IN
EFFECTIVE SPAN	7/12
PITCH	30 LBS./CU.FT.
DENSITY	OSB
DECKING	COMPOSITE
TYPE	7/16 IN
MATERIAL	1.60 LBS./SQ.FT.
THICKNESS	ASPHALT SHINGLE
WEIGHT	ASPHALT
ROOFING	2.30 LBS./SQ.FT.
TYPE	
MATERIAL	
WEIGHT	

ROOF MOUNT SUMMARY		
MAXIMUM (IN)	MOUNT SPACING	RAIL OVERHANG
WIND ZONE 1	64 IN	26 IN
WIND ZONE 2	48 IN	25 IN
WIND ZONE 3	48 IN	23 IN

ROOF LOADING	
GROUND SNOW LOAD:	15 LBS./SQ.FT.
LIVE LOAD:	20 LBS./SQ.FT.
DEAD LOAD:	
ROOFING:	3.9 LBS./SQ.FT.
PV ARRAY:	2.5 LBS./SQ.FT.
TOTAL:	6.4 LBS./SQ.FT.
WIND LOAD:	
UPLIFT ZONE 1:	-24.6 LBS./SQ.FT.
UPLIFT ZONE 2:	-29.0 LBS./SQ.FT.
UPLIFT ZONE 3:	-29.0 LBS./SQ.FT.
DOWNWARD:	23.0 LBS./SQ.FT.
FASTENER LOAD:	
UPLIFT ZONE 1:	-372 LBS.
UPLIFT ZONE 2:	-329 LBS.
UPLIFT ZONE 3:	-329 LBS.
DOWNWARD:	348 LBS.

ROOF MOUNT & FASTENER	
ROOF MOUNT:	QUICKBOLT
MAKE	4 IN Q/BT
MODEL	STAINLESS / EPDM
MATERIAL	
FASTENER:	
MAKE	SOLAR ROOF HOOK
MODEL	HANGER BOLT
MATERIAL	304 SS
SIZE	5/16-1/8 X 5-1/4"
GENERAL:	
WEIGHT	0.56 LBS
FASTENERS PER MOUNT	1
MAX. PULL-OUT FORCE	960.0 LBS.
SAFETY FACTOR	2
DESIGN PULL-OUT FORCE	480.0 LBS.

MOUNTING RAILS	
MAKE	IRONRIDGE
MODEL	XR10
MATERIAL	ALUMINUM
WEIGHT	0.425 LBS/IN
SPACING	34 IN

NC SOLAR NOW



CLIENT INFO
 AMANDA SOLO
 407 CORNBERY PARK LANE
 FUQUAY-VARINA, NC 27526

PROJECT INFO
 DC INPUT: 11.90 kW
 AC EXPORT: 10.00 kW
 DC/INSP. METHOD: OPTION 2

CODE REFERENCES
 NATIONAL ELECTRICAL CODE v. 2017
 NC FIRE PROTECTION CODE v. 2018
 NC BUILDING CODE v. 2018
 NC RESIDENTIAL CODE v. 2018
 ACSE v. 7-10

SITE CONDITIONS
 WIND SPEED: 115 MPH
 RISK CATEGORY: B
 EXPOSURE: B
 SNOW: 15 PSF


SHEET INDEX
 PV-1 COVER SHEET
 PV-2 PV STRUCTURAL
 PV-3 PV ELECTRICAL
 PV-4 PV EQUIPMENT LABELS
 PV-5 PV INSTALL GUIDE

DESIGNER INFO
 DESIGNER: CRM
 ENGINEER: AWK
 DATE: 6/18/2021
 VERSION: P1

PV SYSTEM STRUCTURAL

PV-2.4






© 2019 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.




STATEMENT OF STRUCTURAL COMPLIANCE

THE EXISTING ROOF STRUCTURE HAS BEEN DESIGNED TO SUPPORT THE ADDITIONAL LOADS OF THE PROPOSED PV SYSTEM. IN ADDITION, THE RACKING AND FASTENING SYSTEM SHALL BE CAPABLE OF SECURING THE SYSTEM TO THE STRUCTURE UNDER DESIGN CONDITIONS WHEN INSTALLED PROPERLY AND IN ACCORDANCE WITH THE RACKING AND FASTENING ARRANGEMENT DETAILED WITHIN THESE DRAWINGS.

NAME: ANDREW W. KING, PE
SIGNED: *Andrew W. King*



1 ROOF FASTENER DETAIL
NOT TO SCALE



2 ROOF ARRAY LAYOUT
1/8" = 1'-0"

PV MODULES	
MAKE	HANNIFIA
MODEL	Q PEAK DUVO BLY-G06-340
WIDTH	40.40 IN
LENGTH	48.50 IN
THICKNESS	32 MM
WEIGHT	41.90 LBS
ARRAY AREA	58 SQFT
ARRAY WEIGHT	145 LBS

ROOF SUMMARY	
STRUCTURE TYPE	RAFTERS
MATERIAL	SOUTHERN PINE #2
SIZE	2 X 8
SPACING	16 IN O.C.
EFFECTIVE SPAN	139 IN
PITCH	7/12
DENSITY	30 LBS./CU.FT.
DECKING TYPE	OSB
MATERIAL THICKNESS	7/16 IN
WEIGHT	1.60 LBS/SQFT
ROOFING TYPE	ASPHALT SHINGLE
MATERIAL WEIGHT	2.30 LBS/SQFT

ROOF MOUNT SUMMARY		
MAXIMUM IN	MOUNT SPACING	RAIL OVERHANG
WIND ZONE 1	64 IN	26 IN
WIND ZONE 2	48 IN	25 IN
WIND ZONE 3	48 IN	23 IN

ROOF LOADING	
GROUND SNOW LOAD:	15 LBS./SQFT
LIVE LOAD:	20 LBS./SQFT
DEAD LOAD:	
ROOFING:	3.9 LBS./SQFT
PV ARRAY:	2.5 LBS./SQFT
TOTAL:	6.4 LBS./SQFT
WIND LOAD:	
UPLIFT ZONE 1:	-24.6 LBS./SQFT
UPLIFT ZONE 2:	-29.0 LBS./SQFT
UPLIFT ZONE 3:	-29.0 LBS./SQFT
DOWNWARD:	23.0 LBS./SQFT
FASTENER LOAD:	
UPLIFT ZONE 1:	-372 LBS
UPLIFT ZONE 2:	-329 LBS
UPLIFT ZONE 3:	-329 LBS
DOWNWARD:	348 LBS

ROOF MOUNT & FASTENER	
ROOF MOUNT:	
MAKE	QUICKBOLT
MODEL	4 IN QB1
MATERIAL	STAINLESS / EPDM
FASTENER:	
MAKE	SOLAR ROOF HOOK
MODEL	HANGER BOLT
MATERIAL	304 SS
SIZE	5/16-18 X 5-1/4"
GENERAL:	
WEIGHT	0.56 LBS
FASTENERS PER MOUNT	1
MAX. PULL-OUT FORCE	960.0 LBS
SAFETY FACTOR	2
DESIGN PULL-OUT FORCE	480.0 LBS

MOUNTING RAILS	
MAKE	IRONRIDGE
MODEL	XR10
MATERIAL	ALUMINUM
WEIGHT	0.425 LBS/LIN
SPACING	34 IN

NC SOLAR NOW



CLIENT INFO
AMANDA SOTO
407 CORESBURY PARK LANE
FUQUAY-VARINA, NC 27526

PROJECT INFO
DC INPUT: 11.90 kW
AC EXPORT: 10.00 kW
DOI INSP. METHOD: OPTION 2

CODE REFERENCES
NATION ELECTRICAL CODE v. 2017
NC FIRE PROTECTION CODE v. 2018
NC BUILDING CODE v. 2018
NC RESIDENTIAL CODE v. 2018
ACSE v. 7-10

SITE CONDITIONS
WIND SPEED: 115 MPH
RISK CATEGORY: II
EXPOSURE: B
SNOW: 15 PSF

SHEET INDEX
PV-1 COVER SHEET
PV-2 PV STRUCTURAL
PV-3 PV ELECTRICAL
PV-4 PV EQUIPMENT LABELS
PV-5 PV INSTALL GUIDE

DESIGNER INFO
DESIGNER: CRM
ENGINEER: AWK
DATE: 6/10/2021
VERSION: PT

PV SYSTEM STRUCTURAL

PV-2.5

© 2019 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.

CONDUCTOR SCHEDULE										
TAG	CURRENT CARRYING CONDUCTORS			GROUNDING CONDUCTORS			CONDUIT/RACEWAY			NOTES
	QTY.	SIZE	INSULATION	QTY.	SIZE	INSULATION	QTY.	SIZE	LOCATION	
C1	6	10 AWG	THWN	1	6 AWG	THWN	-	-	FRET AIR	1
C2	6	10 AWG	THWN	1	10 AWG	THWN	1	3/4"	EXT/INT	2,4
C3	3	6 AWG	THWN	1	10 AWG	THWN	1	3/4"	EXTERIOR	2,4
C4	3	6 AWG	THWN	-	-	-	1	3/4"	EXTERIOR	2,4
XC	-	-	-	-	-	-	-	-	-	3

PV MODULE	
MAKE	HANWHA
MODEL	Q.PEAK TWO BRK-L84-140
NOM. POWER (PNOM)	340 WATTS
NOM. VOLT (VMPP)	34.3 VOLTS
O.C. VOLT (VOC)	40.7 VOLTS
MAX. SYS. VOLT	1000 VOLTS
NOM. CURR (IMPP)	9.9 AMPS
S.C. CURR (ISC)	10.4 AMPS
TEMP. COEFF. (PMPP)	-0.15 %/°C
TEMP. COEFF. (VOC)	-0.27 %/°C
MAX. SERIES FUSE	20 AMPS
UL LIST. (VNI)	YES

MODULE OPTIMIZER	
MAKE	SOLAREDGE
MODEL	P401
DC INPUT:	
NOM. POWER	400 WATTS
VOLT. RANGE	8 to 60
MAX. CURR.	11.8 AMPS
DC OUTPUT:	
NOM. POWER	400 WATTS
MAX. VOLT	60 VOLTS
MAX. CURR.	15 AMPS
MIN-MAX STRING	8-15 OPTIMIZERS
UL LIST. (VNI)	YES

DC / AC INVERTER	
MAKE	SOLAREDGE
MODEL	SE10000H-US0006N14
DC INPUT:	
MAX. POWER	15500 WATTS
VOLT. RANGE	400-480
NOM. VOLT.	400 VOLTS
MAX. CURRENT	27 AMPS
STRING INPUTS	3 STRINGS
AC OUTPUT:	
MAX. POWER	10000 WATTS
NOM. POWER	10000 WATTS
NOM. VOLT.	211-240-264
MAX. CURR.	42.00 AMPS
DC DISC. (VNI)	YES
RAPID SHUTDOWN (VNI)	YES
PROTECT. RATING	NEMA TYP. 4X
UL LIST. (VNI)	YES
CONSUMPTION MONITOR	No

JUNCTION BOX	
MAKE	SOLADECK
PROTECT. RATING	NEMA TYP. 3R
UL LIST. (VNI)	YES


METER COMBO (EXISTING)	
MAKE	EATON-CUTLER HAMMER
MODEL	NA
ENCL. RATING	NEMA 3R
VOLT. RATING	240
BUS RATING	200 AMPS
UL LIST. (VNI)	YES
MAIN BREAKER (VNI)	YES
MAIN BREAKER RATING	200 AMPS

AC DISCONNECT	
MAKE	GENERIC
MODEL	NA
ENCL. RATING	NEMA 3R
VOLT. RATING	240 VOLTS
AMP RATING	60 AMPS
UL LIST. (VNI)	YES
FUSED (VNI)	YES
FUSE RATING	60 A

- NOTES:
1. MANUFACTURER PROVIDED, UL LISTED WIRING HARNESS FOR USE ON EXPOSED ROOFS
 2. CONDUIT SIZE SHOWN IS CODE MINIMUM. LARGER SIZES ARE ALLOWED.
 3. EXISTING CONDUCTORS, FIELD VERIFY
 4. EQUIPMENT TERMINAL RATING SHALL BE A MINIMUM OF 75°C AT BOTH END OF CONDUCTOR
 5. PLEASE REFERENCE NOTES ON PV-4 FOR ADDITIONAL DETAIL

- BACK-FEED SOLAR OUTPUT VIA SUPPLY SIDE TAP INSIDE OF MD PANEL
- MAIN BREAKER SERVES AS SERVICE DISCONNECT

- LOAD-BREAK RATED
- VISIBLE OPEN
- LOCKABLE IN OPEN POSITION
- INSTALL ADJACENT TO METER
- DISCONNECT TO BE READILY ACCESSIBLE TO UTILITY COMPANY PERSONNEL AT ALL TIMES
- SERVICE RATED
- PROVIDE NEUTRAL/GROUND BONDING JUMPER



1 ELECTRICAL SCHEMATIC
NTS

NC
SOLAR
NOW



CLIENT INFO
AMANDA SOTO
407 COKESBURY PARK LANE
FLOUQUA, VARIOVA, NC 27526

PROJECT INFO
DC INPUT: 11.90 kW
AC INPUT: 10.00 kW
DOI INSP. METHOD: OPTION 2

CODE REFERENCES
NATION ELECTRICAL CODE v. 2017
NC FIRE PROTECTION CODE v. 2018
NC BUILDING CODE v. 2018
NC RESIDENTIAL CODE v. 2018
ACSE v. 7-10

SITE CONDITIONS
WIND SPEED: 115 MPH
RISK CATEGORY: II
EXPOSURE: B
SNOW: 15 INCH

SHEET INDEX
PV-1 COVER SHEET
PV-2 PV STRUCTURAL
PV-3 PV ELECTRICAL
PV-4 PV EQUIPMENT LABELS
PV-5 PV INSTALL GUIDE

DESIGNER INFO
DESIGNER: CRM
ENGINEER: AWK
DATE: 6/19/2021
VERSION: P1

PV SYSTEM
ELECTRICAL

PV-3.1

© 2019 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.

⚠ WARNING
ELECTRIC SHOCK HAZARD
 TERMINALS ON THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION
 NEC 690.13 (B)
 PLACE ON PV SYSTEM DISCONNECTING MEANS


⚠ WARNING
POWER SOURCE OUTPUT CONNECTION
 DO NOT RELOCATE THIS OVERCURRENT DEVICE
 NEC 705.12 (D)(2)(3)(b)
 PLACE ADJACENT TO BACK-PED BREAKER

⚠ WARNING
DUAL POWER SUPPLY
 SOURCES: UTILITY GRID AND PV SOLAR ELECTRIC SYSTEM
 NEC 705.12 (D)(3)
 PLACE ON ALL EQUIPMENT THAT IS SUPPLIED BY BOTH POWER SOURCES

WARNING: PHOTOVOLTAIC POWER SOURCE
 NEC 690.51 (C)(3)(b)(4)
 PLACE ON ALL JUNCTION BOXES, EXPOSED BACKWAYS, AND OTHER WIRING METHODS EVERY 10' AND ON EVERY SECTION SEPARATED BY ENCLOSURES, WALLS, PARTITIONS, CEILINGS, OR FLOORS

RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM
 NEC 690.56 (C)(3)
 PLACE ON RAPID SHUTDOWN SWITCH OR EQUIPMENT WITH INTEGRATED RAPID SHUTDOWNS *REFLECTIVE*

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN



NEC 690.56 (C)(3)(b)
 PLACE WITHIN 5 FT OF SERVICE DISCONNECTING MEANS TO WHICH THE PV SYSTEMS ARE CONNECTED AND SHALL INDICATE THE LOCATIONS OF RAPID SHUTDOWN SWITCHES

PV SYSTEM DISCONNECT
 NEC 690.13 (B)
 PLACE ON PV SYSTEM DISCONNECTING MEANS

PHOTOVOLTAIC POWER SOURCE
 OPERATING AC VOLTAGE 240 V
 MAXIMUM OPERATING AC OUTPUT CURRENT 42.0 A
 NEC 690.54
 PLACE ON INTERCONNECTION DISCONNECTING MEANS

DIRECT CURRENT PHOTOVOLTAIC POWER SOURCE
 MAXIMUM VOLTAGE 600 VDC
 MAX CIRCUIT CURRENT 45.0 AMPS
 NEC 690.55
 PLACE ON ALL DC DISCONNECTING MEANS

SERVICE DISCONNECT LOCATED: EXTERIOR WEST WALL OF HOME

PV DISCONNECT LOCATED: EXTERIOR WEST WALL OF HOME

NEC 705.10
 PLACE AT SERVICE EQUIPMENT AND PV SYSTEM DISCONNECTING MEANS

LABEL NOTES

- LABELS SHOWN ARE HALF THEIR ACTUAL REQUIRED SIZE.
- LABEL MATERIAL SHALL BE SUITABLE FOR THE EQUIPMENT ENVIRONMENT.
- DC CONDUIT SHALL BE MARKED WITH REQUIRED LABEL EVERY 10 FEET.
- LABELS WILL BE APPLIED IN ACCORDANCE WITH THE NEC. SOME LABELS MAY NOT BE NECESSARY.

DC WIRING NOTES


- CONDUCTORS SHALL BE COPPER, RATED AT NOT LESS THAN 600 VOLTS FOR RESIDENTIAL CONSTRUCTION AND NOT LESS THAN 1000 VOLTS FOR COMMERCIAL CONSTRUCTION.
- MINIMUM SIZE SHALL BE #10 AWG UNLESS OTHERWISE NOTED ON THE DRAWINGS.
- EXPOSED WIRING CONDUCTOR INSULATION SHALL BE TYPE PV WIRE, USE-2, OR RHW-2 WHERE THE OUTER LAYER OF THE INSULATION IS UV, SUNLIGHT, AND MOISTURE RESISTANT.
- EXTERIOR WIRING CONDUCTOR INSULATION SHALL BE TYPE THWN-2 AND INSTALLED IN ELECTRICAL METALLIC TUBING(EMT) OR RIGID POLYVINYL CHLORIDE CONDUIT(PVC). ALTERNATIVELY, METAL CLAD CABLE(MC) CAN BE USED AS WELL WHEN RATED FOR USE IN WET LOCATIONS.
- INTERIOR WIRING CONDUCTOR INSULATION SHALL BE TYPE THHN-2 AND INSTALLED IN ELECTRICAL METALLIC TUBING(EMT), FLEXIBLE METAL CONDUIT(FMC), OR METAL CLAD CABLE(MC).
- USE SCHEDULE 40 PVC OUTDOORS WHERE NOT SUBJECT TO PHYSICAL DAMAGE OR BELOW FLOOR SLAB. USE SCHEDULE 80 PVC OUTDOORS WHERE SUBJECT TO PHYSICAL DAMAGE
- MINIMUM CONDUIT SIZE TO BE 1/2".
- WIRING METHODS TO CONFORM TO ARTICLES 330, 334, 348, 350, 352, 356, AND 358 OF THE 2017 NEC.

AC WIRING NOTES

- CONDUCTORS SHALL BE COPPER RATED AT NOT LESS THAN 600 VOLTS.
- MINIMUM SIZE SHALL BE #14 AWG UNLESS OTHERWISE NOTED ON THE DRAWINGS.
- EXTERIOR WIRING CONDUCTOR INSULATION SHALL BE TYPE THWN AND INSTALLED IN ELECTRICAL METALLIC TUBING(EMT), RIGID POLYVINYL CHLORIDE CONDUIT(PVC), LIQUID-TIGHT FLEXIBLE METAL CONDUIT(LFMC), OR LIQUID-TIGHT FLEXIBLE NON-METALLIC CONDUIT(LFNC). ALTERNATIVELY, METAL CLAD CABLE(MC) CAN BE USED AS WELL WHEN RATED FOR USE IN WET LOCATIONS.
- INTERIOR WIRING CONDUCTOR INSULATION SHALL BE TYPE THHN AND INSTALLED IN ELECTRICAL METALLIC TUBING(EMT), FLEXIBLE METAL CONDUIT(FMC), METAL CLAD CABLE(MC), OR ROMEX
- USE SCHEDULE 40 PVC OUTDOORS WHERE NOT SUBJECT TO PHYSICAL DAMAGE OR BELOW FLOOR SLAB. USE SCHEDULE 80 PVC OUTDOORS WHERE SUBJECT TO PHYSICAL DAMAGE
- MINIMUM CONDUIT SIZE TO BE 1/2".
- WIRING METHODS TO CONFORM TO ARTICLES 330, 334, 348, 350, 352, 356, AND 358 OF THE 2017 NEC.

CONSTRUCTION NOTES

- ALL WORK IS TO BE PERFORMED IN ACCORDANCE WITH THE NEC, STATE, AND LOCAL APPLICABLE CODES.
- FOLLOW MANUFACTURER'S INSTALLATION INSTRUCTIONS, BEST PRACTICES, AND SPECIFICATIONS.
- ENSURE REQUIRED MAINTENANCE ACCESS AND CLEARANCES ARE MAINTAINED.
- WIRES SHALL BE RATED AND LABELED "SUNLIGHT RESISTANT" WHERE EXPOSED TO AMBIENT CONDITIONS.
- FUSES 0 - 600 AMPS SHALL BE UL CLASS "RK-1" LOW PEAK DUAL ELEMENT TIME DELAY WITH 200,000 AMPERE INTERRUPTING RATING AS MANUFACTURED BY BUSSMANN, UNLESS NOTED OTHERWISE.
- ALL TERMINALS/LUGS SHALL BE 75° RATED. ALL TERMINALS, SPLICING CONNECTORS, LUGS, ETC SHALL BE IDENTIFIED FOR USE WITH THE MATERIAL (CU/AL) OF THE CONDUCTOR AND SHALL BE PROPERLY INSTALLED.
- PROVIDE A PULLWIRE IN ALL EXTERIOR CONDUITS.
- ALL PENETRATIONS THROUGH EXTERIOR ROOFS SHALL BE FLASHED IN A WATERPROOF MANNER.
- ALL PENETRATIONS THROUGH ATTIC FIRE BARRIERS SHALL BE SEALED WITH FIRE-BARRIER SEALANT CAULK.
- SUPPORT ALL CONDUIT AND EQUIPMENT IN ACCORDANCE W/ NEC. ANY SUSPENDED MATERIALS SHALL BE DIRECTLY SUPPORTED BY THE BUILDING STRUCTURE.
- METAL CONDUIT COUPLINGS CAN BE COMPRESSION TYPE, THREADED, OR BE SET-SCREW TYPE. PLASTIC CONDUIT COUPLINGS TO BE SOCKET GLUED TYPE.
- A COMPLETE GROUNDING SYSTEM SHALL BE PRESENT OR PROVIDED AND INSTALLED IN ACCORDANCE WITH ARTICLE 250 OF THE NEC, AND AS SHOWN ON THE DRAWINGS.
- EACH ELECTRICAL APPLIANCE SHALL BE PROVIDED WITH A NAMEPLATE GIVING THE IDENTIFYING NAME AND THE RATING IN VOLTS AND AMPERES, OR VOLTS AND WATTS. IF THE APPLIANCE IS TO BE USED ON A SPECIFIC FREQUENCY OR FREQUENCIES, IT SHALL BE SO MARKED. WHERE MOTOR OVERLOAD PROTECTION EXTERNAL TO THE APPLIANCES IS REQUIRED, THE APPLIANCE SHALL BE SO MARKED.
- WHERE APPLICABLE, GROUNDING ELECTRODE CONDUCTOR TO BE CONTINUOUS. GROUNDING CRIMPS TO BE IRREVERSIBLE.
- PHOTOVOLTAIC SYSTEMS SHALL BE PERMANENTLY MARKED AT VARIOUS EQUIPMENT LOCATIONS TO IDENTIFY THAT A PHOTOVOLTAIC SYSTEM IS INSTALLED AND THAT VARIOUS DANGERS ARE PRESENT.
- EACH PHOTOVOLTAIC SYSTEM DISCONNECTING MEANS SHALL BE PERMANENTLY MARKED TO IDENTIFY IT AS A PHOTOVOLTAIC SYSTEM DISCONNECT.
- WHERE ALL TERMINALS OF A DISCONNECTING MEANS MAY BE ENERGIZED IN THE OPEN POSITION, A WARNING SIGN SHALL BE MOUNTED ON OR ADJACENT TO THE DISCONNECT.
- A PERMANENT LABEL FOR THE DIRECT-CURRENT PHOTOVOLTAIC POWER SOURCE SHALL BE PROVIDED AT THE DC DISCONNECT MEANS.
- A PERMANENT PLAQUE OR DIRECTORY, DENOTING ALL ELECTRICAL POWER SOURCES SERVING THE PREMISES, SHALL BE INSTALLED AT EACH SERVICE EQUIPMENT LOCATION AND AT LOCATIONS OF ALL POWER PRODUCTION SOURCES.
- ALL MODULE GROUND CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH NEC SECTION 690.4 (C)
- A NORTH CAROLINA REGISTERED DESIGN PROFESSIONAL WILL BE REQUIRED TO SEAL THE STRUCTURAL DESIGN AT THE TIME OF PERMIT APPLICATION IF ANY OF THE FOLLOWING EXIST AND ARE ATTESTED TO BY THE APPLICANT:
 - THE WEIGHT OF THE PV SYSTEM EXCEEDS THREE (3) POUNDS PER SQUARE FOOT(PSF)
 - THE ROOF POSSESSES MORE THAN ONE (1) LAYER OF ASPHALT SHINGLES
 - THE ROOFING MATERIAL CONSISTS OF A TYPE OTHER THAN ASPHALT SHINGLES OR METAL
 - THE ROOF IS LOCATED IN A 140 MPH OR GREATER WIND ZONE



CLIENT INFO
 ASHLEIGH SOTO
 407 CONKSBURY PARK LANE
 FLOQUAY-VARINA, NC 27526

PROJECT INFO
 DC INPUT: 11.90 kW
 AC EXPORT: 10.00 kW
 DC/INSP.T. METHOD: OPTION 2

CODE REFERENCES
 NATIONAL ELECTRICAL CODE v. 2017
 NFPA 70-2017 NATIONAL FIRE PROTECTION CODE v. 2018
 NC BUILDING CODE v. 2018
 NC RESIDENTIAL CODE v. 2018
 ACSE v. 7-10

SITE CONDITIONS
 WIND SPEED: 115 MPH
 RISK CATEGORY: II
 EXPOSURE: B
 SNOW: 15 PSI

SHEET INDEX
 PV-1 COVER SHEET
 PV-2 PV STRUCTURAL
 PV-3 PV ELECTRICAL
 PV-4 PV EQUIPMENT LABELS
 PV-5 PV INSTALL GUIDE


DESIGNER INFO
 DESIGNER: CRM
 ENGINEER: AVK
 DATE: 6/10/2021
 VERSION: P1

PV SYSTEM EQUIPMENT LABELS

PV-4.1

© 2018 NC SOLAR NOW EXPRESSLY RESERVES ITS COMMON LAW COPYRIGHT AND OTHER PROPERTY RIGHTS IN THESE PLANS. THESE PLANS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MANNER WHATSOEVER, NOR ARE THEY TO BE ASSIGNED TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESSED WRITTEN PERMISSION AND CONSENT OF NC SOLAR NOW.

1 ARRAY LAYOUT DETAIL
NOT TO SCALE



NC
SOLAR
NOW



CLIENT INFO

AMANDA SOTO
407 CORNSBURY PARK LANE
FUQUAY-VARINA, NC 27526

PROJECT INFO

DC INPUT: 11.90 kW
AC EXPORT: 10.00 kW
DOWNSPT. METHOD: OPTION 2

CODE REFERENCES

NATION ELECTRICAL CODE v. 2017
NC FIRE PROTECTION CODE v. 2018
NC BUILDING CODE v. 2018
NC RESIDENTIAL CODE v. 2018
ACSE v. 7-10

SITE CONDITIONS

WIND SPEED: 115 MPH
RISK CATEGORY: II
EXPOSURE: B
SNOW: 15 PSF

SHEET INDEX

PV-1: COVER SHEET
PV-2: PV STRUCTURAL
PV-3: PV ELECTRICAL
PV-4: PV EQUIPMENT LABELS
PV-5: PV INSTALL GUIDE

DESIGNER INFO

DESIGNER: CRM
ENGINEER: AWK
DATE: 6/10/2021
VERSION: P1

PV SYSTEM INSTALL
GUIDE

PV-5.1

powered by

Q.ANTUM DUO

Q.PEAK DUO BLK-G6

330-345

ENDURING HIGH PERFORMANCE



www.VDEInfo.com
ID: 40032587



Q.ANTUM TECHNOLOGY: LOW LEVELISED COST OF ELECTRICITY

Higher yield per surface area, lower BOS costs, higher power classes, and an efficiency rate of up to 19.5%.



INNOVATIVE ALL-WEATHER TECHNOLOGY

Optimal yields, whatever the weather with excellent low-light and temperature behaviour.



ENDURING HIGH PERFORMANCE

Long-term yield security with Anti LID Technology, Anti PID Technology¹, Hot-Spot Protect and Traceable Quality Tra.Q™.



EXTREME WEATHER RATING

High-tech aluminium alloy frame, certified for high snow (5400 Pa) and wind loads (4000 Pa).



A RELIABLE INVESTMENT

Inclusive 12-year product warranty and 25-year linear performance warranty².



STATE OF THE ART MODULE TECHNOLOGY

Q.ANTUM DUO combines cutting edge cell separation and innovative wiring with Q.ANTUM Technology.

¹ APT test conditions according to IEC/TS 62804-1:2015, method B (-1500V, 168h)

² See data sheet on rear for further information.

THE IDEAL SOLUTION FOR:




Rooftop arrays on residential buildings

Engineered in Germany

Q CELLS

MECHANICAL SPECIFICATION

Format	1740 mm × 1030 mm × 32 mm (including frame)
Weight	19.9 kg
Front Cover	3.2 mm thermally pre-stressed glass with anti-reflection technology
Back Cover	Composite film
Frame	Black anodised aluminium
Cell	6 × 20 monocrystalline Q ANTUM solar half cells
Junction box	53-101 mm × 32-60 mm × 15-18 mm Protection class IP67, with bypass diodes
Cable	4 mm ² Solar cable; (+) ≥1150 mm, (-) ≥1150 mm
Connector	Stäubli MC4, Hanwha Q CELLS HQC4; IP68




ELECTRICAL CHARACTERISTICS

POWER CLASS		330	335	340	345	
MINIMUM PERFORMANCE AT STANDARD TEST CONDITIONS, STC ¹ (POWER TOLERANCE +5 W / -0 W)						
Minimum	Power at MPP ¹	P_{MPP} [W]	330	335	340	345
	Short Circuit Current ¹	I_{SC} [A]	10.41	10.47	10.52	10.58
	Open Circuit Voltage ¹	V_{OC} [V]	40.15	40.41	40.66	40.92
	Current at MPP	I_{MPP} [A]	9.91	9.97	10.02	10.07
	Voltage at MPP	V_{MPP} [V]	33.29	33.62	33.94	34.25
	Efficiency ¹	η [%]	≥18.4	≥18.7	≥19.0	≥19.3
MINIMUM PERFORMANCE AT NORMAL OPERATING CONDITIONS, NMOT ²						
Minimum	Power at MPP	P_{MPP} [W]	247.0	250.7	254.5	258.2
	Short Circuit Current	I_{SC} [A]	8.39	8.43	8.48	8.52
	Open Circuit Voltage	V_{OC} [V]	37.86	38.10	38.34	38.59
	Current at MPP	I_{MPP} [A]	7.80	7.84	7.89	7.93
	Voltage at MPP	V_{MPP} [V]	31.66	31.97	32.27	32.57

¹Measurement tolerances $P_{MPP} \pm 3\%$, I_{SC} , $V_{OC} \pm 5\%$ at STC: 1000 W/m², 25 ± 2 °C, AM 1.5 according to IEC 60904-3 • 7800 W/m², NMOT, spectrum AM 1.5


Q CELLS PERFORMANCE WARRANTY



At least 98% of nominal power during first year. Thereafter max. 0.54% degradation per year. At least 93.1% of nominal power up to 10 years. At least 85% of nominal power up to 25 years.

All data within measurement tolerances. Full warranties in accordance with the warranty terms of the Q CELLS sales organisation of your respective country.

PERFORMANCE AT LOW IRRADIANCE



Typical module performance under low irradiance conditions in comparison to STC conditions (25 °C, 1000 W/m²).

TEMPERATURE COEFFICIENTS

Temperature Coefficient of I_{SC}	α [%/K]	+0.04	Temperature Coefficient of V_{OC}	β [%/K]	-0.27
Temperature Coefficient of P_{MPP}	γ [%/K]	-0.36	Nominal Module Operating Temperature	NMOT [°C]	43 ± 3

PROPERTIES FOR SYSTEM DESIGN

Maximum System Voltage	V_{SYS} [V]	1000	PV module classification	Class II
Maximum Reverse Current	I_{SR} [A]	20	Fire Rating based on ANSI / UL 61730	C / TYPE 2
Max. Design Load, Push / Pull	[Pa]	3600 / 2667	Permitted Module Temperature on Continuous Duty	-40 °C - +85 °C
Max. Test Load, Push / Pull	[Pa]	5400 / 4000		

QUALIFICATIONS AND CERTIFICATES

VDE Quality Tested,
IEC 61215:2016,
IEC 61730:2016
This data sheet complies
with DIN EN 50380.



PACKAGING INFORMATION

	1780 mm	1080 mm	1208 mm	673.8 kg	28 pallets	26 pallets	32 modules
Horizontal packaging							
Vertical packaging	1815 mm	1150 mm	1220 mm	683 kg	28 pallets	24 pallets	32 modules

Note: Installation instructions must be followed. See the installation and operating manual or contact our technical service department for further information on approved installation and use of this product. Q CELLS supplies solar modules in two different stacking methods, depending on the location of manufacture (modules are packed horizontally or vertically). You can find more detailed information in the document "Packaging and Transport Information", available from Q CELLS.

Hanwha Q CELLS GmbH


Sonnenallee 17-21, 06766 Bitterfeld-Wolfen, Germany | TEL +49 (0)3494 66 99-23444 | FAX +49 (0)3494 66 99-23000 | EMAIL sales@q-cells.com | WEB www.q-cells.com

Specifications subject to technical changes © Q CELLS Q PEAK DUO BLK-G6_330-345_2020-04_Rev02_EN

Power Optimizer

For North America

P320 / P340 / P370 / P400 / P401 / P405 / P485 / P505



POWER OPTIMIZER

PV power optimization at the module-level

- Specifically designed to work with SolarEdge inverters
- Up to 25% more energy
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch losses, from manufacturing tolerance to partial shading
- Flexible system design for maximum space utilization
- Fast installation with a single bolt
- Next generation maintenance with module-level monitoring
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System (PVRSS)
- Module-level voltage shutdown for installer and firefighter safety

/ Power Optimizer For North America

P320 / P340 / P370 / P400 / P401 / P405 / P485 / P505

Optimizer model (typical module compatibility)	P320 (for 60-cell modules)	P340 (for high- power 60-cell modules)	P370 (for higher- power 60 and 72- cell modules)	P400 (for 72 & 96-cell modules)	P401 (for high power 60 and 72 cell modules)	P405 (for high- voltage modules)	P485 (for high- voltage modules)	P505 (for higher current modules)	
--	----------------------------------	--	---	--	--	---	---	--	--

INPUT

Rated Input DC Power ⁽¹⁾	320	340	370	400		405	485	505	W
Absolute Maximum Input Voltage (Voc at lowest temperature)	48		60	80	60	125 ⁽²⁾		83 ⁽²⁾	Vdc
MPPT Operating Range	8 - 48		8 - 60	8 - 80	8-60	12.5 - 105		12.5 - 83	Vdc
Maximum Short Circuit Current (Isc)	11			10.1	11.75	11		14	A dc
Maximum DC Input Current	13.75			12.5	14.65	12.5		17.5	A dc
Maximum Efficiency	99.5								
Weighted Efficiency	98.8								
Overvoltage Category	II								

OUTPUT DURING OPERATION (POWER OPTIMIZER CONNECTED TO OPERATING SOLAREEDGE INVERTER)

Maximum Output Current	15								
Maximum Output Voltage	60			85			Vdc		

OUTPUT DURING STANDBY (POWER OPTIMIZER DISCONNECTED FROM SOLAREEDGE INVERTER OR SOLAREEDGE INVERTER OFF)

Safety Output Voltage per Power Optimizer	1 ± 0.1								
	Vdc								

STANDARD COMPLIANCE

EMC	FCC Part15 Class B, IEC61000-6-2, IEC61000-6-3								
Safety	IEC62109-1 (class II safety), UL1741								
Material	UL94 V-0, UV Resistant								
RoHS	Yes								

INSTALLATION SPECIFICATIONS

Maximum Allowed System Voltage	1000									
Compatible inverters	All SolarEdge Single Phase and Three Phase inverters									
Dimensions (W x L x H)	129 x 153 x 27.5 / 5.1 x 6 x 1.1			129 x 153 x 33.5 / 5.1 x 6 x 1.3	129 x 153 x 29.5 / 5.1 x 6 x 1.16	129 x 159 x 49.5 / 5.1 x 6.3 x 1.9		129 x 162 x 59 / 5.1 x 6.4 x 2.3		mm / in
Weight (including cables)	630 / 1.4			750 / 1.7	655 / 1.5	845 / 1.9		1064 / 2.3		gr / lb
Input Connector	MC4 ⁽³⁾						Single or dual MC4 ⁽³⁾⁽⁴⁾	MC4 ⁽³⁾		
Input Wire Length	0.16 / 0.52									
Output Wire Type / Connector	Double Insulated / MC4									
Output Wire Length	0.9 / 2.95			1.2 / 3.9						m / ft
Operating Temperature Range ⁽⁵⁾	-40 - +85 / -40 - +185									
Protection Rating	IP68 / NEMA6P									
Relative Humidity	0 - 100									

(1) Rated power of the module at STC will not exceed the optimizer "Rated Input DC Power". Modules with up to +5% power tolerance are allowed.

(2) NEC 2017 requires max input voltage be not more than 80V

(3) For other connector types please contact SolarEdge

(4) For dual version for parallel connection of two modules use P485-4NMDMRM. In the case of an odd number of PV modules in one string, installing one P485 dual version power optimizer connected to one PV module. When connecting a single module seal the unused input connectors with the supplied pair of seals.

(5) For ambient temperature above +85°C / +185°F, power de-rating is applied. Refer to Power Optimizers Temperature De-Rating Technical Note for more details.

PV System Design Using a SolarEdge Inverter ⁽⁶⁾⁽⁷⁾	Single Phase HD-Wave	Single phase	Three Phase for 208V grid	Three Phase for 277/480V grid	
Minimum String Length (Power Optimizers)	P320, P340, P370, P400, P401	8	10	18	
	P405, P485, P505	6	8	14	
Maximum String Length (Power Optimizers)		25	25	50 ⁽⁸⁾	
Maximum Power per String	5700 (6000 with SE7600-US - SE11400-US)	5250	6000 ⁽⁹⁾	12750 ⁽¹⁰⁾	W
Parallel Strings of Different Lengths or Orientations	Yes				

(6) For detailed string sizing information refer to: http://www.solaredge.com/sites/default/files/string_sizing_na.pdf

(7) It is not allowed to mix P405/P485/P505 with P320/P340/P370/P400/P401 in one string

(8) A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement


(9) For 208V grid, it is allowed to install up to 6,500W per string when the maximum power difference between each string is 1,000W

(10) For 277/480V grid, it is allowed to install up to 15,000W per string when the maximum power difference between each string is 2,000W

Single Phase Inverter with HD-Wave Technology

for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US /
SE7600H-US / SE10000H-US / SE11400H-US



INVERTERS

Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Record-breaking efficiency
- Quick and easy inverter commissioning directly from a smartphone using the SolarEdge SetApp
- Fixed voltage inverter for longer strings
- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12
- UL1741 SA certified, for CPUC Rule 21 grid compliance
- Extremely small
- Built-in module-level monitoring
- Outdoor and indoor installation
- Optional: Revenue grade data, ANSI C12.20 Class 0.5 (0.5% accuracy)

/ Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/
SE7600H-US / SE10000H-US / SE11400H-US

Model Number	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
APPLICABLE TO INVERTERS WITH PART NUMBER	SEXXXH-XXXXXBXX4							
OUTPUT								
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
Maximum AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
AC Output Voltage Min.-Nom.-Max. (211 - 240 - 264)	✓	✓	✓	✓	✓	✓	✓	Vac
AC Output Voltage Min.-Nom.-Max. (183 - 208 - 229)	-	✓	-	✓	-	-	✓	Vac
AC Frequency (Nominal)	59.3 - 60 - 60.5 ⁽¹⁾							Hz
Maximum Continuous Output Current @240V	12.5	16	21	25	32	42	47.5	A
Maximum Continuous Output Current @208V	-	16	-	24	-	-	48.5	A
Power Factor	1, adjustable -0.85 to 0.85							
GFDI Threshold	1							A
Utility Monitoring, Islanding Protection, Country Configurable Thresholds	Yes							
INPUT								
Maximum DC Power @240V	4650	5900	7750	9300	11800	15500	17650	W
Maximum DC Power @208V	-	5100	-	7750	-	-	15500	W
Transformer-less, Ungrounded	Yes							
Maximum Input Voltage	480							Vdc
Nominal DC Input Voltage	380				400			Vdc
Maximum Input Current @240V ⁽²⁾	8.5	10.5	13.5	16.5	20	27	30.5	Adc
Maximum Input Current @208V ⁽²⁾	-	9	-	13.5	-	-	27	Adc
Max. Input Short Circuit Current	45							Adc
Reverse-Polarity Protection	Yes							
Ground-Fault Isolation Detection	600k Ω Sensitivity							
Maximum Inverter Efficiency	99	99.2						%
CEC Weighted Efficiency	99						99 @ 240V 98.5 @ 208V	%
Nighttime Power Consumption	< 2.5							W

⁽¹⁾ For other regional settings please contact SolarEdge support

⁽²⁾ A higher current source may be used, the inverter will limit its input current to the values stated

/ Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/
SE7600H-US / SE10000H-US / SE11400H-US

Model Number	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
ADDITIONAL FEATURES								
Supported Communication Interfaces	RS485, Ethernet, ZigBee (optional), Cellular (optional)							
Revenue Grade Data, ANSI C12.20	Optional ⁽³⁾							
Inverter Commissioning	with the SetApp mobile application using built-in Wi-Fi Access Point for local connection							
Rapid Shutdown - NEC 2014 and 2017 690.12	Automatic Rapid Shutdown upon AC Grid Disconnect							
STANDARD COMPLIANCE								
Safety	UL1741, UL1741 SA, UL1699B, CSA C22.2, Canadian AFCI according to T.I.L. M-07							
Grid Connection Standards	IEEE1547, Rule 21, Rule 14 (HI)							
Emissions	FCC Part 15 Class B							
INSTALLATION SPECIFICATIONS								
AC Output Conduit Size / AWG Range	1" Maximum / 14-6 AWG				1" Maximum / 14-4 AWG			
DC Input Conduit Size / # of Strings / AWG Range	1" Maximum / 1-2 strings / 14-6 AWG				1" Maximum / 1-3 strings / 14-6 AWG			
Dimensions with Safety Switch (HxWxD)	17.7 x 14.6 x 6.8 / 450 x 370 x 174				21.3 x 14.6 x 7.3 / 540 x 370 x 185			in / mm
Weight with Safety Switch	22 / 10	25.1 / 11.4	26.2 / 11.9	38.8 / 17.6			lb / kg	
Noise	< 25				< 50			dB(A)
Cooling	Natural Convection							
Operating Temperature Range	-40 to +140 / -40 to +60 ⁽⁴⁾							°F / °C
Protection Rating	NEMA 4X (Inverter with Safety Switch)							

⁽³⁾ Revenue grade inverter P/N: SExxxxH-US000BNC4

⁽⁴⁾ Full power up to at least 50°C / 122°F; for power de-rating information refer to: <https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf>